

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**


No. F6/DFS/MS/ School/2012/584

Dated: 21/02/12

FIRE SAFETY CERTIFICATE

Certified that **Tagore Shiksha Niketan, D-91, Meethapur Extn., Badarpur, New Delhi-110044**, comprised of ground floor only, was granted NOC by this department vide letter No.F6/DFS/MS/2007/2676 DT 24.09.2007. The school building was re-inspected by officer concerned of Delhi Fire Service on 02/02/2012 in the presence of Shri Hemant Kaushik, Manager of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from 21/02/12 for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 21/02/12 at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service



Copy To: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Manager, Tagore Shiksha Niketan ,
D-91, Meethapur Extn, Badarpur, New Delhi-110044

Conditions for the validity of fire safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building: Tagore Shiksha Niketan. G.I.D. Block.
: Meethapur Extn Badaypur New Delhi-110044.
2. Type of Occupancy : Elevation.
3. Type of Case : old
4. Details of previous NOC : FG / DFR / MS / 2007 / 2676 dt 24/9/12
5. Fire Safety directives letter No : _____ Dated: _____
6. Date of Inspection : 2/2/12
7. Name of the Inspecting Officers : Rajan wadehra. AAO/m. Road
8. Name and designation of Officers
From the building side : Shri Hemant Kaushik. (Manager)
9. Year of Construction : Ground Floor
10. Applicant's letter No : _____

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	15Mts	15Mts	M/R
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits		NA	
	• Number of staircase			
	➤ Upper Floors			
	➤ Basements			
	• Width of Staircases		NA	
	➤ Upper Floors			
	➤ Basements			
	• Protection of exits		NA	
	➤ Fire check door			
	➤ Pressurization			
	• No. of continuous staircases to terrace		NA	
	• Width of Corridor			
	• Door Size			

3	Compartmentation			NA
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	/	/	/
4	Smoke Management System			NA
	<ul style="list-style-type: none"> • Basements • Upper Floors 	30 a/c Per hour 12 a/c Per hour	/	/
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	1 ext 300m ² ISI mark	05 Nos. 05 ABC YES	MIR MIR YES.
6	Firs-Aid Hose Reels			NO
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	_____ 30 m 5mm	/	/
7	Automatic Fire detection and alarming system			NA
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 	/	/	/
8	MOEFA			NA
9	Public Address System			NA
10	Automatic Sprinkler System			NA
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	/	/	/
11	Internal Hydrants			NA
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 	/	/	/
12	Yard Hydrants			NA
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 	/	/	/

Special Fire Protection System for
Protection of special risk, if any

NA

NA


NA

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / issue shortcomings as noted at serial number.....

DO (South)


18/2/12


Signature of Inspecting Officer
Name : RAJAN WADEHRA
Designation: ASST. DIV. OFFICER