

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI – 110001

No: F 6/DFS/MS/2012/ school / 615

Dated:- 24/02/2012

FIRE SAFETY CERTIFICATE

Certified that the Sree Chaitanya Public School Sect-5, Near Rithala
Metro Stn Rohini located at Sect-5 Rohini Delhi 110085
..... comprised of Ground floor only occupied
by Sree Chaitanya Pub-School was issued NOC vide this office letter
No F-6/DFS/MS/2006/2825 Dated: 29/9/06 The premises was re-inspected by the
officer concerned of this department on 1-2-2012 and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement under Rule 33
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class
Educational with effect from 24/02/2012 for a period of
03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 24/02/2012 at New Delhi.



Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education
Govt. g. net of Delhi
old Sectt.
Civil line Delhi
2. The Authorized Signatory
Sree Chaitanya Public School
Sect-5, Near Rithala Metro Stn,
Rohini Delhi 110085



old case

INSPECTION REPORT

1. Name & address of the building : SREE CHAITANYA PUBLIC SCHOOL, Sect-5, Rohini, -Delhi-85
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-3/DPS/MS/2006/2925 Dated: 29-9-06
5. Fire Safety directives letter No : •
6. Date of inspection : 01-2-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Ms. Sunita Banerjee (Employee.)
9. Year of Construction : 2004 (Ground floor only)
10. Applicant's letter No. : SCPS/2011 dated 19-12-2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular NBC Dir. Edn. Requirement 17/1/2005</u>	Provided at site	Remarks MR/NM
1	Access to building			
	• Road width	<u>Accessible</u>	<u>09.00 m</u>	<u>M/R</u>
	• Gate width	<u>~</u>	<u>4.5 m</u>	<u>~</u>
	• Width of internal road	<u>~</u>	<u>open ground</u>	<u>~</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		<u>NA</u>	
	• Upper Floors		<u>NR</u>	
	• Basements			
	b. Width of staircases		<u>N/A</u>	
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	<u>~</u>	<u>1 m</u>	<u>M/R</u>
	h. Door Size	<u>1 m -</u>	<u>0.93 m old case</u>	<u>M/R</u>

				NIR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			NIR
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 ABC/CO2 2.5kg. 300M ² for one. ISI marked	6 ABC 5kg. yes	NIR ~ ~
6	First-Aid Hose Reels.			NIR
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm		
7	Automatic fire detection and alarming system.			NIR
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA			NIR
9	Public Address System.		NIR	Provided.
10	Automatic Sprinkler System.			NIR
	<ul style="list-style-type: none"> • Basement 			

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 		NR	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		NR	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		NR	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 		NR	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	Gr. Floor only	M/R	
16	Provision of Lifts.		N/A	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		N/R	
18	Refuge Area.		N/A	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room		N/R	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:		Nil	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

X

Signature of the Inspecting Officer

Name

Designation

D.O. (N.W.)

Shyam Lal
02/2/2012

Signature of the Inspecting Officer

Name SHYAM LAL

Designation Assitt. Divn. Officer

For old case : change mo