

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI-110 001

No. F6/DPS/MS/school/2012/93

Dated: 10/01/12

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Vidyalaya** located at F.U. Block, Pitampura, Dlehi-34 have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules.2010 and verified by Mr. Raj Mal Khokhar, ADO (W.P) on 11.12.2011in the presence of Sh. O. S. Dhaka (Principal), Sarvodaya Vidyalaya and that the building/premises is fit for occupancy Class B (**Educational**) with effect from 10/01/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/01/12 at New Delhi by.



DIRECTOR

Delhi Fire Service

OK
Raj Mal Khokhar
A.D.O.



To:

Sh. O. S. Dhaka (Principal)
Sarvodaya Vidyalaya,
F.U. Block, Pitampura
Delhi-34

Copy to: -

The Director of Education
Old Secretariat,
Delhi

Following fire safety directives must be adhered to: -

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
4. Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building Bye-Laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May kindly see the letter no. S.V.F.V./11/448 dated 02.09.2011 received from Sh. O. S. Dhaka (Principal), Sarvodaya Vidyalaya at F.U. Block, Pitampura, Delhi-34 regarding issuance of NOC from fire safety point of view. Premises was inspected by the ADO (WP) on 11.12.2011 & observed that the school building is comprised of ground & three upper floors only having plot area approx 16000 sq. mtrs. and covered area is 8000 sq. mtrs. approx.

The point wise compliance of fire safety recommendations with the Delhi Fire Service Act-2007 & rules 2010 are given below:-

INSPECTION REPORT				
1	Name & Address of the building	Sarvodaya Vidyalaya		
	Type of occupancy	F.U. Block, Pitampura, Delhi-34		
	Type of case	Educational		
3	Details of previous NOC	New Case (old Building)		
4	Fire Safety directives letter no.	Nil		
5	Date of Inspection	Nil		
6	Name of the Inspecting officers	11.11.2011		
7	Name and designation of officers from the building side	Mr. Raj Mal Khokhar, ADO(WP)		
8	Year of Construction	Sh. O. S. Dhaka (Principal)		
9	Applicant's letter no.	Year 2000 (Old Building)		
10		S.V.F.V./11/448 dated 02.09.2011		
S.N	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 mtrs.	9 mtrs.	MR
	Gate width	5 mtrs.	5 mtrs.	MR
	Width of internal road	NR	NP	
2	Number, Width, type & Arrangement of Exits			
	a. Number of staircases	4 nos.	Provided	MR
	Upper Floors	4 nos.	Provided	MR
	Basement			
	a. Width of staircases			
	Upper Floors	1.5 mtrs. each	Provided	MR
	Basements	NA	NA	
	b. Protection of exits			
	Fire check door	NR	NP	
	Pressurization	NR	NP	
	c. No. of continuous staircases to terrace	4 nos.	Provided	MR
	d. Width of Corridor	6 feet	Provided	MR
	e. Door Size	1 mtr. width & 2 mtrs. in height in each room	Provided	MR
3	Compartmentation			
	• Fire check door	NR	NP	
	• Sealing of electrical shafts	NR	NP	
	• Fire Rating of shaft door	NR	NP	
	• Water curtain	NR	NP	
	• Fire Dampers	NR	NP	
4	Smoke Management System			
	• Basements	NR	NP	
	• Upper Floors	NR	NP	

5	Fire Extinguishers • Total numbers • Types • ISI marking	20 Nos.	Provided	MR
		10 nos. ABC type cap. 5 kg. & 10 nos. CO2 type cap. 4.5 kg.	Provided	MR ✓
		Yes	Provided	MR ✓
		12 nos.	Provided	MR ✓
6	First-Aid Hose Reels • Total numbers on each floor • Length of hose reel hose • Nozzle diameter	3 nos	Provided	MR
		30 mtrs	Provided	MR
		0.5 mm	Provided	MR
7	Automatic fire detection and alarming system • Type of detectors • Location of Main panel • Location of repeater Panel • Alternation source of power • Hooter's location	NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		Required	Provided	MR ✓
8	MOEFA	Required	Provided	MR ✓
9	Public Address System			
10	Automatic Sprinkler System • Basement • Upper Floor • Sprinkler above false ceiling	NA	NA	
		NR	NP	
		NA	NA	
11	Internal Hydrants • Size of riser/down-comer • Number of hydrants per floor • Hose Box	NR	NP	
		-	-	-
		-	-	-
12	Yard Hydrants • Total number of hydrants • Hose Box	NR	NP	
		NR	NP	
13	Pumping Arrangements • Ground Level • Discharge of main pump • Head of Main pump • Number of main pumps • Jockey pump output • Jockey Pump Head • Standby Pump output • Standby pump head • Auto starting/Manual stopping • Pump House Access • Terrace Level • Discharge of the pump • Head of the Pump • Power Supply • Auto Starting of Pump	NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		Required	Provided	MR ✓
		450 LPM	Provided	MR ✓
		40 mtrs	Provided	MR ✓
-	-	-		
-	-	-		
14	Captive Water Storage for fire fighting • Underground tank capacity • Draw-off connection • Fire Service inlet • Access to tank • Overhead Tank capacity	NR	NP	
		NR	NP	
		NR	NP	
		NR	NP	
		15000 ltrs	Provided	MR ✓
		Required	Provided	MR ✓
15	Exit Signage			

16	Provision of Lifts			
	• Pressurization of Lift Shaft		NP	
	• Pressurization of Lift Lobby		NP	
	• Communication in lift car		NP	
	• Fireman's Grounding Switch	NR	NP	
	• Lift Signage	NR	NP	
17	Standby Power Supply	NR	NP	
18	Refuge Area			
	• Total Area	NR	NP	
	• Location	NR	NP	
19	Fire Control Room			
	• Detector System Panel	NR	NP	
	• Flow Switch Panel	NR	NP	
	• PA system Panel	NR	NP	
	• Batter backup	NR	NP	
	• Building Floor Plans	NR	NP	
20	Special Fire Protection Systems for Protection of special Risks, If any:	NA	NA	

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew the Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 . 'Form H' is put up for favour of approval and signature please.


Signature of the Inspecting officer

Signature of the Inspecting officer

Name RAJ MAL KHOKHAR

Name

Designation A.D.O.

Designation