

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DGS/MS/FW/2012/358

Dated: 02 / 02 / 2012

**FIRE SAFETY CERTIFICATE**

Certified that the Master G & Bros, Fire works Shop / Thara No 12, Nangloi J.J. Colony, (Shop No 12, DDA Market, Nangloi,) Delhi-41 proposed for running the trade of Sale and Possession of 300 Kgs Fire Works and 1200 Kg Chinese sparkles at the ground floor of a building owned / occupied by Smt Alka and Sh Akhil, have complied with the fire prevention and fire safety Requirements in accordance with Guidelines issued by Additional Commissioner of Police (Lic.) and verified by the officer concered of fire service on 19/11/2011 in the presence of Sh Akhil and that the Shop is fit for occupancy Class Fire Works with effect from 02/02/12 for a period of three years subject to conditions given below.

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional of fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock when shop is open.
4. Any deviation w.r.t. construction etc shall be verified by concerned building sanctioning authority.
5. This certificate may not be treated in any case for regularization of unauthorized construction, if any.

Issued on 02 / 02 / 2012 at New Delhi by



Chief Fire Officer  
For Director  
Delhi Fire Service

Copy to:

1. The Additional Commissioner of Police (Lic), 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi w.r.t L. No (PFW / 1 / 2011) / 20091-93 / Addl. CP/Lic. (Expl.), dated 11/05/2011
2. Smt Alka & Sh Akhil, Master G & Bros Fire works Shop No 12, DDA Market, Nangloi, Delhi-41



M-1

Please refer to letter No L. No (PFW / 1 / 2011) / 20091-93 / Addl. CP/Lic. (Expl.), dated 11/05/2011 regarding grant of permanent fire works license in respect of Master G & Bros owned by Smt Alka and Shri Akhil, located at Shop / Thara No. 12, Nangloi, J. J. Colony, ( Shop No 12, DDA Market, Nangloi ) Delhi-41. In this connection the premises was inspected by the Assistant Divisional Officer (Fire) on 19/11/2011 with a view to ascertain the fire safety of the premises.

During the course of inspection, it has been observed that the shop mentioned at above address is situated on the ground floor, measuring 17.50 sq meters area. The owner intends to run the trade of selling and storage of fire works in the premises. **The Shop is in DDA market and abuts on 4 mtr wide road leading from 13.5 mtr road at a one hose length distance.**

The fire safety arrangements such conduit / concealed electrical wiring, Miniature Circuit Breaker, two numbers of ISI marked fire extinguishers i.e. water Co2 9 ltrs capacity and DCP fire extinguisher of 5 kg capacity, 02 nos of sand and water buckets each and no smoking sign board were found provided. There is no adjoining shop of fire works.

In view of above, there is no objection for the grant of license from fire and safety point of view for the sale and storage of fire works subject to clearance/ decision of **highlighted portion.**

DFA will be put up accordingly.

*Guish*  
9/1/12

DO(MN)

May kindly advice at 'A'