

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/ms/Banquet/2012/245

Dated: 27 / 01 / 2012

**FIRE SAFETY CERTIFICATE**

Certified that the Wok in the Clouds (Banquet Hall) located at FC 01 3<sup>rd</sup> floor TDI Mall, Shivaji Place, Rajouri Garden, New Delhi., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 04.01.12 in presence of Mr. Deepak (Manager) of Banquet Hall and that the premises is fit for Class-D (Assembly) occupancy with effect from ...27./01./12.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...27./01./12.....at New Delhi by



Chief Fire Officer  
Delhi Fire Service

Copy to:

1. DHO West Zone  
M.C.D. of Delhi, West Zone ,  
Rajouri Garden, New Delhi,
2. Wok in the Clouds (Banquet Hall)  
FC 01 3<sup>rd</sup> floor TDI Mall, Shivaji Place,  
Rajouri Garden, New Delhi

Note :- For general fire safety directives please over leaf.



Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

	b. Width of staircases			
	• Upper Floors	1.5 mtr & 1.25 mtrs	Provided	of the Mall/M.R
	• Basement	1.5 mtr & 1.25 mtrs	Provided	of the Mall/M.R
	c. Protection of exits			
	• Fire check door	Required	Provided	of the Mall/M.R
	• Pressurization	Required	Provided	of the Mall/M.R
	d. No. of continuous staircases to terrace	5	provided	of the Mall/M.R
	e. Width of Corridor	2	2.5	of the Mall/M.R
f. Door size	2 mtrs	Provided by the Banquet management	Provided by the Banquet management/M.R	
3.	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	of the Mall/M.R
	• Sealing of electrical shafts	Required	Provided	of the Mall/M.R
	• Fire Rating of shaft door	1 hrs	Provided	of the Mall/M.R
	• Water Curtain	N.R.	N.A.	of the Mall/M.R
	• Fire Dampers	Required	Provided	of the Mall/M.R
	4.	<b>Smoke Management System.</b>		
	• Basements	Required	Provided	of the Mall/M.R
	• Upper floors	Required	Provided	of the Mall/M.R
5.	<b>Fire Extinguishers</b>			
	• Total numbers	06	Provided 10 fire extinguisher in the Banquet hall	of the banquet hall/M.R
	• Types	ABC & CO <sub>2</sub>	provided	M.R



May Kindly peruse letter no. D-1680/HD/WZ dated 30-11-2011 received from DHO West Zone regarding issue of NOC in r/o Wok in the Clouds Banquet Hall located at FC 01 3<sup>rd</sup> floor TDI Mall, Shivaji Place, Rajouri Garden, New Delhi. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa. All the fire fighting arrangements & staircase of the mall will be used for Banquet Hall also.

1. Name & address of the building : Wok in the Clouds (Banquet Hall) located FC 01 3<sup>rd</sup> floor TDI Mall, Shivaji Place, Rajouri Garden, New Delhi.
2. Type of Occupancy : Class -D (Assembly)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS/2008/2016 dated 18/07/2008 (For Mall)
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 04.01.2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chawdhary & ADO S.S. Tuli
8. Name and designation of officers  
From the building side : Mr. Deepak (Manager)
9. Year of Construction :
10. Applicant's letter No. : D-1680/HD/WZ dated 30-11-2011

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	09mtrs	30 mtr	of the Mall/M.R
	• Gate width	6 mtr	6 mtr	of the Mall/M.R
	• Width of internal road	12 mtr, 9 mtr & 7.5 mtr	6 mtr	of the Mall/M.R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	8	Provided	of the Mall/M.R
	• Upper Floors	Three	Provided	of the Mall/M.R
	• Basement	8+2 ramps	Provided	of the Mall/M.R

	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	required	provided	M.R
<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	four	three	of the Mall/M.R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	required	of the Mall/M.R
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	provided	of the Mall/M.R
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke & Heat	Provided	of the Mall/M.R
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Ground floor	Provided	of the Mall/M.R
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	Ground floor	Provided	of the Mall/M.R
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	of the Mall/M.R
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	All over building	Provided	of the Mall/M.R
<b>8.</b>	<b>MOEFA</b>	Required	Provided	of the Mall/M.R
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	of the Mall/M.R
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	of the Mall/M.R
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	of the Mall/M.R
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	of the Mall/M.R
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150 mm	Provided	of the Mall/M.R
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	4	4	of the Mall/M.R

	• Hose Box	4	4	of the Mall/M.R
<b>12.</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants	4	4	of the Mall/M.R
	• Hose Box	4	4	of the Mall/M.R
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	4500 LPM	Provided	of the Mall/M.R
	➤ Head of Main pump	65 mtr	Provided	of the Mall/M.R
	➤ Number of main pumps	2	Provided	of the Mall/M.R
	➤ Jockey Pump out put	180 LPM	Provided	of the Mall/M.R
	➤ Jockey pump head	65 mtr	Provided	of the Mall/M.R
	➤ Standby pump out put	4500 LPM	Provided	of the Mall/M.R
	➤ Standby pump Head	65 mtr	Provided	of the Mall/M.R
	➤ Auto Starting/Manual stopping	Required	Provided	of the Mall/M.R
	➤ Pump Hose Access	Required	Provided	of the Mall/M.R
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided	of the Mall/M.R
	➤ Head of the pump	65 mtr	Provided	of the Mall/M.R
	➤ Power supply	Required	Provided	of the Mall/M.R
	➤ Auto Starting of pump	Required	Provided	of the Mall/M.R



<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	One lakh	provided	of the Mall/M.R
	➤ Draw -off connection	Required	Provided	of the Mall/M.R
	➤ Fire service inlet	Required	Provided	of the Mall/M.R
	➤ Access to tank	Required	Provided	of the Mall/M.R
	➤ Overhead Tank Capacity	Required 30,000 ltrs	Provided	of the Mall/M.R
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	of the Mall/M.R
<b>16.</b>	<b>Provision of Lifts</b>			
		Required	Provided	of the Mall/M.R
	• Pressurization of Lift Shaft	Required	Provided	of the Mall/M.R
	• Pressurization of Lift lobby	Required	Provided	of the Mall/M.R
	• Communication In lift Car	Required	Provided	of the Mall/M.R
	• Fireman's Grounding Switch	Required	Provided	of the Mall/M.R
	• Lift Signage	Required	Provided	of the Mall/M.R
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	of the Mall/M.R
<b>18.</b>	<b>Refuge Area</b>			
	➤ Total Area	N.R.	N.R.	not applicable
	➤ Location	N.R.	N.R.	not applicable
<b>19.</b>	<b>Fire Control Room</b>			
	➤ Detector System Panel	Required	Provided	of the Mall/M.R
	➤ Flow Switch Panel	Required	Provided	of the Mall/M.R
	➤ PA system Panel	Required	Provided	of the Mall/M.R

	➤ Batter backup	Required	Provided	of the Mall/M.R
	➤ Building Floor plans	Required	Provided	of the Mall/M.R
20.	Special Fire Protection Systems for  Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

  
Signature of the Inspection Officer

Name

Name *SUNIL CHAUDHARY*

Designation

Designation *D.O. (west)*