

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI**


No. F6/MS/DFS/GH/ 2012/ 426

Dated: 07/02/12

FIRE SAFETY CERTIFICATE

Certified that the Annapurna Guest House located at 680, C.M. Road, Feteah Puri, Delhi comprised of ground floor (Commercial use), 1st floor (Dinning Hall), 2nd floor (Reception + 03 guest rooms) 3rd floor (03 guest rooms) and 4th floor (Generator room + 01 store room) total 06 guest rooms was granted NOC by this department vide letter No. F6/DFS/MS/GH/2008/3535 dated 24-12-2008. The premises was re-inspected by the officer concerned of this department on 19-01-2012 in the presence of Sh. Sanjeev Soni and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 06 rooms with effect from 07/02/2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 07/02/12 at New Delhi by.


CHIEF FIRE OFFICER
for DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi – 110049
2. M/s Annapurna Guest House, 680, C.M. Road, Feteah Puri, Delhi-110006

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

Building Covered under Special Area

old

L.No. F.6/MS/DPS/2001/1795 dated 29-8-2001

INSPECTION REPORT

1. Name & address of the building : Annapurna Guest House, 680, Church Mission Road, Patch Puri Delt - 6
2. Type of Occupancy : Group A-1 Residential
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F.6/MS/DPS/GH/08/3535 Dated: 24.12-2008
5. Fire Safety directives letter No : F.6/MS/DPS/GH/2001/1995 dt 2-11-2000 & F.6/MS/DPS/GH/01/2001/197
A.F.6/MS/DPS/GH/01/218 dt 2/2/01
6. Date of inspection : 19/01/2012
7. Name of the Inspecting Officers : A.D.O - Dharamveer Singh Yadav
8. Name and designation of officers from the building side : Owner - Sh. Sanjeev Soni
9. Year of Construction : 1960
10. Applicant's letter No. : 45817/Addl CP/Lic. (H) dt. 27/9/2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	^{NBC} Circulars G.H. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr.	6 mtr	MR
	• Gate width	NA	NA	MR
	• Width of internal road	NA	NA	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	ONE	ONE	MR
	• Upper Floors	ONE	ONE	MR
	• Basements	NIL	NIL	-
	b. Width of staircases	80 cm	80-85cm	MR
	• Upper Floors	80 cm	80-85cm	MR
	• Basements	NIL	NIL	MR
	c. Protection of exits	NR	NR	MR
	• Fire check door	NR	NR	MR
	• Pressurization	NR	NR	MR
	e. No. of continuous staircases to terrace	ONE	ONE	MR
	g. Width of Corridor	NA	NA	MR
	h. Door Size	NA	NA	MR

contd: -

			N-A	
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.		N.A.	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 ABC, CO ₂ , WCO ₂ ISI marked	6 ABC, CO ₂ , WCO ₂ Yes	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on ^{first} each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one provided provided	MR MR MR
7	Automatic fire detection and alarming system.		N.A.	
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	NR	NR	-
9	Public Address System.	R-provided	provided	MR
10	Automatic Sprinkler System.		N.A.	
	<ul style="list-style-type: none"> • Basement 			

contd :-

Annapurna Guest House.

Signature of the Inspecting Officer

Name

Designation

D.O. (Central) 
2/2/12

Signature of the Inspecting Officer

Name

Designation Asstt. Div. Officer
(Central)


01-02-12

DHARAM VIK SINGH YADAV