

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No *F6/DFS/MS/Industrial/2012/707* Dated *28/02/12*

FIRE SAFETY CERTIFICATE

Certified that the M/S B.N.Enterprises located at 203, F.I.E. Patpar Ganj Industrial Area Delhi. which comprises of basement, ground & first floor was granted NOC by this deptt. vide letter No. F6 / DFS / MS / 2006 / 2166 dated 22-8-2006. The premises was re-inspected by the officer concerned of this deptt. on 6-2-2012 in the presence of Mr. Ramesh Manager and found that the bldg. have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of Industrial bldg.with effect from *28-2-* 2012 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *28/02/12* at New Delhi.



CHIEF FIRE OFFICER
DELHI FIRE SERVIC



Copy to :-

1. General Manager
M/S B.N.Enterprises
203, F.I.E. Patpar Ganj,
Industrial Area, Delhi.
2. The Administrative Officer (FL)
Municipal Corporation of Delhi
Factory Licensing Deptt.,
Nigam Bhawan Kashmere Gate,
Delhi.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basements shall be used as per BBL
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

INSPECTION REPORT

1. Name & address of the building : B. N. Enterprises, 203 FIE Patparganj, N Delhi
2. Type of Occupancy : Indl. (G)
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F6/DFS/m/s/2006/2166 Dated: 22.8.2006
5. Fire Safety directives letter No : _____
6. Date of inspection : 06.02.2012
7. Name of the Inspecting Officers : Guramukh Singh
8. Name and designation of officers from the building side : Mrs. Ramesh Manager & other staff
9. Year of Construction : 2004
10. Applicant's letter No. : -NIL- dt. 4.1.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Existing Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 mtr.	13.5 mtr.	MR
	• Gate width	4.5 mtr.	4.5 mtr.	
	• Width of internal road	—	—	
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2 NOS.	2 NOS.	MR
	• Basements	2 NOS.	2 NOS.	
	b. Width of staircases			
	• Upper Floors	1.25 mtr. 75 cm	1.25 mtr. & 77 cm	MR
	• Basements	1.25 mtr.	1.25 & 1.06 mtr.	
	c. Protection of exits			
	• Fire check door	NA	NA	
	• Pressurization	/	/	
	e. No. of continuous staircases to terrace	one	one	MR
	g. Width of Corridor	NA	NA	
	h. Door Size	1.0 mtr.	1.0 mtr.	MR

3	Compartmentation.					
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	}		
		Regd.	Sealed			
		NA	NA			
		NA	NA			
		NA	NA			
4	Smoke Management System.					
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust fans provided.	✓ ✓		
5	Fire Extinguishers					
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	4 Nos. CO ₂ & W CO ₂ ISI marked	12 Nos. CO ₂ & W CO ₂ YES	MR. - - - -		
6	First-Aid Hose Reels.					
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one 30 mts. 5 mm	MR MR MR		
7	Automatic fire detection and alarming system.	NA	NA			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	/	/			
8	MOEFA			Regd.	Provided.	MR
9	Public Address System.			NA.	NA.	MR.
10	Automatic Sprinkler System.					
	<ul style="list-style-type: none"> • Basement 			Regd.	Provided.	MR.

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	NA	NA	
		NA	NA	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	4" dia	4" dia	MR
		one	one	MR
		one	one	MR
12	Yard Hydrants.	NA	NA	
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	/	/	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	—		
		NA	1620 LPM	MR
		NA	40 mtr.	-11-
		NA	2 Nos.	Both directly connected with DG set above.
		NA	180 LPM	MR
		NA	38 mtr.	MR
		NA	NA	—
		—	—	
		—	Auto	MR
		—	Accessible	MR
		450 LPM	900 LPM	MR
		—	38 mtr.	MR
		—	Auto	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	25,000 Ltr	25,000 Ltr	MR
		Regal	Provided	MR

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	Resol. Accessible 15000 Ltrs	Provided Accessible 15,000 lbs.
15	Exit Signage.	Resol.	Provided.
16	Provision of Lifts.	N.A.	N.A.
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		
17	Standby power supply	Resol.	Provided.
18	Refuge Area.	N.A.	N.A.
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		
19	Fire Control Room	N.A.	N.A.
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire protection required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Ashtom
16/2/12

Signature of the Inspecting Officer

Name *Guramkh Singh*

Designation *ADD (LN)*

Signature of the Inspecting Officer

Name

Designation

DO(E)

Submitted for approval please.

11
5