

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2012/410

Dated: 07/02/2012

FIRE SAFETY CERTIFICATE

Certified that the M/s Khaaja Chowk (a unit of Economy Foods) TF-03, City Square, Shivaji place, Raja Garden New Delhi-110027., comprised of basement, ground floor & three upper floors was granted NOC by this department vide letter No. F6/DFS/MS/ EH//2008//3229 dated 24/11/2008. The premises was re-inspected by the officers concerned of this department on **30/01/2012** in the presence of Mr. Kavya Tandon of the restaurant and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for Class-D (Assembly) occupancy with effect from 07/02/12 for a period of three years subject to conditions printed below.

Issued on 07/02/12 at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service

etc
MMS

Copy to:
M/s Khaaja Chowk (a unit of Economy Foods)
TF-03, City Square, Shivaji place, Raja Garden
New Delhi-110027

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated 05-01-2012 received from Sh. Kavya Tandon Khaaja Chowk regarding issue of NOC in r/o M/s Khaaja Chowk (a unit of Economy Foods) TF-03, City Square, Shivaji place, Raja Garden New Delhi-110027. This Mall has already been issue NOC wide letter no. F6/DFS/MS/2005/2314 dated 08/11/2005. However following fire safety points are put up on the prescribe Performa.

1. Name & address of the building : M/s Khaaja Chowk (a unit of Economy Foods) TF-03, City Square, Shivaji place, Raja Garden New Delhi-110027
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/ EH//2008//3229 dated 24/11/2008
5. Fire Safety directives letter No. : Nil
6. Date of inspection :
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary & A.D.O. S.S. Tuli
8. Name and designation of officers
From the building side : Kavya Tandon
9. Year of Construction :
10. Applicant's letter No. : nil dated 05-01-2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09mtrs	30 mtr	M/R
	• Gate width	5 mtr	5 mtr	M/R
	• Width of internal road	6 mtr	6 mtr	M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Three	Three	In Mall/M.R
	• Basement	Five	Five	" / M.R

b. Width of staircases				
	• Upper Floors	1.5 mtr & 1.25 mtrs	Provided	Specification has already been checked during earlier inspection.
	• Basement	1.5 mtr & 1.25 mtrs	Provided	M.R.
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	Required	Provided	M.R.
	d. No. of continuous staircases to terrace	three	three	M.R.
	e. Width of Corridor	Required	Provided	M.R.
f. Door size	Minimum Two exits of 2 mtrs width	Provided	M.R.	
3.	Compartmentation.			
• Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers	Required	Provided	In Mall/ M.R.	
	Required	Provided	“ / M.R.	
	2 hrs	Provided	“ / M.R.	
	Required	Provided	In Mall / M.R.	
	Required	Provided	“ / M.R.	
4.	Smoke Management System.			
• Basements • Upper floors	Required	Provided	In Mall / M.R.	
	Required	Provided	“ / M.R.	
5.	Fire Extinguishers			
• Total numbers	20	provided	“ / M.R.	
• Types	ABC & CO ₂			

	<ul style="list-style-type: none"> IS marking 	required	provided	“ / M.R
			provided	“ / M.R
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	two	two	In Mall/M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 mtr	“ / M.R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	5 mm	“ / M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat	Provided	In Mall/M.R
	<ul style="list-style-type: none"> Location of Main Panel 	Ground floor	Provided	“ / M.R
	<ul style="list-style-type: none"> Location of Repeater Panel 	Ground floor	Provided	“ / M.R
	<ul style="list-style-type: none"> Alternate source of power 	Required	2 generator 450 KVA each	“ / M.R
	<ul style="list-style-type: none"> Hooter's Location 	Required	Provided	“ / M.R
8.	MOEFA	Required	Provided	“ / M.R
9.	Public Address System.	Required	Provided	“ / M.R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	“ / M.R
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	“ / M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	“ / M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	150 mm	“ / M.R
	<ul style="list-style-type: none"> Number of hydrants per floor 	2	2	“ / M.R.

	• Hose Box	2	2	“ / M.R
12.	Yard Hydrants.			
	• Total number of hydrants	4	Provided	“ / M.R
	• Hose Box	required	Provided	“ / M.R
13.	Pumping Arrangements.			
	Ground Level	Required	Provided	It has already been checked during earlier inspection In Mall /M.R
	➤ Discharge of main pump	2850 LPM	Provided	” ”
	➤ Head of Main pump	80 mtr	Provided	” ”
	➤ Number of main pumps	2	Provided	” ”
	➤ Jockey Pump out put	180 LPM	Provided	” ”
	➤ Jockey pump head	80 mtr	Provided	” ”
	➤ Standby pump out put	2850 LPM	Provided	” ”
	➤ Standby pump Head	80 mtr	Provided	” ”
	➤ Auto Starting/Manual stopping	Required	Provided	” ”
	➤ Pump Hose Access	Required	Provided	” ”
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	” ”
	➤ Head of the pump	80 mtr	Provided	” ”
	➤ Power supply	Required	Provided	“ / M.R

	➤ Auto Starting of pump	Required	Provided	“ / M.R
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	100,000	100,000	“ / M.R
	➤ Draw -off connection	Required	Provided	“ / M.R
	➤ Fire service inlet	Required	Provided	“ / M.R
	➤ Access to tank	Required	Provided	“ / M.R
	➤ Overhead Tank Capacity	Required 30,000 ltrs	Provided	“ / M.R
15	Exit Signage.	Required	Provided	In Mall & Restaurant
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	Required	Provided	In Mall / M.R
	• Pressurization of Lift lobby	” ”	” ”	” ”
	• Communication In lift Car	” ”	” ”	” ”
	• Fireman’s Grounding Switch	” ”	” ”	” ”
	• Lift Signage	” ”	” ”	” ”
17.	Standby power supply	Required	Provided	In Mall/ M.R
18.	Refuge Area	N.R.	N.R	In Mall/ M.R
	➤ Total Area	” ”	” ”	” ”
	➤ Location	” ”	” ”	” ”
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided	In Mall/ M.R

	➤ Flow Switch Panel	Required	Provided	” ”
	➤ PA system Panel	Required	Provided	” ”
	➤ Batter backup	Required	Provided	” ”
	➤ Building Floor plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Name

Designation

S. S. Tuli
S. S. Tuli
ADD (MNS)

Signature of the Inspection Officer

Name SUNIL (HAWAIDAR)

Designation D.O (MNS)