

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**


No F 6 / DFS / MS / 2012 / EH/431

Dated 08/02/12

**FIRE SAFETY CERTIFICATE**

Certified that the Mocha Restaurant, GF-9A,12, T-12A, Main Hauz Khas Village, Delhi comprised of Ground Floor only. The premises was inspected by the officer concerned of this department on 01.02.2012 in the presence of Mr. Goyal and found that the said restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class Group – D Assembly with effect from 08/02/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/02/12 at New Delhi by.

  
Chief Fire Officer  
For Director  
Delhi Fire Service  
9/4

To

1. The Dy. Health Officer, Health Department, South Zone, MCD, New Delhi.
2. Mocha Restaurant, GF-9A,12, T-12A, Main Hauz Khas Village, Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The Basement shall be used as per the provisions of **BBL**.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECITON REPORT

- 1) Name & address of the building: Mocha Restaurant, GF-9A,12, T-12A, Main Hauz Khas, Village, Delhi
- 2) Type of Occupancy : Assembly (Restaurant)
- 3) Type of Case : New Case
- 4) Details of previous NOC : - N/A
- 5) Fire Safety directives Letter No. : N/A
- 6) Date of inspection : 01.02.2012
- 7) Name of the Inspecting Officer : DO Dharam Pal & ADO SJK
- 8) Name and designation of Officer  
from the building side : Mr. Goyal
- 9) Year of Construction : 1980
- 10) Applicant's letter No. : D/2838/DHO/52 Dated 05.12.2011

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6mtr	6 mtr	MR
	• Gate width	2 mtr	2.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	NA
	b. Width of staircases	-	-	-
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	YES	YES	MR
	• Pressurization	N/A	N/A	N/A

	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	2 & 1.5	2 & 1.5	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	6	YES	MR
	• Types	WT,CO <sub>2</sub> ,ABC	YES	MR
	• IS marking	YES	YES	MR
6.	First – Aid Hose Reels			
	• Total numbers	-	02	MR
	• Length of hose reel hose	30 m	30 mm	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	At entrance	YES	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	YES	D.G Set	MR
	• Hooters' Location	Public Area	YES	MR
8.	MOEFA	YES	YES	MR
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100 m	Provided	MR
	• Number of hydrants	01	01	MR
	• Hose Box	01	YES	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			

	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> </ul>			MR
		450	450 LPM 01 No.	MR
	➤ Head of main pump	40 m	40 m	MR
	➤ Number of main pumps	01	01	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	40 m	40 m	MR
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	Yes	Yes	MR
	➤ Pump House Access	YES	YES	MR
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	<b>Captive water Storage for fire fighting</b>			
	• Under ground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	YES	MR
	➤ Fire service inlet	Yes	Yes	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000	10,000	MR
15	Exit Signage	YES	YES	MR
16.	<b>Provision of Lifts</b>			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	YES	DG Set	MR
18.	<b>Refuge Area</b>			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	<b>Fire control room</b>			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A

	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name

D. P. Chowdhury

Designation

Div. Officer

Signature of the Inspecting Officer

Name

S. S. K. Koushik

Designation

Asstt. Div. Officer