

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

No *F6/DFS/MS/2012/802*

Dated *06/03/12*

**FIRE SAFETY CERTIFICATE**

Certified that SH. Mukesh Kumar Singhal at 23/1 Loni Road Gokal Pur Village Delhi. which comprises of ground floor was granted NOC by this deptt. vide letter No. F5/(3-A)/DFS/92/140 dated 20-3-1992 for storage of 300Ltrs. Petroleum class -A in barrels in a separate room at Ground floor. The premises was re-inspected by the officer concerned of this deptt. on 14-2-2012 in the presence of Mr. Sharma Supervisor and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy for storage with effect from *6-3-2012* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. printed overleaf.

Issued on *06/03/12* at New Delhi.



CHIEF FIRE OFFICER

DELHI FIRE SERVICE

Copy to :-

1. SH. Mukesh Kumar Singhal  
23/1 Loni Road Gokal Pur Village  
Delhi
2. The Additional Comm. of Police (Lic.)  
First Floor, Police Station,  
Defence Colony, New Delhi.

*Recd  
2/3/12*

1. Nothing in contravention of the Petroleum Rules, 1976 as modified upto 1<sup>st</sup> January, 1981 chapter V Rule 117 read and comments of the chief inspector of Explosive thereof should be permitted.
2. No trade susceptible to cause ignition petroleum vapours by generating heat, mechanical / electrical spark should be allowed within the licenced premises.
3. The workers employed at the site must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
4. Overhead electric cable should not be allowed across the licenced premises.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

- N/116 -

INSPECTION REPORT

1. Name & address of the building : SH. mukul K. Singh, 23/1, vill-Gokulpur, Delhi
2. Type of Occupancy : Storage
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F5(3A)/DFS/2009/207 Dated: 22.6.09.
5. Fire Safety directives letter No : NA
6. Date of inspection : 14.02.2012.
7. Name of the Inspecting Officers : Gurmukh Singh
8. Name and designation of officers from the building side : Mr. Subhash Sharma (Supervisor)
9. Year of Construction : 1992
10. Applicant's letter No. : 64812/ Addl. CP/Lic (Pet)/Expt. dt. 28/12/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b> <ul style="list-style-type: none"><li>• Road width</li><li>• Gate width</li><li>• Width of internal road</li></ul>	<u>Accessible</u> <u>Abwts on road</u> <u>—————</u>	<u>7 meters</u> <u>directly from road</u> <u>2.0 mts</u> <u>—————</u>	<u>MR</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b> <ul style="list-style-type: none"><li>a. Number of staircases<ul style="list-style-type: none"><li>• Upper Floors</li><li>• Basements</li></ul></li><li>b. Width of staircases<ul style="list-style-type: none"><li>• Upper Floors</li><li>• Basements</li></ul></li><li>c. Protection of exits<ul style="list-style-type: none"><li>• Fire check door</li><li>• Pressurization</li></ul></li><li>e. No. of continuous staircases to terrace</li><li>g. Width of Corridor</li><li>h. Door Size</li></ul>	<u>NA</u>	<u>NA</u>	<u>(Go. B. only)</u>

3	<b>Compartmentation.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	/	/	/
4	<b>Smoke Management System.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	NA Natural	/
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	03 Nos. CO <sub>2</sub> ABC & Foam ISI marked	06 Nos. CO <sub>2</sub> Foam & ABC Yes.	MR MR MR
6	<b>First-Aid Hose Reels.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	/	/
7	<b>Automatic fire detection and alarming system.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	/	/	
8	<b>MOEFA</b>	NA	NA	
9	<b>Public Address System.</b>	NA	NA	
10	<b>Automatic Sprinkler System.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	/	/	

	<ul style="list-style-type: none"><li>• Upper Floor</li><li>• Sprinkler above false ceiling</li></ul>	/	/	
11	<b>Internal Hydrants</b>	NA	NA	
	<ul style="list-style-type: none"><li>• Size of riser/down-comer</li><li>• Number of hydrants per floor</li><li>• Hose Box</li></ul>	/	/	
12	<b>Yard Hydrants.</b>	NA	NA	
	<ul style="list-style-type: none"><li>• Total number of hydrants</li><li>• Hose Box</li></ul>	/	/	
13	<b>Pumping Arrangements.</b>	NA	NA	
	<ul style="list-style-type: none"><li>• Ground Level<ul style="list-style-type: none"><li>➤ Discharge of main Pump</li><li>➤ Head of Main pump</li><li>➤ Number of main pumps</li><li>➤ Jockey Pump out put</li><li>➤ Jockey pump head</li><li>➤ Standby Pump out put</li><li>➤ Standby Pump Head</li><li>➤ Auto Starting/ Manual stopping</li><li>➤ Pump House Access</li></ul></li><li>• Terrace level<ul style="list-style-type: none"><li>➤ Discharge of pump</li><li>➤ Head of the pump</li><li>➤ Power Supply</li><li>➤ Auto Starting of pump</li></ul></li></ul>	/	/	
14	<b>Captive Water Storage for fire fighting.</b>	NA	NA	
	<ul style="list-style-type: none"><li>• Underground tank capacity</li><li>➤ Draw-off connection</li></ul>	/	/	

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	/	/	
15	Exit Signage.	NA	NA	
16	Provision of Lifts.	NA	NA	
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	/	/	
17	Standby power supply	NA	NA	
18	Refuge Area.	NA	NA	
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	/	/	
19	Fire Control Room	N.A	N.A	
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	/	/	
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire protection required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

  
Signature of the Inspecting Officer

Name Gurmukh Singh

Designation ADD (LH)

  
Signature of the Inspecting Officer

Name

Designation