

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS:
DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


NO.F6/DFS/MS/2012/FW/708

Dated: 28/02/12

FIRE SAFETY CERTIFICATE

Certified that the **M/s Prabhu Narayan Hans Raj Fireworks** located at **Shop No.18, Khasra No. 9929-9935, K.L.Gupta Shopping Complex, New Rohtak Road, New Delhi** comprised of **ground floor only** have complied with the fire prevention and fire safety requirements in accordance with the guidelines issued by the Additional Commissioner of Police (Lic.) and verified by the officer concerned of Delhi fire service on **20.01.2012** in presence of Mr. Hans Raj Khandelwal, Owner / Occupier and that the shop is fit for running the trade of Sale and possession of 1200 Kg Chinese / sparklers & 300 Kg Fireworks with effect from 28/02/12 for a period of **3(three)** years.

Issued on 28/02/12 at New Delhi by.



**Chief Fire Officer
Delhi fire service**

Copy to: -

1. The Additional Commissioner of Police (Lic.), 1st floor, Police Station, Defence Colony, New Delhi
2. M/s Prabhu Narayan Hans Raj Fireworks, Shop No.18, Khasra No. 9929-9935, K.L.Gupta Shopping Complex, New Rohtak Road, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. The trained fire fighting staffs shall be available round the clock when shop is open.
- c. Any deviation with respect to construction etc. shall be verified by the concerned building sanctioning Authority.
- d. The fire safety arrangements provided in the shop shall be checked every year before Dewali / Dussera Festival.
- e. The certificate may not be treated in any case for regularization of unauthorized construction, if any.

etc
