

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. FG/OAS/ms/2011/3126

Dated: 23/11/2011

FIRE SAFETY CERTIFICATE

Certified that the AANCH Restaurant (Unit of Karishma Events & Hospitality Pvt. Ltd.), Shoppers Stop Ltd, Forth floor Terrace 10 Shivaji Palace, Raja Garden, District Centre, Rajouri Garden, New Delhi-110027, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 16.11.11 in presence of Sh. Brajesh Kapur (Director) of the restaurant and that the premises is fit for Class-D (Assembly) occupancy with effect from 23/11/11.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....23/11/11.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

Copy to:

1. Dy. Health Officer
Municipal Corporation of Delhi,
West Zone, Rajouri Garden, New Delhi-110027
2. Sh. Brajesh Kapur (Director)
AANCH Restaurant (Unit of Karishma Events & Hospitality Pvt. Ltd.)
Shoppers Stop Ltd, Forth floor Terrace 10 Shivaji Palace, Raja Garden,
District Centre, Rajouri Garden, New Delhi-110027.

Note :- For general fire safety, directives please over leaf.

May Kindly peruse letter no. D-1476/H011 dated 31-10-11 received from DHO regarding of NOC in r/o AANCH Restaurant (Unit of Karishma Events & Hospitality Pvt. Ltd.), Shoppers Stop Ltd, Forth floor Terrace, 10 Shivaji Palace, Raja Garden, District Centre, Rajouri Garden, New Delhi-110027. premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : AANCH Restaurant (Unit of Karishma Events & Hospitality Pvt. Ltd.), Shoppers Stop Ltd, Forth floor Terrace 10 Shivaji Palace, Raja Garden, District Centre, Rajouri Garden, New Delhi-110027.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS/2007/1569 dated 12/06/2007 (of the Mall)
5. Fire Safety directives letter No. : F6/DFS/MS/BP/2005/621 dated 21/03/2005 (of the Mall)
6. Date of inspection : 16.11.2011
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
From the building side : Mr. Brajesh Kapur (Director)
9. Year of Construction : 2006 - 2007
10. Applicant's letter No. : D-1476/H011 dated 31-10-11

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 mtrs	24 mtr	M/R
	• Gate width	5 mtr	5 mtr	M/R
	• Width of internal road			
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	11	11	M.R
	• Upper Floors	4	4	M.R

	<ul style="list-style-type: none"> Basement 	11	11	M.R.
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	2 mtr of the restaurant 1.5 mtrs	Provided	M.R.
	<ul style="list-style-type: none"> Basement 	1.5 mtr	Provided	M.R.
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Pressurization 	Required	Provided	M.R.
	d. No. of continuous staircases to terrace	4	4	M.R.
	e. Width of Corridor	No corridors, halls only	No corridors, halls only	M.R.
	f. Door size	2.0mtr of the restaurant	2.0mtr of the restaurant	M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Water Curtain 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided	M.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	M.R.
5.	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers 	90	90	M.R ✓
	<ul style="list-style-type: none"> Types 	ABC & CO ₂ ✓	provided	M.R ✓
	<ul style="list-style-type: none"> IS marking 	ISI marks	provided	M.R ✓
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	4	4	M.R ✓
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	provided	M.R ✓
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R ✓
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat type	✓ Provided	M.R ✓
	<ul style="list-style-type: none"> Location of Main Panel 	Ground floor	✓ Provided	M.R ✓
	<ul style="list-style-type: none"> Location of Repeater Panel 	Ground floor	✓ Provided	M.R ✓
	<ul style="list-style-type: none"> Alternate source of power 	Required	✓ Provided	M.R ✓
	<ul style="list-style-type: none"> Hooter's Location 	Required	✓ Provided	M.R ✓
8.	MOEFA	Required	✓ Provided	M.R ✓
9.	Public Address System.	Required	✓ Provided	M.R ✓
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M.R ✓
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	M.R ✓
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm ✓	provided	M.R ✓

	<ul style="list-style-type: none"> Number of hydrants per floor 	4	Provided	M.R
	<ul style="list-style-type: none"> Hose Box 	4	Provided	M.R
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	4	Provided	M.R
	<ul style="list-style-type: none"> Hose Box 	4	Provided	M.R
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	4500 LPM	4500 LPM	M.R
	➤ Head of Main pump	100 mtr	100 mtr	M.R
	➤ Number of main pumps	Two electrical one diesel	Two electrical One diesel	M.R
	➤ Jockey Pump out put	180 LPM	180 LPM	M.R
	➤ Jockey pump head	100 mtr	70 mtr	M.R
	➤ Standby pump out put	4500 LPM	4500 LPM	M.R
	➤ Standby pump Head	100 mtr	100 mtr	M.R
	➤ Auto Starting/Manual stopping	Required	Required	M.R
	➤ Pump Hose Access	Required	Required	M.R
	Terrace level			
	➤ Discharge of pump	N.R.	N.R	M.R

	➤ Head of the pump	N.R.	N.R	M.R
	➤ Power supply	N.R.	N.R	M.R
	➤ Auto Starting of pump	Required	Provided	M.R
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	One lakh	one lakh	M.R
	➤ Draw -off connection	Required	Provided	M.R
	➤ Fire service inlet	Required	Provided	M.R
	➤ Access to tank	Required	Provided	M.R
	➤ Overhead Tank Capacity	30, 000 ltr	Provided	M.R
15	Exit Signage.	Required	Provided	M.R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	Required	Provided	M.R
	• Pressurization of Lift lobby	Required	Provided	M.R
	• Communication In lift Car	Required	Provided	M.R
	• Fireman's Grounding Switch	Required	Provided	M.R
	• Lift Signage	Required	Provided	M.R
17.	Standby power supply	Required	150 KVA	M.R
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	M.R

	➤ Location	N.R.	N.R.	M.R
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided ✓	M.R
	➤ Flow Switch Panel	Required	Provided ✓	M.R
	➤ PA system Panel	Required	Provided ✓	M.R
	➤ Batter backup	Required	Provided ✓	M.R
	➤ Building Floor plans	Required	Provided ✓	M.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R. dn	N.R. dn	M.R
		Fire protection arrangements provided in the mall will be used for restaurant also dn		

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name D. D. Sunil Chawdhary

Name

Designation

D. V. officer

Designation