

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No. F6/DAS/MS/GH/2011/3149

Dated : 24/11/11

**FIRE SAFETY CERTIFICATE**

Certified that the Akash guest house at Plot No.17, Main Road Village Gazi Pur, Delhi. Comprised of ground plus three upper floors (Ground-shops, First floor-6 Nos. guest rooms, Second floor-6 Nos. guest rooms, Third floor-laying vacant) owned/occupied by M/S Akash guest house have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 31.10.11 in the presence of Sh. Manoj Sharma of the guest house and that the first & second floor with twelve guest rooms is fit for occupancy Group – A (Residential Building) with effect from 24/11/11 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 24/11/11 at New Delhi by




Chief Fire Officer  
For Director  
Delhi Fire Service

1. The Addl. Commissioner of Police (Lic.)  
1<sup>st</sup> Floor, Police Station, Defence Colony,  
New Delhi.

2. Sh. Manoj Sharma  
M/S Akash guest house  
Plot No.17, 1<sup>st</sup> Floor, Main Road Village Gazi Pur,  
Delhi.

:- In reference no. 43996-98/Addl. C.P./Lic. (H) 9c  
dated 10.09.11





3	<b>Compartmentation.</b>	NA	NA
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	/	/
4	<b>Smoke Management System.</b>	NA	NA
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Notional ventilator
5	<b>Fire Extinguishers</b>		
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	04 Nos. CO <sub>2</sub> & WCO <sub>2</sub> ISI marked	06 Nos. ✓ 100R CO <sub>2</sub> & WCO <sub>2</sub> ISI marked
6	<b>First-Aid Hose Reels.</b>	NA	But provided.
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	01 No. 30 mtrs 5 mm
7	<b>Automatic fire detection and alarming system.</b>	NR	Not provided.
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	/	/
8	<b>MOEFA</b>	NR	But provided.
9	<b>Public Address System.</b>	NR	- do -
10	<b>Automatic Sprinkler System.</b>	NR	Not provided
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	NA	NA

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	/
		NA	NA	
11	<b>Internal Hydrants</b>	NR.	But provided.	
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>		4" dia.	/
			01 No.	
			01 No.	
12	<b>Yard Hydrants.</b>	NR.	Not provided.	
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	/	/	/
13	<b>Pumping Arrangements.</b>	NR.	But provided.	
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	/		/
			220 LPM	-
			30 mts.	-
			Provided.	-
			Auto start	-
14	<b>Captive Water Storage for fire fighting.</b>	NR.		
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>	/	/	

- N/S -

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA		
		NA		
		NA	5,000 kgs.	
15	<b>Exit Signage.</b>	Regd.	Periodical.	MR
16	<b>Provision of Lifts.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	/	/	
17	<b>Standby power supply</b>	NA	NA	
18	<b>Refuge Area.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	/	/	
19	<b>Fire Control Room</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PAi System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	/	/	
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	

The fire protection systems provided in the building were test checked and found functional at the of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

21/6-

Signature of the Inspecting Officer

Name

Designation

Ashtant  
4/11/11

Signature of the Inspecting Officer

Name

Designation

Guramkh Singh

ADD (L.N)

DO(E)

Submitted for approval please.

1/11/11