

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F-6/DFS/MS/2012/Indl./G17

Dated: 24/02/2012

FIRE SAFETY CERTIFICATE

Certified that the **Aman Rex Pvt. Ltd.** locate at Plot no. G-8, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041., comprised of basement, ground floor magazine and first floor was granted NOC by this department vide letter F-6/DFS/MS/BP/97/739 dated 01.07.1997. The premises was re-inspected by the officers concerned of this department on **09/02/2012** in the presence of Mr. Subhash Arora (Director) of the factory and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class-G (G-1) Industrial** occupancy with effect from24/02/12 for a period of three years subject to conditions printed over leaf.

Issued on.....24/02/2012.....at New Delhi by



Chief Fire Officer
Delhi Fire Service


Copy to:

Mr. Subhash Arora (Director)

M/s Aman Rex Pvt. Ltd.

Plot no. G-8, Udyog Nagar, Industrial Area,
Rohtak Road, New Delhi-110041

Note :- For general fire safety directives please over leaf.



May Kindly peruse letter no. nil dated 09-09-2011 received from Mr. Subhash Arora (Director) for Aman Rex (P) Ltd. regarding of NOC in r/o Aman Rex Pvt. Ltd. Plot no. G-8, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041. premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa :-

1. Name & address of the building : Aman Rex Pvt. Ltd. Plot no. G-8, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041.
2. Type of Occupancy : Class-G (G1) Industrial
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/BP/97/739 dated 01.07.1997
5. Fire Safety directives letter No. : F6/DFS/MS/BP/88/1720 dated 30-11-1988
6. Date of inspection : 09-02-2012
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
8. Name and designation of officers
From the building side : Mr. Subhash Arora (Director)
9. Year of Construction : 1988-1981
10. Applicant's letter No. : nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	12mtr.	M.R.
	• Gate width	4.5 mtr	6 mtr	M.R.
	• Width of internal road	3 mtr & 4 mtr	Provided	M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	3	3	M.R.
	• Upper Floors	3	3	M.R.
	• Basement	3	3	M.R.

	b. Width of staircases			
	• Upper Floors	1.20 mtr each	Provided	M.R. ✓
	• Basement	1.20 mtr each	Provided	M.R. ✓
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R. ✓
	• Pressurization	N.R.	N.R.	Not applicable
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1.5 mtr	Halls only	M.R. ✓
f. Door size	1.5 mtrs	N.R.	M.R. ✓	
3.	Compartmentation.			
	• Fire check door	Required	Provided	M.R. ✓
	• Sealing of electrical shafts	Required	Provided	M.R. ✓
	• Fire Rating of shaft door	N.A.	N.R.	Not applicable
	• Water Curtain	N.R.	N.R.	Not applicable
	• Fire Dampers	N.A.	N.R.	Not applicable
4.	Smoke Management System.			
	• Basements	Required	Exhaust fan provided	M.R. ✓
	• Upper floors	N.R.	N.R.	Not applicable
5.	Fire Extinguishers			
	• Total numbers	10	15	M.R. ✓
	• Types	ABC & CO ₂ type	provided	M.R. ✓

	• ISI marking	ISI marked required	provided	M.R. ✓
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	2	2	M.R. ✓
	• Length of hose reel hose	30 m required	provided	M.R. ✓
	• Nozzle diameter	5 mm required	provided	M.R. ✓
7.	Automatic fire detection and alarming system.			
	• Type of detectors	N.R	N.R	Not applicable
	• Location of Main Panel	N.R	N.R	Not applicable
	• Location of Repeater Panel	N.R	N.R	Not applicable
	• Alternate source of power	N.R	N.R	Not applicable
	• Hooter's Location	N.R	N.R	Not applicable
8.	MOEFA	N.R	Provided	M.R..
9.	Public Address System.	N.R.	N.R.	Not applicable
10.	Automatic Sprinkler system			
	• Basement	Required	Provided	M.R. ✓
	• Upper Floor	N.R	N.R.	Not applicable
	• Sprinkler above false ceiling	N.A.	N.A..	Not applicable
11.	Internal Hydrants			
	• Size of riser/down-comer	100 m	Provided	M.R. ✓
	• Number of hydrants per floor	2	Provided	M.R. ✓

	• Hose Box	2	Provided	M.R. ✓
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	Not applicable.
	• Hose Box	N.R.	N.R.	Not applicable
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	1620 LPM	Provided	M.R. ✓
	➤ Head of Main pump	60 mtr	Provided	M.R. ✓
	➤ Number of main pumps	2	Provided	M.R. ✓
	➤ Jockey Pump out put	180 LPM	Provided	M.R. ✓
	➤ Jockey pump head	60 mtr	Provided	M.R. ✓
	➤ Standby pump out put	1620 LPM	Provided	M.R. ✓
	➤ Standby pump Head	1620 LPM	Provided	M.R. ✓
	➤ Auto Starting/Manual stopping	Required	Provided	M.R. ✓
	➤ Pump Hose Access	Required	Provided	M.R.
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R. ✓
	➤ Head of the pump	50 mtr	provided	M.R. ✓
	➤ Power supply	Required	100 KVA	M.R.
	➤ Auto Starting of pump	Manual	Provided	M.R.

14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	50,000	Provided	M.R. ✓
	➤ Draw -off connection	required	provided	M.R.
	➤ Fire service inlet	required	provided	M.R.
	➤ Access to tank	required	provided	M.R.
	➤ Overhead Tank Capacity	5000 ltr	10,000	M.R. ✓
15	Exit Signage.	N.R.	N.R.	Not applicable
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A.	N.R.	Not applicable
	• Pressurization of Lift lobby	N.A.	N.R.	Not applicable
	• Communication In lift Car	N.A.	N.R.	Not applicable
	• Fireman's Grounding Switch	N.A.	N.R.	Not applicable
	• Lift Signage	N.A.	N.R.	Not applicable
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area	N.R.	N.R.	Not applicable
	➤ Total Area	N.R.	N.R.	Not applicable
	➤ Location	N.R.	N.R.	Not applicable
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	Not applicable
	➤ Flow Switch Panel	N.R.	N.R.	Not applicable

	➤ PA system Panel	N.R.	N.R.	Not applicable.
	➤ Batter backup	N.R.	N.R.	Not applicable.
	➤ Building Floor plans	N.R.	N.R.	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name SUNIL CHAUDHARY

Name

Designation D.O.

Designation