

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2011 / EH / 3271

Dated 01/12/2011

FIRE SAFETY CERTIFICATE

Certified that the Club Czar Restaurant located at Shop No G-09 & G-22-24 (Ground floor), Rasvilas Plot No D-1 Distt Centre Saket, New Delhi, was inspected by the officers concerned of this department on 11.11.2011 in the presence of Mr. Rajeev Goyal and found that the said Restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" with effect from 01/12/2011 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 01/12/2011 at New Delhi by.


Chief Fire Officer
For Director
Delhi Fire Service
7/4

To

1. M/s Club Czar,
Shop No G-09 & G-22-24 GF, Rasvilas
Plot No D-1 Distt Centre Saket, New Delhi.
2. The Dy. Health Officer, Health Department,
South Zone, MCD, New Delhi.

This is located in the ground floor of the mall which has already got NOC.

INSPECITON REPORT

1. Name & address of the building: Club Czar, (ground floor) Shop No. G-09 & G-22-24 Rasvilas, plot no D-1, Distt Centre Saket
2. Type of Occupancy : Assembly
3. Type of Case : New Case / (but it is situated in the mall which has already got NOC)
4. Details of previous NOC : Letter No. _____ N/A _____ Dated _____
5. Fire Safety directives Letter No. : However building get NOC
6. Date of inspection : 11.11.2011
7. Name of the Inspecting Officer : ADO S.S. Kaushik *Do D.P. Bhandari*
8. Name and designation of Officer
from the building side : Mr. Rajeev Goyal
9. Year of Construction : N/A
10. Applicant's letter No. : MCD Letter No D/2580/DHO/S2 Dated 19.10.2011

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A	N/A	As it is situated at GF
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	N/A	N/A	situated at GF
	• Upper floors	N/A	N/A	situated at GF
	• Basements	N/A	N/A	situated at GF
	a. Width of staircases	N/A	N/A	situated at GF
	• Upper floors	N/A	N/A	situated at GF
	• Basements	N/A	N/A	situated at GF
	b. Protection of exits			

Club Gzan G. 09 x G-22-24 Rasvlas
Plot No D-1 District Centre Saket N.D

	<ul style="list-style-type: none"> • Fire check door 	YES	YES	MR
	<ul style="list-style-type: none"> • Pressurization 	N/A	N/A	N/A
	c. No of continuous staircase to terrace	N/A	N/A	N/A
	d. Width Of Corridor	N/A	N/A	N/A
	e. Door Size	2.00/1.50 mtr	YES	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	YES	YES	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	YES	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	02 each type	YES	MR
	<ul style="list-style-type: none"> • Types 	WT, CO ₂ , DCP	YES	MR
	<ul style="list-style-type: none"> • IS marking 	YES	YES	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	02	YES	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	YES	YES
	<ul style="list-style-type: none"> • Nozzle diameter 	5 m m	YES	YES
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	YES	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	YES	YES	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	YES	YES	MR
	<ul style="list-style-type: none"> • Hooters' Location 	YES	At entrance	MR
8.	MOEFA	YES	YES	MR
9.	Public Address System	N/A	N/A	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor 	N/A	YES	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	YES	YES	MR (already available in the bldg.)
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	YES	MR
	<ul style="list-style-type: none"> • Hose Box 	1	YES	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	N/A	N/A	N/A

Club Czar Restaurant - opp shops G-1-a G 22-24 Ranvitas
 shoppy mall Pld no D-1 District Centre Saket-

	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Discharge of main pump	CONNECTED TO MAIN FIRE PUMP HOUSE OF MALL		MR
	➤ Head of main pump			MR
	➤ Number of main pumps			MR
	➤ Jockey pump out put			MR
	➤ Jockey pump head			MR
	➤ Standby Pump out put			MR
	➤ Standby Pump Head			MR
	➤ Auto Staring/Manual stopping			MR
	➤ Pump House Access			MR
	• Terrace level			MR
	➤ Discharge of pump			MR
	➤ Head of the pump			MR
	➤ Power supply			MR
	➤ Auto starting of pump			MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	YES	Common water Tank is available	MR
	➤ Draw of connection	YES	YES	MR
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	YES	YES	YES
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	YES	YES	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Club Ozon Restaurant Shop no. Cr 9. & 9-22-294 Rasvillas
Shoppers mall. D I District Center Sahel. ND

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings~~ as ~~noted~~ at ~~serial~~ numbers

..... According to A is put up A.

Signature of the Inspecting Officer

Name

D. P. Bhardwaj

Designation

Dir. Officer

Signature of the Inspecting Officer

Name

S. S. Kaushik

Designation

Asst Div. Officer