

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.


No. F6/DFS/MS/GH/2012/135

Dated: 13/01/12

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Blue Sapphire**, located at 3351-54, Christen Colony, Bank Street, Karol Bagh, New Delhi-110005 comprised of Basement, Ground Floor plus four upper floors, using basement as Hall; Ground Floor as reception, office, hall, shops & staff pantry, first floor having nine guest rooms and one store room, second floor having five guest rooms and one store room, third floor having nine guest rooms and one store room (Total twenty three guest rooms) and one staff room on terrace floor. Above guest house was issued NOC vide this office letter No.F.6/DFS/MS/GH/2008/3402 dated 12/12/2008 owned/occupied by Sh. Suman Anand have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 02.01.2012 in the presence of Sh. Manjeet Singh and Sh. Naresh Kumar. The building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....13/01/12..... at New Delhi.



CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Addl. Commissioner of Police (Lic.)
1st floor, P.S., Defence Colony, New Delhi.
(Re. No.45843/Addl. C.P./Lic.(H), Dated 27.09.2011)
2. Mr. Suman Anand (Owner)
Hotel Blue Sapphire,
3351-54, Christen Colony, Bank Street,
Karol Bagh, New Delhi - 110005.

etc



INSPECTION REPORT

1. Name & address of the building : Hotel Blue Sapphire, 3351-54, Christen Colony, Bank Street, K. Bagh, N.D.O.S
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/GH/08/3402 Date 12.12.08
5. Fire Safety directives letter No : N/A
6. Date of inspection : 02.01.2012
7. Name of Inspecting Officer : D.O H.L. Aneja & A.D.O P.S. Dahiya.
8. Name and designation of officers
From the building side : Sh. Manjeet Kumar, Naresh Kumar
9. Year of Construction : Before 2002
10. Applicant's letter No. : 45843/ Addl. C.P./LIC (H) dated 27/09/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>-</p> <p>-</p>	<p>12mtr</p> <p>120 cms</p> <p>-</p>	<p>MR</p> <p>MR</p> <p>-</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	One	One	MR
	• Upper Floors	- do -	- do -	MR
	• Basements	- do -	- do -	MR
	b. Width of staircases			
	• Upper Floor	-	107cms to 119cms	MR, Being Old Case
	• Basements	-	114cms	- do -
	c. Protection of exits			
	• Fire check door	N/A	-	-
	• pressurization	N/A	-	-
	d. No. of continuous staircases to terrace	-	One	MR
	e. Width of Corridor	-	200cms	MR
	f. Door Size	-	87cms x 204cms	MR
3.	Compartmentation			
	• Fire check door	N/A	-	-
	• Sealing of electrical shafts	N/A	Sealed	MR
	• Fire Rating of shaft door	N/A	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust Fans are Provided	MR
	• Upper floors		Natural Ventilation	MR

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	Two at each floor Co ₂ , Water Co ₂ ISI marked	Provided -do- ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	Provided -do- -do-	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A - - - -	- - - D.G. Set of 45 kVA In Staircase	- - - MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required N/A N/A	Provided - -	MR - -
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	- - -	- - -
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	- -	- -
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	N/A N/A N/A N/A N/A N/A N/A N/A	- - - - - - - -	- - - - - - - -

G.H Blue Sapphire, 3351-54, Christen Colony,
Bank Street, Karol Bagh, N.D - 05.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	-	-
		450 LPM	450 LPM	MR
		30 M	30 M	MR
		-	Provided	MR
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	-	-
		N/A	-	-
		N/A	Provided	MR
		N/A	- do -	MR
		5000ltr	5000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	-	-
		N/A	-	-
		Required	Provided	MR
		- do -	- do -	MR
		- do -	- do -	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		-	Provided	MR
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{Renewal}~~grant~~ Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~


Signature of Inspecting Officer

Name *M. L. Anjeja*
Designation *Divisional Officer*


Signature of Inspecting Officer

Name *P. S. Dahiya*
Designation *AS&H. Divisional Officer*