

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI**


No. F6/MS/DFS/GH/2012/ 889

Dated: 12/03/12

FIRE SAFETY CERTIFICATE

Certified that the Sadar Guest House, located at 6-E, Sadar Thana Road, New Delhi comprised of ground floor (Shops), Mezzanine floor (Reception), 1st floor (08 guest rooms + 03 Temporary Stores), 2nd floor (08 guest rooms) and 3rd floor (08 guest rooms) total 24 guest rooms was granted NOC by this department vide letter No. F6/DFS/MS/GH/2010/1165 dated 22-04-2010. The premises was re-inspected by the officer concerned of this department on 05-03-2012 in the presence of Sh. Dharam pal owner of the Guest House and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 24 guest rooms with effect from 12.03.2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 12.03.12 at New Delhi by.


CHIEF FIRE OFFICER
FOR DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi – 110049
2. Shri Dharam Pal M/s Sadar Guest House, 6-E Sadar Thana Road, Opp. Police Station, Delhi.
3. The Commissioner MCD with a request to get height of the building measured and sent intimation to this department.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Sadar Guest House, 6E,
Sadar Thana Road, New Delhi.
2. Type of Occupancy : Group A-I Residential.
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. FB/DFE/mc/GH/2010/165 Dated: 22-04-2010
5. Fire Safety directives letter No : - N.A -
6. Date of inspection : 05-09-2012
7. Name of the Inspecting Officers : Dharm vir singh yadav
8. Name and designation of officers from the building side : Sh. Daram Pal (owner)
9. Year of Construction : Pre to 1986
10. Applicant's letter No. : NIL dated 21-02-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	^{checklist of} NBC Guest House Requirement	Provided at site	Remarks <i>old case</i>
1	Access to building			<i>P.S. Area</i>
	• Road width	<i>Accessible</i>	<i>more than 6mtr</i>	<i>M.R.</i>
	• Gate width	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	• Width of internal road	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<i>-</i>	<i>one</i>	<i>M.R.</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	b. Width of staircases			
	• Upper Floors	<i>-</i>	<i>one</i>	<i>M.R.</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	c. Protection of exits			
	• Fire check door	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	• Pressurization	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	h. Door Size	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>

Contd. :-

Sadar Court House G.E,
Sadar Thana Road
New Delhi

old case
P.S. Area.

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.A		
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N.A natural ventilation M.R	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	— — ISI marked	Eight CO ₂ type wet CO ₂ type yes. M.R M.R. M.R.	
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one yes yes	M.R. M.R. M.R.
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N.A		
8	MOERA	N.A	N.A	N.A
9	Public Address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N.A		

contd. ✓

old case
PSS Area

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	✓ N.A	—	—
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	✓ N.A	—	—
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	✓ N.A	—	—
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	✓ N.A	—	—
		—180 LPM	180 LPM	N.R.
		30 M.	30 M.	N.R.
		Yes.	Electrical	M.R.
		— N.A —	N.A —	— N.A —
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	✓ N.A	—	—

contd:-

old case
P.S. Area.

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N.A	—	—
15	Exit Signage.	yes.	Provided	M.R.
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N.A	—	
17	Standby power supply	—	D.G. Set 32 KVA	M.A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N.A	—	—
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N.A	—	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	—	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

contd: -

Signature of the Inspecting Officer

Name


Designation

D.O. (contd.)

6/03/12

Signature of the Inspecting Officer

Name DHARM VIR SINGH YADAV

Designation Assistant Divisional
Officer (contd.)


03-03-12