

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No. F6/DFS/MS/2012/ *School/442*

Dated: *09/02/12*

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C. Primary Girls School- I (Urdu), Abul Fazal Enclave, Jamia Nagar, New Delhi-110025** comprised of ground floor only **Owned/Occupied** by M.C. Primary Girls School- I (Urdu), has complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officers concerned of Delhi Fire Service on 18 /01/2012 in the presence of Mrs. Nayyar, Principal of the school and that the building/premises is fit for occupancy class-B (Educational) with effect from *09/02/12* for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on *09/02/12* at New Delhi by

  
Chief Fire Officer  
For Director  
Delhi Fire Service

**Copy To: -**

1. The Director of Education, *MCD Civic Center*, Delhi.
2. Principal, M.C. Primary Girls School-I (Urdu),  
Abul Fazal Enclave, Jamia Nagar, New Delhi-110025

**Conditions for the validity of fire safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

INSPECTION REPORT

1. Name and address of the building: M.C. Primary Girls School-I (Urdu)  
Abulfazal Enclave Jamia Nagar N.O. 110025
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : NIL
5. Fire Safety directives letter No : NIL Dated: \_\_\_\_\_
6. Date of Inspection : 18/01/2012
7. Name of the Inspecting Officers : Rajan Wadehra Aso/m.Rood.
8. Name and designation of Officers  
From the building side : Mrs. Nayyza (Principal)
9. Year of Construction : Ground Floor (Asbestos Roof)
10. Applicant's letter No : NIL

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	15 Mts	15 Mts	M/R
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits		NA	
	• Number of staircase			
	➤ Upper Floors			
	➤ Basements			
	• Width of Staircases		NA	
	➤ Upper Floors			
	➤ Basements			
	• Protection of exits		NA	
	➤ Fire check door			
	➤ Pressurization			
	• No. of continuous staircases to terrace		NA	
	• Width of Corridor			
	• Door Size			



3	Compartmentation			NA
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>			
4	Smoke Management System			NA
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floors</li> </ul>	30 a/c Per hour 12 a/c Per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total Number</li> <li>• Types</li> <li>• IS marking</li> </ul>	1 Ext Per 300 Sqmts ISI mark	4 Nos 2 Nos ABC 2 Nos Cap Yes	MIR MIR MIR
6	Firs-Aid Hose Reels			NA
	<ul style="list-style-type: none"> <li>• Total Number on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	_____ 30 m 5mm		
7	Automatic Fire detection and alarming system			NA
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's Location</li> </ul>			
8	MOEFA			NA
9	Public Address System			NA
10	Automatic Sprinkler System			NA
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
11	Internal Hydrants			NA
	<ul style="list-style-type: none"> <li>• Size of riser/down comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	Yard Hydrants			NA
	<ul style="list-style-type: none"> <li>• Total Number of hydrants</li> <li>• Hose Box</li> </ul>			



20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA
----	---	----	----	----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial number.....~~

Do(S)

*[Handwritten signature]*  
25/11/12

*[Handwritten signature]*

Signature of Inspecting Officer

Name Rajan Wadehra

Designation: Asst Div officer