


NO. Ag/DFS/MS/2012/GH/864

Dated: 09/03/2012

FIRE SAFETY CERTIFICATE

Certified that the National Lodge, Guest House located at 24-A/7880, Arakashan Road, Paharganj, New Delhi is comprised of Ground + Four Upper Floors. Ground floor has Reception + 02 Guest Rooms. First floor to Third floor has 04 guest rooms at each floor. Fourth floor has 03 Guest Rooms and staff kitchen. Terrace has DG set was granted NOC by this department vide letter No F-6/DFS/MS/GH/2009/1359 dated 18/05/2009. The premises was inspected by the officers concerned of this department on 21/02/2012 in the presence of Sh Vinod Kumar, Manager and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for occupancy with effect from 09 / 03 /2012 for a period of three years subject to conditions printed below.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in


7/3
Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defense Colony, New Delhi w.r.t letter No 7890/Addl. C.P. /Lic. (H) Dated 08/02/2012.
2. Smt Manjeet Kaur, National Lodge Guest House, 24-A/7880, Arakashan Road, Paharganj, New Delhi

INSPECTION REPORT

1. Name & address of the building : National Lodge, 24-A/7880, Arakshan Road, Paharganj, New Delhi
2. Type of Occupancy : Guest House
3. Type of Case : ~~New Case~~ / Renewal
4. Details of previous NOC : Letter No. FG/DFE/MS/GH/2009/1359 Dated: 18/5/2009
5. Fire Safety directives letter No : —
6. Date of inspection : 21/02/2012
7. Name of the Inspecting Officers : ADO D.S. Yadav & J.O. Atul Garg
8. Name and designation of officers from the building side : Sh Vinod kumar, Manager
9. Year of Construction : 1999
10. Applicant's letter No. : 7890/Addl. CP./Lic (H) dtd 8/2/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m	Provided	m/R
	• Gate width	—	—	—
	• Width of internal road	6 m	Provided	m/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	one of 25 mtr	Provided	m/R
	• Upper Floors	—	—	—
	• Basements	—	—	—

	b. Width of staircases	1.25Mtr	1.22 to 1.25Mtr	N/A
	• Upper Floors	- " -	- " -	N/A
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	N/A	NP	N/A
	• Pressurization	- " -	- " -	- " -
	e. No. of continuous staircases to terrace	one	provided	N/A
	g. Width of Corridor	-	-	-
	h. Door Size	1 mtr	provided	N/A
3	Compartmentation.	N/A	N/A	N/A
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-

4	Smoke Management System.			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers		10 Nos	M/R
	• Types	ISI marked	S ABC S CO ₂	M/R
	• IS marking		yes	yes
6	First-Aid Hose Reels.			
	• Total numbers on each floor	—	Provided on each floor	M/R
	• Length of hose reel hose	30 m	yes	yes
	• Nozzle diameter	5 mm	yes	yes
7	Automatic fire detection and alarming system.			
	• Type of detectors	NR	NP	N/A
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	Reqd	30 kVA DG set provided	M/R
	• Hooters' Location	—	—	—
8	MOEFA	Reqd	Provided	M/R
9	Public Address System.			
		—	—	—

10	Automatic Sprinkler System.	N/R	N/P	N/A
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants	N/R	N/P	N/A
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—
12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—

	➤ Auto Starting/ Manual stopping	-	-	-
	➤ Pump House Access	-	-	-
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	m/R
	➤ Head of the pump	40 m	40 m	m/R
	➤ Power Supply	-	-	-
	➤ Auto Starting of pump	-	-	-
14	Captive Water Storage for fire fighting.	N/A	N/A	N/A
	• Underground tank capacity	-	-	-
	➤ Draw-off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	• Overhead Tank capacity	2500 ltr	Provided	m/R

15	Exit Signage.	Reqd	Provided	m/r
16	Provision of Lifts.	N/R	Provided	m/r
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	Provided	N/R
	• Lift Signage	-	- " -	- " -
17	Standby power supply	Reqd	30kVA DG set	m/r
18	Refuge Area.	N/R	N/P	N/A
	➤ Total Area	- N.A -	-	-
	➤ Location	-	-	-
19	Fire Control Room	-	-	-
	• Detector System Panel	- N.A -	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



Signature of the Inspecting Officer

Name

ATULGARG

Designation

DD/CC



Signature of the Inspecting Officer

Name

D.S. Yadav

Designation

Assistant Divisional
Officer