

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/EH/2012/852

Dated: 07/03/12

FIRE SAFETY CERTIFICATE

Certified that the M/s Costa Coffee Restaurant (unit of Devyani Int. Ltd.) situated at 67 Patel Road, first floor, Moment Mall, Kirti Nagar Metro Station, New Delhi., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 21.02.12 in presence of Mr. Parkash (Manager) of the Restaurant and that the premises is fit for Class-D (Assembly) occupancy with effect from .....07./03./12.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....07./03./12.....at New Delhi by

  
Chief Fire Officer  
For Director  
Delhi Fire Service

Copy to:

1. DHO West Zone,  
M.C.D. of Delhi, West Zone,  
Rajouri Garden, New Delhi,
2. M/s Costa Coffee Restaurant (unit of Devyani Int. Ltd.)  
67 Patel Road, first floor, Moment Mall,  
Kirti Nagar Metro Station, New Delhi

Note :- For general fire safety directives please over leaf.

May kindly peruse letter no.D-1612/HD/WZ/2011 dated 18-11-2011 received from DHO West Zone regarding issue of NOC in r/o M/s Costa Coffee Restaurant (unit of Devyani Int. Ltd.) situated at 67 Patel Road, **first floor**, Moment Mall, Kirti Nagar Metro Station, New Delhi. The premise was inspected by the undersigned from fire safety point of view & the status is put up below on prescribed Performa.

1. Name & address of the building : M/s Costa Coffee Restaurant (unit of Devyani Int. Ltd.) situated at 67 Patel Road, first floor, Moment Mall, Kirti Nagar Metro Station, New Delhi.
2. Type of Occupancy : Class -D (Assembly)
3. Type of Case : New
4. Details of previous NOC : L. No. F6/DFS/MS/2011/993 dated 25.06.2011 & L. No. F6/DFS/MS/2011/2511 dated 13.10.2011
5. Fire Safety directives letter No. : NOC issued to Mall as per S. No. 4
6. Date of inspection : 21-02.2012
7. Name of the Inspecting Officers : Assistant Divisional Officer S.S. Tuli
8. Name and designation of officers  
From the building side : Mr. Parkash (Manager)
9. Year of Construction : -
10. Applicant's letter No. : D-1612/HD/WZ/2011 dated 18-11-2011

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Required	Available	M.R
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	Required	Available	M.R
	• Upper Floors	-	-	-

	<ul style="list-style-type: none"> <li>Basement</li> </ul>	-	-	-
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	As per Mall	Provided	M.R
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	-	-	-
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	-	-	-
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	-	-	-
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required 2 mtr ✓	Available in front of restaurant	M.R
	f. Door size	Required	40 feet front opening of the restaurant	M.R of the Restaurant
3.	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N/A	N/A	N/A
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	N/A	N/A	N/A
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	03 ✓	Provided in the restaurant	M.R of the restaurant

	<ul style="list-style-type: none"> <li>Types</li> <li>IS marking</li> </ul>	ABC & CO <sup>2</sup>  required	2 ABC & 1 CO <sup>2</sup> provided in the restaurant	M.R of restaurant
			Provided in the restaurant	M.R of restaurant
<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>		Available in the Mall covering restaurant	M.R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	-	-
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	-	-
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Required	Smoke & Heat detectors provided in the restaurant	Extended from the Mall to the restaurant /M.R
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	-	-	-
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	-	-	-
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	-	-	-
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	-	-	-
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M.R
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	M.R
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided in the restaurant	Extended from the Mall to the restaurant /M.R
<b>11.</b>	<b>Internal Hydrants</b>			

	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	Required	Provided	Available in Mall/M.R.
		-	-	-
		-	-	-
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	Required	Available in the Mall covering restaurant	M.R.
		-	-	-
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	2280 LPM	Provided with the Mall	M.R
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby pump out put	-	-	-
	➤ Standby pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
	➤ Pump Hose Access	-	-	-
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided in the Mall	M.R
	➤ Head of the pump	-	-	-

	➤ Power supply	-	-	-
	➤ Auto Starting of pump	-	-	-
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	Required 2 lakh	Available with the Mall	M.R
	➤ Draw -off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	➤ Overhead Tank Capacity	Required 30,000 ltrs	Available with the Mall	M.R
<b>15</b>	<b>Exit Signage.</b>	Required	Provided in the restaurant	M.R
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
<b>17.</b>	<b>Standby power supply</b>	Required	Provided with the Mall covering restaurant	M.R
<b>18.</b>	<b>Refuge Area</b>			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.

19.	<b>Fire Control Room</b>			
	➤ Detector System Panel	Required	Provided with the Mall	M.R
	➤ Flow Switch Panel	N.A.	N.A.	N.A.
	➤ PA system Panel	N.A.	N.A.	N.A.
	➤ Batter backup	N.A.	N.A.	N.A.
	➤ Building Floor plans	N.A.	N.A.	N.A.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Name

Designation

(D. S. Tuli)

Signature of the Inspection Officer

Name

Designation

(D. S. Tuli)  
SS Tuli  
ADO(mw)