

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DGS/MS/EH/2012/738

Dated: 02/03/2012

FIRE SAFETY CERTIFICATE

Certified that the **M/s Lee Pacific Restaurant** at 31/35 First floor & Second floor, Rohtak Road West Punjabi Bagh New Delhi., Building is comprised basement + Stilt + G.+1st +2nd floor, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **22.02.12** in presence of **Mr. Shankar Bansal (Manager)** of the restaurant and that the premises is fit for Class-D (Assembly) occupancy with effect from 02/03/12.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....02/03/12.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

ok

Copy to:
M/s Lee Pacific Restaurant
31/35 First floor & Second floor
Rohtak Road, West Punjabi Bagh New Delhi

Note :- For general fire safety directives please over leaf.

May Kindly peruse letter no. D-1533/DH/WZ dated 04-11-2011 received from DHO regarding of NOC in r/o M/s Lee Pacific Restaurant at 31/35 F.F. & S.F Rohtak Road West Punjabi Bagh New Delhi. Premises was inspected by the undersigned & observed that building is constructed on a plot area measuring 464.503 sq. mtr, comprising B + stilt + UG + Ist + IInd floor. Height of the bldg. is more than 10 mtr, but not exceeding 15 metres. Fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : M/s Lee Pacific Restaurant at 31/35 F.F. & S.F
Rohtak Road West Punjabi Bagh New Delhi.
2. Type of Occupancy : (Assembly)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 22-02-2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
From the building side : Mr. Shankar Bansal
9. Year of Construction :
10. Applicant's letter No. : D-1553/HD/WZ

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 mtrs	9 mtrs	MR ✓
	• Gate width	4.5 mtr	6 mtr	MR ✓
	• Width of internal road	N.R.	N.R.	MR ✓
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	P	M.R ✓
	• Upper Floors	2	P	M.R ✓
	• Basement	2	2	M.R ✓

	b. Width of staircases			
	• Upper Floors	1.5 mtrs	Provided	M.R.
	• Basement	1.5 mtr	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.R.	N.R.	M.R.
	d. No. of continuous staircases to terrace	2	2	M.R.
	e. Width of Corridor	Halls only	Halls only	M.R.
f. Door size	2 mtrs & 1.5 mtr	Provided	M.R.	
3.	Compartmentation.			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	N.A.	N.A.	Not applicable
	• Fire Rating of shaft door	N.R.	N.R.	Not applicable
	• Water Curtain	N.R.	N.R.	Not applicable
	• Fire Dampers	N.R.	N.R.	Not applicable
4.	Smoke Management System.			
	• Basements	Required	Exhaust Fan Provided	M.R.
	• Upper floors	N.R.	N.R.	NR
5.	Fire Extinguishers			
	• Total numbers	20	22	M.R.
	• Types	Co2 ABC type	Provided	M.R.
	• IS marking	ISI marks R	Provided	MR

6.	First-Aid Hose Rees.			
	• Total numbers on each floor	one	One	M.R
	• Length of hose reel hose	30 m Required	Provided	MR
	• Nozzle diameter	5 mm Required	Provided	M.R
7.	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & heat	Provided	MR
	• Location of Main Panel	G floor	Provided	MR
	• Location of Repeater Panel	Each floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	M.R
9.	Public Address System.	N.R.	N.R	M.R
10.	Automatic Sprinkler system			
	• Basement	Required	Provided	MR
	• Upper Floor	N. R.	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm 1	Provided	MR
	• Number of hydrants per floor	1	Provided	M.R
	• Hose Box	1	Provided	MR

12	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R	NR
	• Hose Box	N.R.	N.R.	NR
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2280 LPM	Provided	M.R
	➤ Head of Main pump	80 mtr	Provided	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	80 mtr	Provided	MR
	➤ Standby pump out put	2280 LPM	Provided	MR
	➤ Standby pump Head	80 mtr	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump Hose Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	900 LPM.	Provided	M.R
	➤ Head of the pump	50 mtrs.	Provided	M.R
	➤ Power supply	Required	Provided	M.R
	➤ Auto Starting of pump	Required	Provided	M.R

14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	50,000 ltrs	50,000	M.R ✓
	➤ Draw -off connection	Required	Provided	MR ✓
	➤ Fire service inlet	Required	Provided	MR ✓
	➤ Access to tank	Required	Provided	MR ✓
	➤ Overhead Tank Capacity	10, 000 ltrs	Provided	M.R ✓
15	Exit Signage.	Required	Provided	MR ✓
16.	Provision of Lifts	N.A.	N.A.	Not applicable ✓
	• Pressurization of Lift Shaft	N.A.	N.A.	Not applicable ✓
	• Pressurization of Lift lobby	N.A.	N.A.	Not applicable ✓
	• Communication In lift Car	N.A.	N.A.	Not applicable ✓
	• Fireman's Grounding Switch	N.A.	N.A.	Not applicable ✓
	• Lift Signage	N.A.	N.A.	Not applicable ✓
17.	Standby power supply	Required	Provided	MR ✓
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	Not applicable ✓
	➤ Location	N.R.	N.R.	Not applicable ✓
19.	Fire Control Room			

	➤ Detector System Panel	N.R.	N.R.	Not applicable
	➤ Flow Switch Panel	N.R.	N.R.	Not applicable
	➤ PA system Panel	N.R.	N.R.	Not applicable
	➤ Batter backup	N.R.	N.R.	Not applicable
	➤ Building Floor plans	N.R.	N.R.	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Name

Sunil Chawdhary

Designation

D.O.

Signature of the Inspection Officer

Name

Designation