

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110 001

No. *F6/DFS/MS/School/2012/283*

Dated: *31/01/12*

FIRE SAFETY CERTIFICATE

Certified that the **Mother Khazani Convent School** at Mungeshpur, Delhi-39 is comprised of ground & first floor only thus below 09 meters have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education & verified by the officer concerned of Fire Service on 16.01.2012 in the presence of Sh. Naresh Kumar (Vice-Principal), Mother Khazani Convent School and that the building/premises is fit for occupancy Class B (**Educational**) with effect from *31/01/12*....for a period of three years subject to the conditioned mentioned below.

Issued on ...*31/01/12*..... at New Delhi by.



DIRECTOR
Delhi Fire Service

To:

ofc
AS
AM
Sh. Naresh Kumar (Vice-Principal),
Mother Khazani Convent School,
Mungeshpur, Delhi-39.



Copy to: -

The Director of Education,
Old Secretariat,
Delhi.

May kindly see the letter no.MKCS/V2/P-97/1344 dated 23.12.2011 received from Mr. Naresh Kumar (Vice-Principal), Mother Khazani Convent School, Mungeshpur, Delhi-39 regarding issuance of NOC from fire safety point of view. Premises was inspected by the ADO (WP) on 16.01.2012 & observed that the school building having two blocks, One is old block which is found locked at the time of inspection. Other new block is comprised of ground & first floor only having plot area approx 2.5 acre and covered area is 2150 sq. mtrs. approx (Total 30 rooms).

The point wise compliance of fire safety recommendations accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education are given below:-

INSPECTION REPORT				
1	Name & Address of the building	Mother Khazani Convent School		
	Type of occupancy	Mungeshpur, Delhi-110039		
3	Type of case	Educational		
4	Details of previous NOC	New Case (old Building)		
5	Fire Safety directives letter no.	Nil		
6	Date of Inspection	16.01.2012		
7	Name of the Inspecting officers	Mr. Raj Mal Khokhar, ADO(WP)		
8	Name and designation of officers from the building	Mr. Naresh Kumar (Vice-Principal)		
9	Year of Construction	Year 1998 (Old Building)		
10	Applicant's letter no.	MKcs/V2/P-97/1344 dated 23.12.2011		
S.N	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 mtrs.	8 mtrs.	MR
	Gate width	2 gate of width 5 mtrs. each	Provided	MR
	Width of internal road	NR	NP	
2	Number, Width, type & Arrangement of Exits			
	a. Number of staircases			
	Upper Floors	2 nos.	Provided	MR
	Basement	NA	NA	
	a. Width of staircases			
	Upper Floors	1.5 mtr & 1.25 mtr.	Provided	MR
	Basements	NA	NA	
	b. Protection of exits			
	Fire check door	NR	NP	
	Pressurization	NR	NP	
	c. No. of continuous staircases to terrace	Both	Provided	MR
	d. Width of Corridor	NR	NP	
	e. Door Size	1 mtr. width & 2 mtrs. in height	Provided	MR
3	Compartmentation			
	• Fire check door	NR	NP	
	• Sealing of electrical shafts	NR	NP	
	• Fire Rating of shaft door	NR	NP	
	• Water curtain	NR	NP	
	• Fire Dampers	NR	NP	
4	Smoke Management System			
	• Basements	NR	NP	
	• Upper Floors	NR	NP	

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types 	10 Nos.	Provided	MR
		5 nos. ABC type cap. 5 kg.		
		, 5 nos. WCo2 cap. 9 ltr.		
		Each	Provided	MR
	<ul style="list-style-type: none"> ISI marking 	Yes	Provided	MR
6	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	NR	NP	
	<ul style="list-style-type: none"> Length of hose reel hose 	NR	NP	
	<ul style="list-style-type: none"> Nozzle diameter 	NR	NP	
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NR	NP	
	<ul style="list-style-type: none"> Location of Main panel 	NR	NP	
	<ul style="list-style-type: none"> Location of repeater Panel 	NR	NP	
	<ul style="list-style-type: none"> Alternation source of power 	NR	NP	
	<ul style="list-style-type: none"> Hooter's location 	NR	NP	
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	
	<ul style="list-style-type: none"> Upper Floor 	NR	NP	
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NR	NP	
	<ul style="list-style-type: none"> Number of hydrants per floor 	NR	NP	-
	<ul style="list-style-type: none"> Hose Box 	NR	NP	-
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NR	NP	
	<ul style="list-style-type: none"> Hose Box 	NR	NP	
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 	NR	NP	
	<ul style="list-style-type: none"> Discharge of main pump 	NR	NP	
	<ul style="list-style-type: none"> Head of Main pump 	NR	NP	
	<ul style="list-style-type: none"> Number of main pumps 	NR	NP	
	<ul style="list-style-type: none"> Jockey pump output 	NR	NP	
	<ul style="list-style-type: none"> Jockey Pump Head 	NR	NP	
	<ul style="list-style-type: none"> Standby Pump output 	NR	NP	
	<ul style="list-style-type: none"> Standby pump head 	NR	NP	
	<ul style="list-style-type: none"> Auto starting/Manual stopping 	NR	NP	
	<ul style="list-style-type: none"> Pump House Access 	NR	NP	
	<ul style="list-style-type: none"> Terrace Level 	NR	NP	
	<ul style="list-style-type: none"> Discharge of the pump 	NR	NP	
	<ul style="list-style-type: none"> Head of the Pump 	NR	NP	
	<ul style="list-style-type: none"> Power Supply 	NR	NP	-
	<ul style="list-style-type: none"> Auto Starting of Pump 	NR	NP	-
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	NR	NP	
	<ul style="list-style-type: none"> Draw-off connection 	NR	NP	
	<ul style="list-style-type: none"> Fire Service inlet 	NR	NP	
	<ul style="list-style-type: none"> Access to tank 	NR	NP	
	<ul style="list-style-type: none"> Overhead Tank capacity 	NR	NP	
15	Exit Signage	Required	Provided	MR

16	Provision of Lifts			
	• Pressurization of Lift Shaft	NR	NP	
	• Pressurization of Lift Lobby	NR	NP	
	• Communication in lift car	NR	NP	
	• Fireman's Grounding Switch	NR	NP	
	• Lift Signage	NR	NP	
17	Standby Power Supply	NR	NP	
18	Refuge Area			
	• Total Area	NR	NP	
	• Location	NR	NP	
19	Fire Control Room			
	• Detector System Panel	NR	NP	
	• Flow Switch Panel	NR	NP	
	• PA system Panel	NR	NP	
	• Batter backup	NR	NP	
	• Building Floor Plans	NR	NP	
20	Special Fire Protection Systems for Protection of special Risks, If any:	NA	NA	

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education. "Form H' is put up for favour of approval & signature please.

Signature of the Inspecting officer

Signature of the Inspecting officer

Name RAJ MAL KHOKHAR

Name

Designation A 00

Designation