

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/Club/2012/253 Dated: 27 / 01 / 2012

FIRE SAFETY CERTIFICATE

Certified that the Punjabi Bagh Club located at Punjabi Bagh, Ringh road, New Delhi.110026., comprised of basement, ground floor & two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/GH/09/358 dated 05-02-2009. The premises was re-inspected by the officers concerned of this department on 16/01/2012 in the presence of Mr. Puri (Manager) of the Club and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for Class D (Assembly) occupancy with effect from 27/01/12 for a period of three years subject to conditions printed below.

Issued on...27/01/12.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

ole

Copy to:

1. The Additional Commissioner of Police (Lic), 1st floor,
Police Station, Defense Colony, New Delhi
2. Mr. Puri (Manager)
Punjabi Bagh Club
Punjabi Bagh, Ringh road, New Delhi.110026.

Note :- For general fire safety directives please over leaf.

May Kindly peruse letter no. 53182-86/Addl.C.P./Lic.(H) dated 11-11-2011 received from the Addl. Commissioner of Police Licensing unit; Delhi, regarding issue of NOC r/o Punjabi Bagh Club located at Punjabi Bagh, Ringh road, New Delhi.110026. This Club has already been issue NOC wide letter no. F6/DFS/MS/GH/09/358 dated 05-02-2009. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : Punjabi Bagh Club located at Punjabi Bagh, Ringh road, New Delhi.110026.
2. Type of Occupancy : Class D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/09/358 dated 05-02-2009
5. Fire Safety directives letter No. : F6/DFS/MS/2006/347 dated 08-02-2006
6. Date of inspection : 16.01.2012
7. Name of the Inspecting Officers : Division Officer Sunil Chowdhary & A.D.O. S.S. Tuli
8. Name and designation of officers
From the building side : Mr. Puri (Manager)
9. Year of Construction :
10. Applicant's letter No. : 53182-86/Addl.C.P./Lic.(H) dated 11-11-2011

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

| S. No. | Minimum Standards on fire Prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | 09mtrs | Provided | M/R ✓ |
| | • Gate width | 5 mtr | Provided | M/R ✓ |
| | • Width of internal road | 5 mtr | Provided | M/R ✓ |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | Two | Provided | M/R ✓ |
| | • Upper Floors | Two | Provided | M/R ✓ |
| | • Basement | Two | Provided | M/R ✓ |

| | | | | |
|--------------|--|---------------------|-----------|------------------|
| | b. Width of staircases | | | |
| | • Upper Floors | 1.5 mtr | Provided | M/R ✓ |
| | • Basement | 1.5 mtr | Provided | M/R ✓ |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided- | M.R.- ✓ |
| | • Pressurization | N.R.- | N.R.- | N.R.- ✓ |
| | d. No. of continuous staircases to terrace | Two | Provided | M/R ✓ |
| | e. Width of Corridor | 2 mtr | Provided | M.R ✓ |
| f. Door size | 1.5 mtrs | 1.5 mtr | M.R. ✓ | |
| 3. | Compartmentation. | | | |
| | • Fire check door | Required | Provided | M.R. ✓ |
| | • Sealing of electrical shafts | N/A | N/A | Not applicable ✓ |
| | • Fire Rating of shaft door | N/A | N/A | Not applicable ✓ |
| | • Water Curtain | N/A | N/A | Not applicable ✓ |
| | • Fire Dampers | N/A | N/A | Not applicable ✓ |
| 4. | Smoke Management System. | | | |
| | • Basements | Required | Provided | M.R ✓ |
| | • Upper floors | Natural ventilation | Provided | M.R ✓ |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 20 | Provided | M.R ✓ |
| | • Types | ABC type | Provided | M.R ✓ |
| | • IS marking | ISI marked | yes | M.R ✓ |
| 6. | First-Aid Hose Rees. | | | |

| | | | | | |
|-----|---|--------------|-------------------|------|---|
| | <ul style="list-style-type: none"> Total numbers on each floor | | Two at each floor | M.R | ✓ |
| | <ul style="list-style-type: none"> Length of hose reel hose | 30 m | yes | M.R | ✓ |
| | <ul style="list-style-type: none"> Nozzle diameter | 5 mm | yes | M.R | ✓ |
| 7. | Automatic fire detection and alarming system. | | | | |
| | <ul style="list-style-type: none"> Type of detectors | Heat & smoke | Provided | M.R | ✓ |
| | <ul style="list-style-type: none"> Location of Main Panel | Ground floor | Provided | M.R | ✓ |
| | <ul style="list-style-type: none"> Location of Repeater Panel | Ground floor | Provided | M.R | ✓ |
| | <ul style="list-style-type: none"> Alternate source of power | Required | 400 KVA | M.R | ✓ |
| | <ul style="list-style-type: none"> Hooter's Location | Required | Provided | M.R | ✓ |
| 8. | MOEFA | Required | Provided | M.R | ✓ |
| 9. | Public Address System. | Required | Provided | M.R | ✓ |
| 10. | Automatic Sprinkler system | Required | Provided | M.R | ✓ |
| | <ul style="list-style-type: none"> Basement | Required | Provided | M.R | ✓ |
| | <ul style="list-style-type: none"> Upper Floor | Required | Provided | M.R | ✓ |
| | <ul style="list-style-type: none"> Sprinkler above false ceiling | Required | Provided | M.R | ✓ |
| 11. | Internal Hydrants | | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer | 150 mm | provided | M.R | ✓ |
| | <ul style="list-style-type: none"> Number of hydrants per floor | 2 each floor | provided | M.R. | ✓ |
| | <ul style="list-style-type: none"> Hose Box | 2 each floor | provided | M.R | ✓ |

| | | | |
|------------|---|----------|--------------------------|
| 12. | Yard Hydrants. | | |
| | • Total number of hydrants | 6 | Provided M.R. ✓ |
| | • Hose Box | 6 | Provided M.R. ✓ |
| 13. | Pumping Arrangements. | | |
| | Ground Level | | |
| | ➤ Discharge of main pump | N.R. | Provided 1620 LPM M.R. ✓ |
| | ➤ Head of Main pump | 40 mtr | 40 mtr M.R. ✓ |
| | ➤ Number of main pumps | 1 | Provided M.R. ✓ |
| | ➤ Jockey Pump out put | 180 LPM | Provided M.R. ✓ |
| | ➤ Jockey pump head | 40 mtr | Provided M.R. ✓ |
| | ➤ Standby pump out put | N.R. | N.R. Not applicable ✓ |
| | ➤ Standby pump Head | N/A | N/A Not applicable ✓ |
| | ➤ Auto Starting/Manual stopping | Required | Provided M.R. ✓ |
| | ➤ Pump Hose Access | Required | Provided M.R. ✓ |
| | Terrace level | | |
| | ➤ Discharge of pump | 900 LPM | Provided M.R. ✓ |
| | ➤ Head of the pump | 40 mtr | Provided M.R. ✓ |
| | ➤ Power supply | Required | Provided M.R. ✓ |
| | ➤ Auto Starting of pump | Required | Provided M.R. ✓ |
| 14. | Captive Water Storage for fire fighting. | | |

| | | | | |
|-----|----------------------------------|----------|------------------------|------------------|
| | Underground tank capacity | N.R. | Provided 50,000 ltr | M.R. |
| | ➤ Draw -off connection | N.R | Provided | M.R ✓ |
| | ➤ Fire service inlet | Required | Provided | M.R ✓ |
| | ➤ Access to tank | Required | Provided | M.R ✓ |
| | ➤ Overhead Tank Capacity | Required | Provided | M.R ✓ |
| 15 | Exit Signage. | Required | Provided | M.R. ✓ |
| 16. | Provision of Lifts | | | |
| | • Pressurization of Lift Shaft | N.A | N.A. | Not applicable ✓ |
| | • Pressurization of Lift lobby | N.R. | N.R. | Not applicable ✓ |
| | • Communication In lift Car | N.A. | N.A | Not applicable ✓ |
| | • Fireman's Grounding Switch | N.A. | N.A. | Not applicable ✓ |
| | • Lift Signage | N.A | N.A. | Not applicable ✓ |
| 17. | Standby power supply | Required | Provided 400 K.V.A. | M.R ✓ |
| 18. | Refuge Area | | | |
| | ➤ Total Area | N.R. | N.R. | Not applicable ✓ |
| | ➤ Location | N.R. | N.R. | Not applicable ✓ |
| 19. | Fire Control Room | | | |
| | ➤ Detector System Panel | Required | Provided | M.R ✓ |
| | ➤ Flow Switch Panel | Required | Provided | M.R ✓ |
| | ➤ PA system Panel | Required | Provided | M.R ✓ |
| | ➤ Batter backup | Required | Provided | M.R ✓ |

| | | Required | Provided | M.R |
|-----|---|----------|----------|----------------|
| | ➤ Building Floor plans | | | |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any: | N.R. | N.R. | Not applicable |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

S.S. Tuli

Name

Sunil Chawdhary

Designation

ADD(MW)

Designation

D.O (West)