

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2012 / EH / 942

Dated 14/03/12

FIRE SAFETY CERTIFICATE

Certified that the Tao Restaurant (A Unit of K.S. Hotel Pvt. Ltd.) located at E-8, (Ground & mezzanine floor) Connaught Place, New Delhi, was granted NOC by this department vide letter No F6/MS/DFS/EH/2009/ 848 dated 24.03.2009. The premises was inspected by the officer concerned of this department on 02.03.2012 in the presence of Mr. Rana, GM and found that the Restaurant have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D Assembly Building of with effect from 14/03/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 14/03/12 at New Delhi by.



Chief Fire Officer
For Director
Delhi Fire Service

of
me

Copy to: -

- 1) The Medical Officer of Health, N.D.M.C., Health Deptt, Palika Kendra, New Delhi
- 2) Tao Restaurant located at E-8, (Ground & mezzanine floor) Connaught Place, New Delhi.

Conditions for the validity of fire safety certificate

- 1) All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2) Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5) The basement shall be used as per the provisions of BBL.
- 6) The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECITON REPORT

1. Name & address of the building: Tao Restaurant, Located at E-8, Connaught Place, New Delhi
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/DFS/MS/EH/2009/848 Dated 24.03.2009
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 02.03.2012
7. Name of the Inspecting Officer : ADO D.S. Yadav
8. Name and designation of Officer
 from the building side : Mr. Rana, GM
9. Year of Construction : N/A
10. Applicant's letter No. : KSH/TAO/FIR/11-12/01 Dated 17.02.2012

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC Requirements | Provided at site | Remarks MR/NMR |
|------|---|------------------|------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | N/A | Main Road | MR |
| | • Gate width | N/A | N/A | N/A |
| | • Width of internal road | N/A | N/A | N/A |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 02 | 02 | MR |
| | • Basements | N/A | N/A | N/A |
| | b. Width of staircases | | | |
| | • Upper floors | N/A | 1.00/0.9 | MR |
| | • Basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No of continuous staircase to terrace | N/A | N/A | N/A |
| | e. Width Of Corridor | N/A | N/A | N/A |
| | f. Door Size | N/A | 1.25 | MR |

| | | | | |
|-----|---|-----------------|---------------------------------|-----|
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Sealing of electrical shafts | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Fire Rating of shaft door | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Water Curtain | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke managements System | | | |
| | <ul style="list-style-type: none"> • Basements | 30 a/c per hour | N/A | N/A |
| | <ul style="list-style-type: none"> • Upper floors | 12 a/c per hour | YES | MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers | | 08 | MR |
| | <ul style="list-style-type: none"> • Types | | 4CO ₂ , 2WT, 2DCP | MR |
| | <ul style="list-style-type: none"> • IS marking | ISI marked | YES | MR |
| 6. | First – Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor | - | 01 | MR |
| | <ul style="list-style-type: none"> • Length of hose reel hose | 30 m | YES | MR |
| | <ul style="list-style-type: none"> • Nozzle diameter | 5 mm | YES | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> • Type of detectors | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Location of Main Panel | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Location of Repeater Panel | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Alternate source of power | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | YES | YES | MR |
| 9. | Public Address System | YES | YES | MR |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> • Basements | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Upper Floor | YES | YES | MR |
| | <ul style="list-style-type: none"> • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> • Size of riser/down- comer | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Number of hydrants per floor | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Hose Box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> • Total number of hydrants | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> • Ground Level | | | |
| | | N/A | N/A | N/A |

| | | | | |
|-----|---|---------|--------|-----|
| | <ul style="list-style-type: none"> • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | 450 Lpm | YES | MR |
| | | 100 Lpm | | |
| | | 30 M | 30 M | MR |
| | | YES | YES | MR |
| | | YES | YES | MR |
| 14. | Captive water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | 5000 L | 5000 L | MR |
| 15 | Exit Signage | YES | YES | MR |
| 16. | Provision of Lifts | | | |
| | <ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 17. | Standby power supply | YES | YES | MR |
| 18. | Refuge Area | | | |
| | <ul style="list-style-type: none"> ➤ Total area ➤ Location | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 19. | Fire control room | | | |
| | <ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | N/A | N/A | N/A |

OLD CASE

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name

ATUL GARG

Designation

DD/HQ/CC

Signature of the Inspecting Officer

Name

DHARM VIR SINGH YADAV

Designation

A.D.O (Control)