

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/Auditorium/2012/635 Dated: 24/02/12

FIRE SAFETY CERTIFICATE

Certified that the Auditorium at Swaminarayan Akshardham Temple, N.H.-24, Opp. Nizammuddin Bridge, Delhi-92, owned/occupied by BAPS Swaminarayan Sanstha, comprised of ground floor only was granted NOC vide letter No. F6/DFS/MS/2011/Auditorium/249 dated 15.02.11. The auditorium building was inspected by the officers concerned of this department on dated 28.01.12 in the presence of Swami Dhyeynishtha Das and found that the auditorium building have complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D' Assembly Building' with effect from 24/02/12 for a period of **three** years, subject to conditions printed overleaf.

Issued on 24/02/12 at New Delhi by



Chief Fire Officer
Delhi Fire Service

24/02/12

The Addl. Commissioner of Police(Lic),
First floor, police Station,
Defence Colony, New Delhi

in reference letter no 64630- 35/Addl.CP/Lic.(Amst)
dated 28.12.12

Copy to-

Sh. Jayesh Gadhiya,
BAPS Swaminarayan Sanstha
Swaminarayan Akshardham Temple, N.H -24,
Opp Nizammuddin Bridge, delhi-92

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Akshar Dham Temple Auditorium
2. Type of Occupancy : Assembly
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DFSI MS/2011/Auditorium/296 Dated: 15.02.2017
5. Fire Safety directives letter No : Issued to entire bld/complex
6. Date of inspection : 2.2.2012
7. Name of the Inspecting Officers : ADO Suresh Singh. DO Virendra Singh
8. Name and designation of officers from the building side : JAYESH KISHORE
9. Year of Construction : 2005
10. Applicant's letter No. : 66630 - 35/Adm C.P./Lic (Amst) dt 28.2.17

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 M	20 M	MR
	• Gate width	4.5	6 M	MR
	• Width of internal road			
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	2	MR
	• Upper Floors	2	2	MR
	• Basements	—	—	—
	b. Width of staircases	2 M	2 M	MR
	• Upper Floors	2 M	2 M	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	2 M	2 M	MR

			Provided	
3	Compartmentation.		Provided	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.	Provided		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers	Required		
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 No ISI marked	10 No CO2 Water CO2 ISI	MR MIR MR
6	First-Aid Hose Reels.	Required		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2 No 30 m 5 mm	2 No 30 m 5 mm	MIR MIR MIR
7	Automatic fire detection and alarming system.	Provided		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke — — — Hall	Provided — — — Hall	MIR — — — MR
8	MOEFA	Provided	Provide	MIR
9	Public Address System.		Yes	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 			

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants	Provided		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100 mm	100 mm	MIR
		1	1	MIR
		2 No	2 No	MIR
12	Yard Hydrants.	Provided		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	2 No	2 No	MIR
		2 No	2 No	MIR
13	Pumping Arrangements.	Required		
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
		2850 LPM	2850 LPM	MIR
		70 M	70 M	MIR
		1	1	MIR
		225 LPM	225 LPM	MIR
		70 M	70 M	MIR
		70 M	70 M	MIR
		—	Auto	MIR
		—	—	—
		—	Yes	—
		—	—	—
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.	:		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	200000 ltr	400000 ltr	MIR
			Provided	MIR

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	Yes	MIR
		—	Yes	MIR
		—	—	—
15	Exit Signage.	—	Provided	MIR
16	Provision of Lifts.	N/A		
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	Yes	—
18	Refuge Area.	N/A		
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	N/A		
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the D-Fire Service Rules 2010 ~~issue shortcomings as noted at serial numbers~~

Singh

Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ADO*

Dy CFO

Singh
15/12

Virendra Singh

Signature of the Inspecting Officer

Name *VIRENDRA SINGH*

Designation *AO(E)*