

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2011/ *school/811*

Dated:- *06/03/12*

FIRE SAFETY CERTIFICATE

Certified that the *Govt Sarvodaya Kanya Vidyalaya*
Adrash Nagar Delhi 110033 comprised of *Ground + one*
upper floor owned/occupied by *Govt Sarvodaya*
Kanya Vidyalaya. Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on *23/2/12* in the presence of
Mrs. Sarima Garg and that the building/premises is fit for occupancy
Educational building with effect from *06/03/12* for a period of
03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *06/03/12* at New Delhi.

[Signature]
6/3

Chief Fire Officer
Delhi Fire Service

[Signature]

Copy to:-

- The Principal*
Govt Sarvodaya Kanya Vidyalaya
Adrash Nagar Delhi
- The Addl. Director Edu (AET)*
Govt of NCT of Delhi
Old Sectt - Delhi

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NBC.
 6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

29

INSPECTION REPORT

1. Name & address of the building : Govt Kanya Sarvodaya Vidyalaya, Adarsh, vijaya, belga.
2. Type of Occupancy : Educational (Ground + one)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: _____
5. Fire Safety directives letter No : _____
6. Date of inspection : _____
7. Name of the Inspecting Officers : DO vijay kental
8. Name and designation of officers from the building side : Smt. Garima Garg
9. Year of Construction : 2000
10. Applicant's letter No. : SKV/AN/2/2011/5790/29.11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement <i>Director of Education Circular No 1-3/11</i>	Provided at site	Remarks M/R
1	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>M/R</u>
	• Gate width	<u>N.A</u>		
	• Width of internal road			
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>8 no</u>	<u>8</u>	<u>M/R</u>
	• Basements			
	b. Width of staircases	<u>1.5 mtr & if width is less than additional staircase required</u>	<u>1.45 mtr & NO 1.35 mtr. 4 NO</u>	<u>M/R</u>
	• Upper Floors			
	• Basements			
	c. Protection of exits	<u>N.A</u>		
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>width 1 mtr, 2 exits of contra if students more than 45</u>	<u>2 No. of 1 mtr width</u>	<u>M/R</u>

2/10

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	DCP type / CO2 type, 2.5kg ISI marked	water CO2 & DCP type	N/A
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	N/A	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	
8	MOEFA		N/A	
9	Public Address System.		N/A	
10	Automatic Sprinkler System.		N/A	
	<ul style="list-style-type: none"> • Basement 		N/A	

N/11

	<ul style="list-style-type: none">• Upper Floor• Sprinkler above false ceiling			
11	Internal Hydrants			
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box			
12	Yard Hydrants.			
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box			
13	Pumping Arrangements.			
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none">• Underground tank capacity➤ Draw-off connection			

4/12

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.		<i>n.r</i>	<i>Provided</i>
16	Provision of Lifts.		<i>n/a</i>	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		<i>n/a</i>	
18	Refuge Area.		<i>n/a</i>	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room		<i>n/a</i>	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

The short coming for Exit sign in stair case & corridor, Emergency telephone no. board communicated by dept letter dt. 3.11.11 copy previous file not traceable.

2/13

Signature of the Inspecting Officer

keentat
Signature of the Inspecting Off

Name

Name *VIPIN KENIAT*

Designation

Designation *Donor*

DCFO

S-4
1/3