

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : CONNAUGHT LANE
NEW DELHI-110 001.

No. F6/OFS/MS/school/2012/344

Dated : 02/02/12

FIRE SAFETY CERTIFICATE

Certified that the **M.C. PRIMARY SCHOOL** located at **Ladpur, Delhi-110 081**, comprised of ground plus one upper floor only and less than 9 meters in height, have complied with the fire prevention and fire safety requirement in accordance with Director of Education circular dated 01.03.2001 and verified by the officer concerned of fire service on 23.01.2012 in the presence of Shri Sandeep Kumar Mor, Principal and that the building/ premises is fit for occupancy class **Educational class** with effect from 02/02/12 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/02/12 at New Delhi by



Director
Delhi Fire Service

OK
MS
ASO



29/1

Shri Sandeep Kumar Mor, Principal,
M.C. PRIMARY SCHOOL,
Ladpur, Delhi-110 081.

Copy to :

The Director,
Dte. Of Education,
Old Sectt., Delhi.

Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

INSPECTION REPORT

1. Name & address of the building : M.C. PRIMARY BOYS SCHOOL, LADPUR, DELHI-81
2. Type of Occupancy : SCHOOL
3. Type of Case : NEW CASE
4. Details of previous NOC : N.A.
5. Fire Safety directives letter No. : F.16/Estate/cc/Fire Safety/2011/3298-3398 Dt. 1-3-2011
6. Date of inspection : 28/01/2012
7. Name of the Inspecting Officers : SHRI RAJMAL KHOKHAR, ADO
8. Name and designation of officers
From the building side : SHRI SANDEEP KUMAR VAR, PRINCIPAL
9. Year of Construction : 2010
10. Applicant's letter No. : No. 1 Dated 15/12/11

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Direction NBC letter 01-1-3-11 Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	—u—	—u—	—u—
	• Width of internal road	—	—	—
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	Two	Two	MR
	• Upper Floors	—u—	—u—	—u—
	• Basement	—	—	—
b.	Width of staircases	150 cms each	170 cms each	MR
	• Upper Floors	—u—	—u—	—u—
	• Basement	—	—	—
c.	Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
d.	No. of continuous staircases to terrace	Two	Two	MR
e.	Width of Corridor	1½ Meters	2½ Meters	MR
f.	Door size	Single Door 100 cm	Double Door 105cm each	MR

	Compartmentation.			NA
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System.			NA
	• Basements	-	-	-
	• Upper floors	-	-	-
5.	Fire Extinguishers			Provided
	• Total numbers		4 - 5kg 2 - 3kg	MR
	• Types		ABC Type	-u-
	• IS marking	ISI marked	ISI Marked	-u-
6.	First-Aid Hose Rees.			NA
	• Total numbers on each floor	_____	-	-
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7.	Automatic fire detection and alarming system.			NA
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooter's Location	-	-	-
8.	MOEFA			NA
9.	Public Address System.	Required	Provided	MR

10.	Automatic Sprinkler system		NA	
	• Basement	1	1	1
	• Upper Floor	1	1	1
	• Sprinkler above false ceiling	1	1	1
11.	Internal Hydrants		NA.	
	• Size of riser/down-comer	1	1	1
	• Number of hydrants per floor	1	1	1
	• Hose Box	1	1	1
12.	Yard Hydrants.		NA	
	• Total number of hydrants	1	1	1
	• Hose Box	1	1	1
13.	Pumping Arrangements.		NA.	
	Ground Level			
	➤ Discharge of main pump	1	1	1
	➤ Head of Main pump	1	1	1
	➤ Number of main pumps	1	1	1
	➤ Jockey Pump out put	1	1	1
	➤ Jockey pump head	1	1	1
	➤ Standby pump out put	1	1	1
	➤ Standby pump Head	1	1	1
	➤ Auto Starting/Manual stopping	1	1	1
	➤ Pump Hose Access	1	1	1
	Terrace level			
	➤ Discharge of pump	1	1	1
	➤ Head of the pump	1	1	1
	➤ Power supply	1	1	1
	➤ Auto Starting of pump	1	1	1

14.	Captive Water Storage for fire fighting.			NA
	Underground tank capacity			
	➤ Draw -off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	➤ Overhead Tank Capacity			
15	Exit Signage.	Repaired	Provided	MR
16.	Provision of Lifts			NA
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17.	Standby power supply			NA.
18.	Refuge Area			NA
	➤ Total Area			
	➤ Location			
19.	Fire Control Room			NA
	➤ Detector System Panel			
	➤ Flow Switch Panel			
	➤ PA system Panel			
	➤ Batter backup			
	➤ Building Floor plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any:			

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.
✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....



Signature of the Inspection Officer

Signature of the Inspection Officer

Name SHRI RAJMAL KHOKHAR

Name

Designation ASST. DIR. OFFICER

Disignation

50 (NY)