

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,  
NEW DELHI-110001**

No: *F6/DFS/MS/school/2012/804*

Dated: *06/03/12*


**FIRE SAFETY CERTIFICATE**

Certified that the N.P. Middle School located at Sangli Mess, New Delhi-110001 owned/occupied by N.P. Middle School, building comprised of ground plus two upper floors have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 27-02-2012 in the presence of Mr. Jasbir Singh, FO cum NA of NDMC and that the building is fit for occupancy class B "Educational Building" Sub Division B-1 with effect from...*06/03/12*... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if

Issued on *06/03/12* at New Delhi by.

  
CHIEF FIRE OFFICER  
FOR DIRECTOR  
DELHI FIRE SERVICE

*Jc* *05-03-12*  
*AD. (Central)*

Copy to :-

-  *For*
1. Mr. Jasbir Singh, FO cum NA, Fire Department, NDMC, Palika Kendra, New Delhi - 110001

**INSPECTION REPORT**

*N.P. Middle School*

1. Name & address of the building : *Sangali mess New Delhi-110001*
2. Type of Occupancy : *Educational.*
3. Type of Case :  New Case/ Renewal
4. Details of previous NOC : Letter No. *- N.A -* Dated: \_\_\_\_\_
5. Fire Safety directives letter No : *- N.A -*
6. Date of inspection : *27-02-2012*
7. Name of the Inspecting Officers : *Dharm vir singh yadav.*
8. Name and designation of officers from the building side : *Shri Jasbir Singh Fire officer cum N.A.*  
*Shri Ram Pal A.E. civil*
9. Year of Construction : *2001*
10. Applicant's letter No. : *File/3526/D. dt 05-11-11*

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<i>Approachable</i>	<i>06 mtrs</i>	<i>M.R</i>
	• Gate width	<i>- " -</i>	<i>05 mtrs</i>	<i>M.R</i>
	• Width of internal road	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<i>—</i>	<i>TWO</i>	<i>M.R</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	b. Width of staircases			
	• Upper Floors	<i>1.5 mtrs</i>	<i>1.65 mtrs &amp; 1.25 mtrs</i>	<i>M.R.</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>M.R</i>
	c. Protection of exits			
	• Fire check door	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	• Pressurization	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	<i>—</i>	<i>1.5 mtrs</i>	<i>M.R</i>
	h. Door Size	<i>—</i>	<i>1.3 mtrs</i>	<i>M.R</i>

*contd. :-*

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	- N.A -		
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	- N.A - Natural ventilation	M.R M.R.
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	Five at each floor. CO <sub>2</sub> Type & w.CO <sub>2</sub> ISI marked	Five at each floor CO <sub>2</sub> Type = 2 w.CO <sub>2</sub> Type = 3 yes.	M.R M.R M.R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One 30 m 5 mm	one at each floor. yes yes	M.R M.R M.R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	- N.A - - N.A - - N.A - - N.A - -		
8	<b>MOEFA</b>	- N.A -	- N.A -	-
9	<b>Public Address System.</b>	-	Provided	M.R
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	- N.A -	- N.A -	- N.A -

contd: -

N.P. middle school Sangali mess  
New Delhi-110001

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	- N.A -	- N.A -	-
11	<b>Internal Hydrants</b>	- N.A -	- N.A -	-
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	- N.A -		
12	<b>Yard Hydrants.</b>	- N.A -		
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	- N.A -		
13	<b>Pumping Arrangements.</b>	- N.A -		
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	-	450 LPM	M.R
		-	40 mtrs	M.R
		-	Elect.	M.R
		-	yes	M.R.
14	<b>Captive Water Storage for fire fighting.</b>	- N.A -	- N.A -	-
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>	- N.A -	- N.A -	-

contd:-

N.P. Middle School,  
Sangali mess  
New Delhi-110001

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			10,000 litres	M.R.
15	Exit Signage.			yes	M.R.
16	Provision of Lifts.				
	• Pressurization of Lift Shaft	- N.A -	- N.A -	-	-
	• Pressurization of Lift lobby	- N.A -	- N.A -	-	-
	• Communication In lift Car	- N.A -	- N.A -	-	-
	• Fireman's Grounding Switch	- N.A -	- N.A -	-	-
	• Lift Signage	- N.A -	- N.A -	-	-
17	Standby power supply				
18	Refuge Area.				
	➤ Total Area	- N.A -	- N.A -	-	-
	➤ Location	- N.A -	- N.A -	-	-
19	Fire Control Room				
	• Detector System Panel	- N.A -	- N.A -	-	-
	• Flow Switch Panel	- N.A -	- N.A -	-	-
	• PA System Panel	- N.A -	- N.A -	-	-
	• Batter backup	- N.A -	- N.A -	-	-
	• Building Floor Plans	- N.A -	- N.A -	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	- N.A -	- N.A -	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

contd: -

N.P. Middle school.  
Sangali mess, New Delhi - 110001

(5)

June  
Signature of the Inspecting Officer  
27/2/12

Name Asst. Engineer (Civil) ROME

Designation

D.O. (Central) [Signature]  
27/2/12

27-2-12  
Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation Asstt. Divisional  
officer  
(Central)