

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/2012/993

Dated: 20 / 03 / 2012

**FIRE SAFETY CERTIFICATE**


Certified that the **PARSVNATH METRO MALL**, located at Inder Lok, New Delhi., comprised of ground plus two floors & terrace was granted NOC by this department vide letter No. **F6/DFS/MS/2007/3455 dated 13/11/2007**. The premises was re-inspected by the officers concerned of this department on **05/03/2012** in the presence of **Mr. S.M. Rishi, Chief Safety Officer** of the Mall and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for Class -F (2) (Mercantile) occupancy with effect from 20/03/12 for a period of three years subject to conditions printed over leaf.

Issued on...20/03/12.....at New Delhi by



Chief Fire Officer  
Delhi Fire Service

OK



22.03.2012

Copy to:  
Mr. S.M. Rishi, Chief Safety Officer  
**PARSVNATH METRO MALL,**  
Inder Lok, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

May Kindly peruse letter no. BPPL/HO\_Corp./2011-2012 dated 06/02/2012 received from Authorized Signatory regarding of NOC in r/o Parsvnath Metro Mall, located at Inder Lok, New Delhi. premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa

1. Name & address of the building : **PARSVNATH METRO MALL**, located at Inder Lok, New Delhi.
2. Type of Occupancy : Class -F (2) (Mercantile)
3. Type of Case : Renewal
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : F-6/DFS/MS/BP/2003/2634 dated 24.10.2003
6. Date of inspection : 05-03-2012
7. Name of the Inspecting Officers : A.D.O. Rajmal Khokhar & D.O. Sunil Chawdhary
8. Name and designation of officers  
From the building side : Mr. S.M. Rishi, Chief Safety Officer
9. Year of Construction : 1999-2000
10. Applicant's letter No. : nil

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12mtrs	60mtr.	M.R.
	• Gate width	4.5 mtr	5 mtr	M.R.
	• Width of internal road	6 mtr	10 mtr	M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	5	5	M.R.
	• Basement	N.A.	N.A.	N.A.

b. Width of staircases  • Upper Floors  • Basement  c. Protection of exits  • Fire check door  • Pressurization  d. No. of continuous staircases to terrace  e. Width of Corridor  f. Door size			
	1.5 mtr	Provided	M.R. ✓
	N.A.	N.A.	N.A. ✓
	Required	Provided	M.R. ✓
	Required	Provided	M.R. ✓
	05	05	M.R. ✓
2.4	3 mtr	M.R. ✓	
2 mtrs	2.5 mtrs	M.R. ✓	
3.	<b>Compartmentation.</b>		
• Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers	Required	Provided	M.R. ✓
	Required	Provided	M.R. ✓
	Required	Provided	M.R. ✓
	Required	Provided	M.R. ✓
	Required	Provided	M.R. ✓
4.	<b>Smoke Management System.</b>		
• Basements  • Upper floors	N.A.	N.A.	N.A. ✓
	Required	Provided	M.R. ✓
5.	<b>Fire Extinguishers</b>		
• Total numbers	50	65	M.R. ✓
• Types	ABC & CO <sub>2</sub> type	provided	M.R. ✓
• ISI marking	ISI marked	provided	M.R. ✓

<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	3	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	M.R. ✓
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Ground floor	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	Each floor	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	Required	Provided	M.R. ✓
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M.R. ✓
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	M.R. ✓
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	N.A.	Not applicable ✓
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	M.R. ✓
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150 mm	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	3	Provided	M.R. ✓

	• Hose Box	3	Provided	M.R.
<b>12</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants	Required	Provided	M.R.
	• Hose Box	Required	Provided	M.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	2280 LPM	Provided	M/R
	➤ Head of Main pump	70 mtr	Provided	M/R
	➤ Number of main pumps	2	Provided	M/R
	➤ Jockey Pump out put	180 LPM	Provided	M/R
	➤ Jockey pump head	70 mtr	Provided	M/R
	➤ Standby pump out put	2280 LPM.	Provided	M/R
	➤ Standby pump Head	70 mtr	Provided	M/R
	➤ Auto Starting/Manual stopping	auto	Provided	M/R
	➤ Pump Hose Access	Required	Provided	M/R
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	45 mtr	provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.

	<b>Underground tank capacity</b>	1,40,00 ltrs	provided	M.R.
	➤ Draw -off connection	required	provided	M.R.
	➤ Fire service inlet	required	provided	M.R.
	➤ Access to tank	required	provided	M.R.
	➤ Overhead Tank Capacity	1,40,000 ltrs	provided	M.R.
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M.R.
<b>16.</b>	<b>Provision of Lifts</b>	<b>N.R.</b>	<b>N.R.</b>	<b>Not applicable</b>
	• Pressurization of Lift Shaft	Required	Provided	M.R.
	• Pressurization of Lift lobby	Required	Provided	M.R.
	• Communication In lift Car	required	provided	M.R.
	• Fireman's Grounding Switch	required	provided	M.R.
	• Lift Signage	required	provided	M.R.
<b>17.</b>	<b>Standby power supply</b>	Required.	Provided	M.R.
<b>18.</b>	<b>Refuge Area</b>	N.R.	N.R.	Not applicable
	➤ Total Area	N.R.	N.R.	Not applicable
	➤ Location	N.R.	N.R.	Not applicable
<b>19.</b>	<b>Fire Control Room</b>	Required	provided	M.R.
	➤ Detector System Panel	Required	provided	M.R.
	➤ Flow Switch Panel	Required	provided	M.R.
	➤ PA system Panel	Required	provided	M.R.

	➤ Batter backup	Required	provided	M.R.
	➤ Building Floor plans	Required	provided	M.R.
20.	Special Fire Protection Systems for  Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

*[Handwritten Signature]*

Signature of the Inspection Officer

Signature of the Inspection Officer

Name *RAJMAL ISHOKHAR*

Name

Designation *A.D.O*

Designation

*DO (M.N)*