

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI -- 110001


No: F 6/DFS/MS/2011/School/799

Dated:- 05/03/12

FIRE SAFETY CERTIFICATE

Certified that the SMS Public School, A-61 Kh. No 13/1 and 2 Pili Kothi
Nathu Pura Buzari located at Nathu Pura Buzari Delhi 110084
..... comprised of Ground + 2 upper floor occupied
by SMS Public School, Nathu Pura Delhi was issued NOC vide this office letter
No. F 6/MS/DFS/2006/2138 Dated: 18/08/2006. The premises was re-inspected by the
officer concerned of this department on 9/2/12 and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement under Rule 33
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class
Educational with effect from 05/03/12 for a period of
03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 05/03/12 at New Delhi.


43
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Director Edu. (ACT)
Sect. of WCT of Delhi
old Sect. Delhi
2. The Manager,
SMS Public School
A-61 Kh. No 13/1 & 2
Pili Kothi Nathu Pura
Buzari Delhi



1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NBC.
 6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building SMS Public School, A-61, KH.No. 13/1 & 2, Pili Kothi, Natha pura,
-Burasri, Delhi-84
2. Type of Occupancy Educational.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/MS/DRS/06/2138 Dated: 18-8-2006
5. Fire Safety directives letter No F-16/Estate/CC/F.Safety/11/3298-3398 dt: 18.8.2006
6. Date of inspection 09-2-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers
from the building side : Manager - Sh. Nand Lal
9. Year of Construction : 2002, Gr. & 2010 (G+2), Two blocks - Gr. & Gr. +2
10. Applicant's letter No. SMS/PS/06/12/11 dt: 1-12-2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edun. Requirement 1/3/2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	4 mtrs.	M/R
	• Gate width	—do—	3.30 mtrs.	M/R
	• Width of internal road	—do—	open area	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	3	M/R
	• Upper Floors	2	3	M/R
	• Basements	Nil	Nil	Nil
	b. Width of staircases	1.5 m	1.5 m, 114m, 90cm	M/R
	• Upper Floors	1.5 m.	—do—	M/R
	• Basements	Nil	Nil	Nil
	c. Protection of exits		NR	
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace	1	1	M/R
	g. Width of Corridor	—	2.15	M/R
	h. Door Size	1 m	1 m	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			NR
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		NR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 ABC & CO2 ISI marked	6 ABC & CO2 yes	MIR - -
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one provided provided	MIR -do- -do-
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			NR
8	MOEFA			NR
9	Public Address System.			NR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 			NR

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants		NR	
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.		NR	
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.		NR	
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		450 Lts./min	450 Lts/m	MJR
		40 m	40 m	
14	Captive Water Storage for fire fighting.		NR	
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 			

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name SHYAM LAL

Designation

D.O. (N.W.P)

Designation Assitt. Divn. officer.

pl mention break up of staircase in each block

ADD/R.N.

u
23/2

Sir, There are two blocks interconnected, ground floor & ground + 2 floors, having three No's of stair case, (1) Ground to first width 90 cm (2) Ground to second floor width 1.5 mts. & (3) Ground to terrace floor 1.14 mts. please.

D.O. (N.W.P)

Shyam Lal
ADD(RN)
24/2/2012