

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No:

FD/DFB/MS/2011/school/3595

Dated:

16/12/11

FIRE SAFETY CERTIFICATE

Certified that the building of **Sarvodaya Kanya Vidyalaya**, Deendarpur, New Delhi -110043 comprising of Ground Floor plus one upper floor, having total 36 rooms (Including Class Rooms, Office, Computer Lab, Science Lab, Sports Room, Staff Room, Library, Examination Room & Store etc) owned/occupied by The Govt. of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education, Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 26.11.2011 in the presence of Sh. Ashok Kumar and that the building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on16/12/11.....at New Delhi



CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE
etc
Mev

Copy to: -

- 1 The Vice Principle,
Sarvodaya Kanya Vidyalaya,
Deendarpur, New Delhi-110043.
(Ref No- 5028, dated 09.08.11)
- 2 Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

N/3

May kindly see the letter No. 5028 dated 09.08.2011 received from the Vice Principal, Sarvodaya Kanya Vidyalaya, Deendarpur, New Delhi-110043, regarding grant of fire safety certificate in respect of above said school.

In this connection it is stated that the school building in question was inspected by undersigned on 26.11.2011 with a view to ensure the compliance of the fire safety recommendations issued from the director of education vide circular No.F.16/Estate/CC/Fire.Safety/2011/3298 to 3398 dated 01-03-2011. Sh. Ashok Kumar was also present.

During the course of inspection it was observed that the school building is comprised of ground floor plus one upper floor. The upper floor served by four staircases having width 146cms, 189 cms, 170 cms & 172 cms respectively. The building is directly approachable to the fire fighting vehicles. The electrical wiring was seen concealed and the electric supply was passing through MCB's. The building is properly ventilated. The room's allocation in the school is as under: -

Total Rooms: - 36 rooms (Including Class Rooms, Office, Computer Lab, Science Lab, Sports Room, Staff Room, Library, Examination Room & Store etc.)

The school building is protected by the following fire safety arrangements are as under: -

1. **Access to the building:** Available.
2. **Numbers of Doors in a Class Room:** Double doors are provided.
3. **Fire Extinguishers:** One Co2 type Fire Extinguisher of 2.5 Kgs Cap. With ISI Marked or one ABC type Fire Extinguisher with ISI marked for every 300 sq.m of covered area, In addition, one Fire Extinguisher each in Laboratory, near to the electrical installation and /or generator Room are provided in the building as per the above said circular.
4. **Staircase:** - Provided four staircases having width 146 cms, 189 cms, 170 cms & 172 cms respectively.

The Fire Extinguishers were checked and the performance found satisfactory at the time of inspection. In view of above said school premises may be considered safe from fire safety point of view for grant of fire safety certificate for running the school in above said building.

DFA is put up accordingly for your perusal and signature please.

D.O (S.W)

1
26/11

Submitted please
Honey
23/11/11