

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2011 / EH / 3667

Dated 22/12/11

FIRE SAFETY CERTIFICATE

Certified that the Tryst Restaurant located at Shop No G-16 & 17, G-30 & 31 Rasvilas Plot No D-1 Distt Centre Saket, New Delhi. Comprised of Ground Floor Only. The premises was inspected by the officers concerned of this department on 30/11/11 in the presence of Mr. Rajeev Goyal and found that the said restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class Group - D Assembly with effect from 22/12/11 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/12/11..... at New Delhi by.


Chief Fire Officer
For Director
Delhi Fire Service

To

1. The Dy. Health Officer, Health Department,
South Zone, MCD, New Delhi.
2. Tryst Restaurant,
G-16 & 17, G-30 & 31
Rasvilas Plot No D-1 Distt Centre Saket, New Delhi

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be uses as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N/1-

INSPECITON REPORT

1. Name & address of the building: Tryst Restaurant, G-16 & 17, G-30 & 31 Rasvilas,
plot no D-1, Distt Centre Saket
2. Type of Occupancy : Assembly *Restaurant*
3. Type of Case : New Case / (but it is situated in the mall
which has already got NOC)
4. Details of previous NOC : Letter No. N/A Dated
5. Fire Safety directives Letter No. : However building get NOC
6. Date of inspection : 30.11.2011
7. Name of the Inspecting Officer : ADO S. Kaushik
8. Name and designation of Officer
from the building side : Mr. Rajeev Goyal
9. Year of Construction : N/A
10. Applicant's letter No. : MCD Letter No DHO/S2/11/HD/D/2769 Dated 25.11.2011

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A	N/A	As it is situated at GF
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	N/A	N/A	situated at GF
	• Upper floors	N/A	N/A	situated at GF
	• Basements	N/A	N/A	situated at GF
	a. Width of staircases	N/A	N/A	situated at GF
	• Upper floors	N/A	N/A	situated at GF
		N/A	N/A	situated at GF

11/2

	<ul style="list-style-type: none"> Basements Protection of exits Fire check door Pressurization No of continuous staircase to terrace Width Of Corridor Door Size 	YES	YES	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		2.00/1.50 mtr <i>Two No of Exits</i>	YES	MR(as area is approximately 175 sqm only)
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	YES	YES	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 each type	YES	MR
		WT, CO ₂ , DCP	YES	MR
		YES	YES	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02	YES	MR
		30 m	YES	YES
		5 m m	YES	YES
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	YES	MR
		YES	YES	MR
		N/A	N/A	N/A
		YES	YES	MR
		YES	At entrance	MR
8.	MOEFA	YES	YES	MR
9.	Public Address System	N/A	N/A	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	YES	MR
		N/A	N/A	MR
11.	Internal Hydrants			

	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	YES	YES	MR (already available in the bldg.)
		1	YES	MR
		1	YES	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	CONNECTED TO MAIN FIRE PUMP HOUSE OF MALL		MR
				MR
				MR
				MR
				MR
				MR
				MR
				MR
				MR
				MR
				MR
				MR
				MR
				MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	YES	Common water Tank is available	MR
		YES	YES	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15	Exit Signage	YES	YES	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	YES	YES	MR

- 2/4 -

18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name S.S. Kausluk

Designation

Designation Asstt Div. Officer

DO (South)


18/12/11