

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DAS/MS/CH/2012/1092

Dated: 27/03/2012

FIRE SAFETY CERTIFICATE

Certified that the M/s Metro View Guest House located at 25, First Floor, Second Floor, Paschim Vihar Extn, New Delhi-110027, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 19.03.2012 in presence of Mr. Luv Kumar (Manager) of the Restaurant and that the premises is fit for Class-A-1 (i) Residential occupancy with effect from 27/03/12.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/03/12.....at New Delhi by



27/3

Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. DHO West Zone
M.C.D. of Delhi, West Zone,
Rajouri Garden, New Delhi,
2. M/s Metro View Guest House
25, First Floor, Second Floor,
Paschim Vihar Extn, New Delhi-110027

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

Rambhadesh

May Kindly peruse letter no.D-128/HO/WZ dated 24/01/2012 received from DHO, MCD West Zone, regarding of NOC in r/o M/s Metro View Guest House located at 25, First Floor, Second Floor, Paschim Vihar Extn, New Delhi-110027. premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : M/s Metro View Guest House located at 25, First Floor, Second Floor, Paschim Vihar Extn, New Delhi-110027.
2. Type of Occupancy : Class-A-1 (i) Residential
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : nil
6. Date of inspection : 19.03-2012
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
8. Name and designation of officers
From the building side : Mr. Luv Kumar (Manager)
9. Year of Construction :
10. Applicant's letter No. : D-128/HO/WZ dated 24/01/2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	Provided	M.R.
	• Gate width	4.5 mtr	Provided	M.R.
	• Width of internal road	N.A.	N.A.	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	One	Provided	M.R. As per BBL-83
	• Upper Floors	One	Provided	M.R.

	<ul style="list-style-type: none"> Basement 	Two	Provided	M/R ✓
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basement 	1.45mtr	Provided	M.R. As per BBL-83 ✓
	c. Protection of exits	1.45 mtr & 90 c.m.	Provided	M/R As per BBL-83 ✓
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required	Provided	M.R. ✓
	d. No. of continuous staircases to terrace	N.R.	N.R.	✓
	e. Width of Corridor	one	Provided	M.R. ✓
	f. Door size	1 mtr approx.	Provided	M.R. ✓
		1 mtr	Provided	M.R. ✓
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Sealing of electrical shafts 	N.A.	N.R	Not applicable ✓
	<ul style="list-style-type: none"> Fire Rating of shaft door 	N.A.	N.R	Not applicable ✓
	<ul style="list-style-type: none"> Water Curtain 	N.A.	N.R	Not applicable ✓
	<ul style="list-style-type: none"> Fire Dampers 	N.A.	N.R	Not applicable ✓
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	M.R. ✓
5.	Fire Extinguishers			

	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N.A.	N.R.	Not applicable ✓
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 m	Provided	M.R. ✓
	<ul style="list-style-type: none"> Number of hydrants per floor 	1	Provided	M.R. ✓
	<ul style="list-style-type: none"> Hose Box 	1	Provided	M.R. ✓
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N.R.	N.R.	N.R. ✓
	<ul style="list-style-type: none"> Hose Box 	N.R.	N.R.	N.R. ✓
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	Not applicable ✓
	➤ Head of Main pump	N.R.	N.R.	Not applicable ✓
	➤ Number of main pumps	N.R.	N.R.	Not applicable ✓
	➤ Jockey Pump out put	N.R.	N.R.	Not applicable ✓
	➤ Jockey pump head	N.R.	N.R.	Not applicable ✓
	➤ Standby pump out put	N.R.	N.R.	Not applicable ✓
	➤ Standby pump Head	N.R.	N.R.	Not applicable ✓
	➤ Auto Starting/Manual stopping	N.R.	N.R.	Not applicable ✓
	➤ Pump Hose Access	N.R.	N.R.	Not applicable ✓
	Terrace level			

	➤ Total Area	N.R.	N.R.	Not applicable. ✓
	➤ Location	N.R.	N.R.	Not applicable ✓
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided	M.R. ✓
	➤ Flow Switch Panel	Required	Provided	M.R. ✓
	➤ PA system Panel	Required	Provided	M.R. ✓
	➤ Batter backup	Required	Provided	M.R. ✓
	➤ Building Floor plans	N.R.	N.R.	Not applicable ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable. ✓

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Sumit (Chaudhary)

Name

Designation

D. O. O.

Designation

	<ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto Starting of pump 	 	 	
		900 LPM	provided	M.R. ✓
		50 mtr	Provided	M.R. ✓
		Required	Provided	M.R. ✓
		Required	Provided	M.R. ✓
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	<ul style="list-style-type: none"> ➤ Draw -off connection ➤ Fire service inlet ➤ Access to tank ➤ Overhead Tank Capacity 	 	 	
		N.R	N.R	N.R ✓
		N.R	N.R	N.R ✓
		N.R	N.R	N.R ✓
		10,000 Required	Provided Provided	M.R. M.R. ✓
15	Exit Signage.			
16.	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	 	 	
		N.A	N.R	Not applicable ✓
		N.A	N.R	Not applicable ✓
		N.A	N.R	Not applicable ✓
		N.A	N.R	Not applicable ✓
		N.A	N.R	Not applicable ✓
17.	Standby power supply	R	P	M.R ✓
18.	Refuge Area			