

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**


No. F6/DFS/MS/ *School/2012/757*

Dated: *02/03/12*

FIRE SAFETY CERTIFICATE

Certified that **M.C. Primary Girls School, Meethapur Extn.-1, Badarpur, New Delhi**, comprised of ground floor only Owned/Occupied by M.C. Primary Girls School has complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire Service on 03/02/2012 in the presence of Shri Pukhraj Meera, Teacher of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from *02/03/12* for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on *02/03/12* at New Delhi by


Chief Fire Officer
For Director
Delhi Fire Service

Copy To: -

1. The Directorate of Education, Govt. of NCT of Delhi, MCD Civic Centre, Delhi.
2. The Principal, M.C. Primary Girls School,
Meethapur Extn.-1, Badarpur, New Delhi-110044

Conditions for the validity of fire safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building: M.C. Pooj Girls School Meethapur
: Badar Pooj new Delhi 110044
2. Type of Occupancy : Education
3. Type of Case : New
4. Details of previous NOC : NIL
5. Fire Safety directives letter No : NIL Dated: _____
6. Date of Inspection : 3/2/22
7. Name of the Inspecting Officers : Rajan wadhwa ADO/M.Road.
8. Name and designation of Officers
From the building side : Smt. Pukhraj meera. (Teacher)
9. Year of Construction : Ground Floor (Asbestos Sheet)
10. Applicant's letter No : NIL

50-20/2-00 3902

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	15 MBS	15MBS	MIR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits		NA	
	• Number of staircase			
	➤ Upper Floors			
	➤ Basements			
	• Width of Staircases		NA	
	➤ Upper Floors			
	➤ Basements			
	• Protection of exits		NA	
	➤ Fire check door			
	➤ Pressurization			
	• No. of continuous staircases to terrace		NA	
	• Width of Corridor			
	• Door Size			


3	Compartmentation			NA
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 			
4	Smoke Management System			NA
	<ul style="list-style-type: none"> • Basements • Upper Floors 	30 a/c Per hour		
		12 a/c Per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	1 Ext 300 m ²	2 NOS	MIR
		ISI mark	2 ABC	MIR
			YES	YES.
6	Firs-Aid Hose Reels			NA
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	30 m		
		5mm		
7	Automatic Fire detection and alarming system			NA
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 			
8	MOEFA			NA
9	Public Address System			NA
10	Automatic Sprinkler System			NA
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			NA
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants			NA
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 			

13	Pumping Arrangements	NA
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Number of main pump ➤ Discharge of main pump ➤ Head of main pump ➤ Jockey pump out put ➤ Jockey pump Head ➤ Standby pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual ➤ Pump House Access 	
	<ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto starting /manual 	NA
14	Captive Water Storage for Fire Fighting	NA
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead tank capacity 	
15	Exit Signage	NA
16	Provision of Lifts	NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 	
17	Standby Power Supply	NA
18	Refuge Area	NA
	<ul style="list-style-type: none"> • Total Area • Location 	
19	Fire Control Room	NA
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery back up • Building Floor Plans 	

20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA
----	---	----	----	----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / issue shortcomings as noted at serial number.....



Signature of Inspecting Officer
Name : RAJAN WADEHRA
Designation: ASST. DIV. OFFICER