

No. F6/DFs/ms/school/2012/933

Dated : 14/03/12

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary Girls School** located at **Holambi Khurd, Delhi-110 082**, comprised of three blocks of ground floor only and less than 9 meters in height, have complied with the fire prevention and fire safety requirement in accordance with Director of Education circular dated 01.03.2001 and verified by the officer concerned of fire service on 27.02.2012 in the presence of Mrs Parul, Teacher and that the building/ premises is fit for occupancy class **Educational class** with effect from 14/03/12 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/03/12 at New Delhi by



Director

Delhi Fire Service



Mrs. Santosh Dahiya, Principal,
M.C. Primary Girls School,
Holambi Khurd, Delhi-110 082.

Copy to :

The Director,
Dte. Of Education,
MED, Delhi.
Civic Centre

Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

May kindly see the letter No. Nil dated 15.12.2011 received from Municipal Corporation Primary Girls School, Holambi Khurd, Delhi-110 082 from fire safety point of view. Premises was inspected by the ADO (Bawana) on 27.02.2012 & observed that the building is comprised of three blocks of ground floor only having plot area 500 sq meters approximately and covered area is 217.55 sq. meters.

The point wise compliance of the safety recommendations as per the Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010 are given below:

INSPECTION REPORT

1. Name & address of the building : M.C. Primary Girls School, Holambi Khurd, Delhi-82
2. Type of Occupancy : School (G.F only)
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No. : F-16/Estate/Fire Safety/CC/2011/3298-3398 dt. 1.3.2011
6. Date of inspection : 27/02/2012
7. Name of the Inspecting Officers : Shri Rajmed Kholker, ADO
8. Name and designation of officers From the building side : Mrs. Parul, Teacher
9. Year of Construction : 1980-1984
10. Applicant's letter No. : MIL dt. 15.12.2011

NW-2012-003909

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	5 Meters	6 Meters	-
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	.	.	.
	• Upper Floors	-	-	-
	• Basement	-	-	-
b.	Width of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basement	-	-	-
c.	Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-

	d. No. of continuous staircases to terrace	-	-	-
	e. Width of Corridor	-	-	-
	f. Door size	100 Cms	100 Cms	MR
3.	Compartmentation.	NA		
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System.	NA		
	• Basements	-	-	-
	• Upper floors	-	-	-
5.	Fire Extinguishers	Provided		
	• Total numbers	ISI marked	Two	MR
	• Types		ABC Type	-u-
	• IS marking		ISI marked	-u-
6.	First-Aid Hose Rees.	NA		
	• Total numbers on each floor	_____	-	-
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7.	Automatic fire detection and alarming system.	NA		
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooter's Location	-	-	-

8.	MOEFA	-	-	-
9.	Public Address System.	Required	Provided	M R
10.	Automatic Sprinkler system		NA	
	• Basement	-	-	-
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants		NA	
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants.		NA	
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements.		NA	
	Ground Level			
	➤ Discharge of main pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby pump out put	-	-	-
	➤ Standby pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
	➤ Pump Hose Access	-	-	-
	Terrace level			
	➤ Discharge of pump	-	-	-
	➤ Head of the pump	-	-	-
	➤ Power supply	-	-	-
	➤ Auto Starting of pump	-	-	-

14.	Captive Water Storage for fire fighting.		NA	
	Underground tank capacity	-	-	-
	➤ Draw -off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	➤ Overhead Tank Capacity	-	-	-
15	Exit Signage.	Required	Provided	NA
16.	Provision of Lifts		NA	
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17.	Standby power supply		NA	
18.	Refuge Area		NA	
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19.	Fire Control Room		NA	
	➤ Detector System Panel	-	-	-
	➤ Flow Switch Panel	-	-	-
	➤ PA system Panel	-	-	-
	➤ Batter backup	-	-	-
	➤ Building Floor plans	-	-	-
20.	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

- ✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.
- ✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....



Signature of the Inspection Officer

Signature of the Inspection Officer

Name

SHRI RAJMAL KHORHAR

Name

Designation

ASST. DIV. OFFICER

Disignation