

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. *F6/DFS/MS/School/2012/970*

Dated: *16/03/12*

FIRE SAFETY CERTIFICATE

Certified that the Delhi Police Public School, PTS Campus, Wazirabad, Delhi-94. Comprised of ground floor was granted NOC by this department vide letter No.F.6/DFS/MS/2008/1970 dated 15.07.08. The premises was re-inspected by the officer concerned of this department on 01.02.12 in the presence of Mrs. Preety Batra, Incharge of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education on dated 01.03.11 and that the building is fit for occupancy class B "Educational Building" with effect from *.16/03/12*. Renewed for a period of three years, subject to conditions printed overleaf.

Issued on... *16/03/12* at New Delhi by

[Signature]
15/3
Chief Fire Officer
For Director
Delhi Fire Service

To,
Delhi Police Public School,
PTS Campus, Wazirabad, Delhi-94

Copy to:-
The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.

OC
[Signature]
15/3/12

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Delhi Police Public School, PDS
 2. Type of Occupancy : Educational Campus Wagre. Bad Delh-44
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. F-6/DFS/MS/2008/1970 Dated: 15.7.08
 5. Fire Safety directives letter No : F-16/Estete/cci Fire Safety/2011/3298 to 3398
 6. Date of inspection : 12.2012
 7. Name of the Inspecting Officers : ADD Suresh Singh
 8. Name and designation of officers from the building side : Mrs Preety Batra
 9. Year of Construction : 2004
 10. Applicant's letter No. : DPPS/OS dated 5.1.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 M	6 M	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	1.5 M	1.80 M	MR
	h. Door Size	1 M	1 M	MR

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			provided	
4	Smoke Management System.		N/A		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour			
5	Fire Extinguishers		Required		
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	8 No	8 No	MIR	
			CO2 + ABC	MIR	
		ISI marked	ISI	MR	
6	First-Aid Hose Reels.		N/A		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm			
7	Automatic fire detection and alarming system.		N/A		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA		N/A		
9	Public Address System.			Yes	
10	Automatic Sprinkler System.		N/A		
	<ul style="list-style-type: none"> • Basement 				

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants	N/A		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	—	—	—
12	Yard Hydrants.	N/A		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	—	—	—
13	Pumping Arrangements.	N/A		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14	Captive Water Storage for fire fighting.	N/A		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	—	—	—

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	NIA		
16	Provision of Lifts.	NIA		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	NIA		
18	Refuge Area.	NIA		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room	NIA		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIA		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the D-Fire Service Rules 2010/ issue shortcomings as noted at serial numbers

Singh

Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ADO*

Signature of the Inspecting Officer

Name

Designation