

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**


**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

No *F6/0 F-2/MS/school/2012/775* Dated *05/03/12*

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Girls, Secondary School Mayur Vihar, Ph – 1, Pkt - IV Delhi. Comprises of ground & First floor with 28 rooms have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education GNCTD and verified by the officer concerned of this department on 9-2-2012 in the presence of the Principal, and that the building is fit for occupancy, class B “Educational Building” with effect from *5-3* - 2012 for a period of three years, subject to conditions printed overleaf.

Issued on *05/03/12* at New Delhi

  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Prinicpal  
Govt. Girls, Secondary School  
Mayur Vihar, Ph-1, Pkt-IV, Delhi.
2. The Director Education,  
MCD, Civic Centre  
Jawahar Lal Nehru Marg, New Delhi.
3. The Principal  
Govt Boys Secondary School  
Mayur Vihar, Ph-1, Pkt-IV, Delhi.

*9/2*

*2/3/12*

### Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building : Govt. Girls/Boys Sr. Sec. School, Pkt-IV, Mansarovar Vihar Ph-II, Delhi
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. N.A. Dated: —
5. Fire Safety directives letter No : N.A.
6. Date of inspection : 9.2.12
7. Name of the Inspecting Officers : Guramkh Singh
8. Name and designation of officers from the building side : Principal
9. Year of Construction : 1994
10. Applicant's letter No. : GGSSS/Pkt-IV/mv-1/2012/14 dt-19/1/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>6.0 mtr.</u>	<u>MR</u>
	• Gate width	<u>4.5 mtr.</u>	<u>4.5 mtr.</u>	<u>MR</u>
	• Width of internal road	<u>—</u>	<u>—</u>	
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	<u>2 NOS.</u>	<u>03 NOS.</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>NA</u>	
	b. Width of staircases			
	• Upper Floors	<u>1.5 mtr.</u>	<u>1.45 mtr Each.</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>—</u>
	c. Protection of exits			
	• Fire check door	<u>NA</u>	<u>NA</u>	<u>—</u>
	• Pressurization	<u>NA</u>	<u>NA</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>—</u>	<u>03 NOS.</u>	<u>— MR</u>
	g. Width of Corridor	<u>1.5 mtr.</u>	<u>1.5 mtr.</u>	<u>MR</u>
	h. Door Size	<u>1.0 mtr.</u>	<u>1.0 mtr.</u>	<u>MR</u>

3	<b>Compartmentation.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	/	/	
4	<b>Smoke Management System.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour /	/	
5	<b>Fire Extinguishers</b>	06 Nos.	18 Nos.	MR
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	ABC & CO <sub>2</sub> ISI marked	ABC, CO <sub>2</sub> & DCP. YES	MR MR
6	<b>First-Aid Hose Reels.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm /	/	
7	<b>Automatic fire detection and alarming system.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	/	/	
8	<b>MOEFA</b>	NA	NA	
9	<b>Public Address System.</b>	NA	NA	
10	<b>Automatic Sprinkler System.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	/	/	

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	/	/	
11	<b>Internal Hydrants</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	/	/	
12	<b>Yard Hydrants.</b>	N.A.	N.A.	
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	/	/	
13	<b>Pumping Arrangements.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	/	/	/
14	<b>Captive Water Storage for fire fighting.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>	/	/	/

-N/5-

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	/	/	
15	Exit Signage.	NA	NA	
16	Provision of Lifts.	NA	NA	
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	/	/	
17	Standby power supply	NA	NA	
18	Refuge Area.	NA	NA	
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	/	/	
19	Fire Control Room	NA	NA	
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	/	/	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers guidelines issued by Director Education G.H.C.D.

- H/6 -


(113)

Guramkh  
21/2/12

Signature of the Inspecting Officer


Name Guramkh Singh

Designation ADO (LH).



Signature of the Inspecting Officer

Name



Designation