

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI -- 110001

No: F 6/DFS/MS/2012/ School/856

Dated:- 07/03/12

FIRE SAFETY CERTIFICATE

Certified that the Mata Sunder Kaur Public School (Recognised)
located at 1631-32 Sohan Sang near Kothapur Road
Delhi 110007 comprised of Ground floor with 8 classrooms only at ground floor occupied
by Mata Sunder Kaur Public School was issued NOC vide this office letter
No. F-6/MS/DFS/2006/3176 Dated: 26/10/2006 The premises was re-inspected by the
officer concerned of this department on 2-8/2/12 and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement under Rule 33
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class
Educational with effect from 07/03/12 for a period of
03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 07/03/12 at New Delhi.


6/3

Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal
Mata Sunder Kaur Public School
1631-32 Sohan Sang
Near Kothapur Rd. Delhi 7.
2. The Addl. Director Edu. (MCD)
Nigam Bhawan, old Hindu
College Bldg. Kashmere Gate
Delhi 110006.



INSPECTION REPORT

1. Name & address of the building : Mata Seemla Kaur Public School, 1631-32, Soham Colony, Delhi
2. Type of Occupancy : Group B-1, Educational Building
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No F-6/MS/DFS/2006/3176 Dated: 26-10-2006
5. Fire Safety directives letter No : F-16/2stale/cc/fire safety/2011/3298-3398 dt. 1-3-2011
6. Date of inspection : 12-9-2011
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Chairman - Sh. Indez Pal Singh
9. Year of Construction : 1970 (old building) (G+1)
10. Applicant's letter No. : Nil / 24-7-2011


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	3.0 mts.	N/M/R
	• Gate width	~	3 Nos - 1 m.	~
	• Width of internal road	~	Nil	~
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	one	NMR
	• Upper Floors	Two	one	~
	• Basements	Nil	Nil	Nil
	b. Width of staircases	1.50 m	1.20 m	~
	• Upper Floors	1.50 m	one 1.20	~
	• Basements	Nil	Nil	~
	c. Protection of exits			
	• Fire check door	~	~	~
	• Pressurization	~	~	~
	e. No. of continuous staircases to terrace	~	~	~
	g. Width of Corridor	~	Nil	~
	h. Door Size	1 m	2 m x 1 m.	~

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	stairs/corridor	NIL	NMR
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		N/A	
18	Refuge Area.	N/A		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:		NIL	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers 1, 2, 5, 15.....

D.O. (NW)


 ADO
 13/9/2011

(5)

Signature of the Inspecting Officer

Name

Designation

Shyam Lal

Signature of the Inspecting Officer

Name *SHYAM LAL*

Designation *Asstt. Divn. Officer.*