

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001


No: F.6/DFS/MS/2011/ school/ 870

Dated : 09/03/12

FIRE SAFETY CERTIFICATE

Certified that the – **Ramjas Primary School**, Anand Parbat, New Delhi-110005
Comprised of - ground floor only, owned/occupied by Ramjas Foundation, New Delhi
has complied with the fire prevention and fire safety requirements in accordance with the
Director of Education letter No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated
01.03.2011 and verified by the officer concerned of fire Service on 17.02.12 in the
presence of - Smt. Sunita Dinngra Principal and that the building/premises is fit for
occupancy class – group-B (educational) with effect from the date of issue of this
certificate for a period of - three years in accordance with rule 36 unless renewed under
rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions
under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on09/03/12.....at New Delhi.


Chief Fire Officer
For Director
Delhi Fire Service

slc
mw

Copy to:

1. The Principal,
Ramjas Primary School, Anand Parbat,
New Delhi-110005.
2. The Director of Education
MCD Nigam Bhawan(Old Hindu Collage Bldg)
Kashmere Gate, Delhi.
3. Divisional Officer (South West)
Shanker Road Fire Station, New Delhi

Gf

INSPECTION REPORT

1. Name & address of the building : Ranjana Primary School, Anand Parbat N.O.S.
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NIL Dated: _____
5. Fire Safety directives letter No : NIL
6. Date of inspection : 17/02/12
7. Name of the Inspecting Officers : D.O. H.L. ANEJA
8. Name and designation of officers from the building side : Sh. Bijender Singh (Chokidas)
9. Year of Construction : _____
10. Applicant's letter No. : NIL dt 23.9.11. L 20.1.12.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	9mtr	MR
	• Gate width	R	3.75mtr	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NR	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	—	—	—

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NR			
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	NR	30 a/c per hour		
			12 a/c per hour		
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	R	P	MR	
			4 N100		
		ISI marked	ABE type		
			yes		
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NR			
			30 m		
			5 mm		
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NR			
8	MOEFA				
		NR			
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement 	NR			

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants	NR		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	—	—	—
12	Yard Hydrants.	NR		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	—	—	—
13	Pumping Arrangements.	NR		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14	Captive Water Storage for fire fighting.	NR		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	—	—	—

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15	Exit Signage.	NR	—	—
16	Provision of Lifts.	NR	—	—
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	NR	—	—
18	Refuge Area.	NR	—	—
	➤ Total Area	NR	—	—
	➤ Location	—	—	—
19	Fire Control Room	NR	—	—
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~ NR

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name H. L. ANETA

Designation Div. Officer

5