

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No. F6/DFS/MS/school/2012/941

Dated: 15/03/12

FIRE SAFETY CERTIFICATE

Certified that the **Shiksha Bharati Educational Society** at Shiksha Bharti Public School, Sec-7, Dwarka, New Delhi-110075 comprised of basement, ground floor plus two upper floors, having total 120 Rooms (Including Class Rooms, Sci. Lab, Comp. Lab, Math Lab, Library, Sports Room, Examination Room, Staff Room, Multipurpose Hall, Hostel, Kitchen, Office & Store etc.). Above school was issued NOC vide this office letter No.F.6/DFS/MS/2009/42 dated 06.01.2009 owned/ occupied by Management of Shiksha Bharati Educational Society above said school have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 06.03.2012 in the presence of School Principal Smt. Mamta Gupta. The building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....15/03/12..... at New Delhi.


CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE

etc
mkl

Copy to:-

1. The Treasurer,
Shiksha Bharati Educational Society
Shiksha Bharati Public School,
Sec-7, Dwarka, New Delhi-110075.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110 054

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT Shiksha Bharati Educational Society at

1. Name & address of the building : Shiksha Bharati Public School, Sec-7, Dwarka, N.D-75.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/ms/09/42 Date 06.01.2009
5. Fire Safety directives letter No : N/A
6. Date of inspection : 06.03.2012
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Smt. Mamta Gupta (Principal)
9. Year of Construction : Before 2009.
10. Applicant's letter No. : Nil dated 12.01.2012


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible - - 	<ul style="list-style-type: none"> 09 mtr 4.50 mtr - 	<ul style="list-style-type: none"> MR MR -
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	Ten	MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 	-	Six	MR
	b. Width of staircases	-	Four	MR
	<ul style="list-style-type: none"> • Upper Floor • Basements 	-	92cms to 146cms	MR
	c. Protection of exits	-	86cms to 162 cms	MR
	<ul style="list-style-type: none"> • Fire check door • pressurization 	N/A	-	-
	d. No. of continuous staircases to terrace	N/A	-	-
	e. Width of Corridor	-	Four	-
	f. Door Size	-	260cms	-
		-	94cms x 110cms	MR, Being Old Case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> N/A - N/A N/A N/A 	<ul style="list-style-type: none"> - Sealed - - - 	<ul style="list-style-type: none"> - - - - -
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	<ul style="list-style-type: none"> Exhaust Fans are Provided Natural Ventilation 	<ul style="list-style-type: none"> MR MR

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	Eight at each floor	Provided	MR
	• Types	A.B.C, D.C.P, Co ₂	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Three	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G Set of 125 KVA	-
	• Hooters' Location	-	-	-
8.	MOEFA		Not Required	Provided MR
9.	Public Address System		Required	Provided MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100m.m	-
	• Number of hydrants per floor	-	Three	-
	• Hose Box	-	Three	-
12.	Yard Hydrants			
	• Total number of hydrants	-	One	-
	• Hose Box	-	One	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	-	-
		450 LPM	450 LPM, 180 LPM, 180 LPM	MR
		30 M	30 M Each	MR
		-	-	-
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	-	-
		N/A	-	-
		N/A	Provided	-
		N/A	-	-
		-	12500 ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	-do-
		-	-	-do-
		-	-	-do-
		-	-	-do-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		N/A	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		-	Provided	-
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{Renewal} grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~



Signature of Inspecting Officer

Name P. S. Dahiya

Designation Asstt. Divisional Officer.

Signature of Inspecting Officer

Name

Designation