

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F6/DFS/MS/ *school/2012/982*

Dated: *19/03/2012*

FIRE SAFETY CERTIFICATE

Certified that Zayed Public School for Girls at B-112, Kalindi Kunj Road, Street No: 7, Shaheen Bagh, Jamia Nagar, Okhla, New Delhi, comprised of basement, ground plus three upper floors **Owned/Occupied by** Zayed Public School for Girls has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire Service on 21/02/2012 in the presence of Mohd. Talha, Manager of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from *19/03/12* for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on *19/03/12* at New Delhi by



Director

Delhi Fire Service

d/c

Copy To: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.
2. The Manager, Zayed Public school For Girls,
B-112, Kalindi Kunj Road, Street No: 7, Shaheen Bagh, Jamia Nagar Okhla New Delhi.

Conditions for the validity of fire safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building: ZAYED PUBLIC SCHOOL FOR GIRLS
Sheheen Bagh, Jamaia Nagar, Okla, N. Delhi.
2. Type of Occupancy: EDUCATIONAL
3. Type of Case: NEW
4. Details of previous NOC Shortcoming conveyed vide letter NO-FG/DFS/MS/2010/1136
5. Fire Safety directives letter No: _____ Dated: dt- 20-4-10
6. Date of Inspection: 21-2-12
7. Name of the Inspecting Officers: Rajan Kladhra
8. Name and designation of Officers: MOHD TALHA (Manager)
- From the building side: _____
9. Year of Construction: Basement + G + three upper floors
10. Applicant's letter No: R.M/128/11-12 dt 19/12/2011

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	15mb	15mb	M/R
	• Gate width	N/A	N/A	NA
	• Width of internal road	N/A	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	• Number of staircase			
	➤ Upper Floors	2	3	M/R
	➤ Basements	2	2	M/R
	• Width of Staircases			
	➤ Upper Floors	1.5mb	1.5mb	M/R
	➤ Basements	1.5mb	1.5mb	M/R
	• Protection of exits		N/A	
	➤ Fire check door	/	/	
	➤ Pressurization	/	/	
	• No. of continuous staircases to terrace	1	1	M/R
	• Width of Corridor	/	/	
	• Door Size	/	/	

3	Compartmentation	N A		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	/ / /		
4	Smoke Management System	N A		
	<ul style="list-style-type: none"> • Basements 	30 a/c Per hour	/ /	
	<ul style="list-style-type: none"> • Upper Floors 	12 a/c Per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number 	1 Per 300 sqm	16 Nos	MIR
	<ul style="list-style-type: none"> • Types 	ISI mark	8 CO2 8 ABC	MIR
	<ul style="list-style-type: none"> • IS marking 		Key	MIR
6	Firs-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total Number on each floor 	1	1	MIR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	30 m	MIR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	5mm	MIR
7	Automatic Fire detection and alarming system	N A		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 	/ / /		
8	MOEFA	Provided		MIR
9	Public Address System	Provided		MIR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	Required	Provided	MIR
	<ul style="list-style-type: none"> • Upper Floor 	N A	N A	N A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N A	N A	N A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 	/ / /		
12	Yard Hydrants	N A		
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 	/ / /		

13	Pumping Arrangements	NA		
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Number of main pump ➤ Discharge of main pump ➤ Head of main pump ➤ Jockey pump out put ➤ Jockey pump Head ➤ Standby pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto starting /manual 			
		900 LPM	900 LPM	MIR
		40 mH	40 mH	MIR
		125 kVA	125 kVA	MIR
		Auto	Auto	Auto
14	Captive Water Storage for Fire Fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MIR
		15,000 L	15,000 L	MIR
15	Exit Signage	Provided		
16	Provision of Lifts	NA		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 			
17	Standby Power Supply	125 kVA	125 kVA	MIR
18	Refuge Area	NA		
	<ul style="list-style-type: none"> Total Area Location 			
19	Fire Control Room	NA		
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery back up Building Floor Plans 			

20	Special Fire Protection System for Protection of special risk, if any	4 ABC Fire ext.	4 ABC Fire ext.	M/R
----	---	-----------------	-----------------	-----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted~~ at serial number.....



Signature of Inspecting Officer

Name : RAJAN WADHAVANI

Designation: Asst. Divisional Officer

DO (MST)