

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2012 / ६५/१०७९

Dated 23 / 03 / 12

FIRE SAFETY CERTIFICATE

Certified that the @ Live Restaurant, Located at K-12, Outer Circle Connaught Place, New Delhi was granted NOC by this department vide letter No F6/MS/DFS/EH/2009/ 963 dated 09.04.2009. The premises was re-inspected by the officer concerned of this department on 12.03.2012 in the presence of Mr. Sunil Tikoo and found that the Restaurant have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D Assembly Building of with effect from 23/03/12.. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 23/03/12..... at New Delhi by.


Chief Fire Officer
For Director
Delhi Fire Service
ofc
men

Copy to: -

- 1) The Medical Officer of Health, N.D.M.C., Health Deptt, Palika Kendra, New Delhi
- 2) The Manager, Live Restaurant, K-12, Outer Circle Connaught Place, New Delhi

Conditions for the validity of fire safety certificate

- 1) All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2) Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5) The basement shall be used as per the provisions of BBL.
- 6) The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECITON REPORT

1. Name & address of the building: @ Live Restaurant, Located at K-12, Outer Circle
Connaught Place, New Delhi
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/DFS/MS/EH/2009/963 Dated 09.04.2009
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 12.03.2012
7. Name of the Inspecting Officer : ADO D.S. Yadav, DO Atul Garg
8. Name and designation of Officer
from the building side : Mr. Sunil Tikoo
9. Year of Construction : N/A
10. Applicant's letter No. : Nil Dated 30.01.2012

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A	12 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	01	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	01 mtr	01 mtr	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A

	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.5	1.5	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	YES	MR
5.	Fire Extinguishers			
	• Total numbers		06	MR
	• Types		CO ₂ , WT, DCP	MR
	• IS marking		YES	MR
		ISI marked		
6.	First – Aid Hose Reels			
	• Total numbers on each floor	-	01	MR
	• Length of hose reel hose	30 m	YES	MR
	• Nozzle diameter	5 mm	YES	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	YES	YES	MR
9.	Public Address System	YES	YES	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	YES	YES	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			

	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> • Discharge of main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Staring/Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 Lpm 180 Lpm	YES	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	30 M	30 M	MR
	<ul style="list-style-type: none"> ➤ Power supply 	YES	YES	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	YES	YES	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw of connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Overhead Tank capacity 	5000 L	5000 L	MR
15	Exit Signage	YES	YES	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Lift Signage 	N/A	N/A	N/A
17.	Standby power supply	YES	YES	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Building Floor Plans 	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

@ Live Restaurant

OLD CASE

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

ATUL GARI

Name

Dharmvir Singh Yadav

Designation

DD

Designation

A-DO (Central)