

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001


No. F6/MS/DFS/GH/2012/ 1111

Dated: 28/03/12

FIRE SAFETY CERTIFICATE

Certified that the Delhi Darshan Guest House located at 8230/6, Arakashan Road Road, Pahar Ganj, New Delhi-110055 comprised of ground floor (reception + office), 1st floor (04 guest rooms), 2nd floor (04 guest rooms) 3rd floor (04 guest rooms), 4th floor (04 guest rooms) Total 16 guest rooms and terrace floor having 01 staff room plus 01 store room & kitchen is sealed by MCD was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/164 dated 20-01-2009. The premises was re-inspected by the officer concerned of this department on 15-03-2012 in the presence of Sh. Nem Singh, Manager and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 16 guest rooms with effect from ..28/03/.....2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 28/03/12 at New Delhi by.


CHIEF FIRE OFFICER
FOR DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi – 110049
2. Shri Narendra Chawla, M/s. Delhi Darshan Guest House, 8230/6, Arakashan Road, Pahar Ganj, New Delhi-110055

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

Delhi Darshan Guest House,

1. Name & address of the building : 8230/6, Azakashan Road, Park Garden, New Delhi-110055
2. Type of Occupancy : Residential (Guest house)
3. Type of Case : ~~New Case~~/ Renewal
4. Details of previous NOC : Letter No. F6/DFS/M.S/G.H/2009/164 Dated: 20-01-09
5. Fire Safety directives letter No : - N.A -
6. Date of inspection : 15-03-2012
7. Name of the Inspecting Officers : Dharm Vir Singh Yadav. (A.D.O)
8. Name and designation of officers from the building side : Shri Nem Singh, manager
9. Year of Construction : 2006 (starting year)
10. Applicant's letter No. : NIL. old case

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<i>circular</i> NBC G.M. Requirement <i>P.S. Area</i>	Provided at site	Remarks MR/NMR <i>P.S. Area</i>
1	Access to building			
	• Road width	<u>Accessible</u>	<u>06 mtrs</u>	<u>M.R</u>
	• Gate width	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
	• Width of internal road	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>—</u>	<u>one</u>	<u>M.R</u>
	• Basements	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
	b. Width of staircases			
	• Upper Floors	<u>90 cms</u>	<u>90 cms to 114 cms</u>	<u>M.R</u>
	• Basements	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
	c. Protection of exits			
	• Fire check door	<u>- N.A</u>	<u>—</u>	
	• Pressurization			
	e. No. of continuous staircases to terrace	<u>—</u>	<u>one</u>	<u>M.R</u>
	g. Width of Corridor	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
	h. Door Size	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>

contd.:-

Delhi Darshan Guest House
 8230/6, Akashan Road,
 Park Garden, New Delhi-110055.

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.A.		
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	- N.A - Natural ventilation	- N.A - N.A.
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	- - ISI marked	Eight coz type and A.B.C type yes.	M.R. M.R. M.R.
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one yes yes	M.R. M.R. M.R.
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N.A.		
8	MOEFA	Required	provided	M.R
9	Public Address System.	- " -	- " -	- " -
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N.A.		

contd: -

Delhi Darshan
 8230/6, Akashan Road,
 Park Grand, New Delhi-110055

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	N.A		
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N.A		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N.A		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N.A		
		450 LPM	450 LPM	M.R.
		30 mtrs	30 mtrs	M.R.
		Electric	Electric	M.R.
		N.A	N.A	N.A
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	N.A		

contd: -

Delhi Darshan Guest House,
8230/6, Akashan Road,
Pahar Ganj, New Delhi-110055.

old case
PSS Area

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<p>—</p> <p>—</p> <p>2500 litres</p>	<p>Provided</p> <p>Provided</p> <p>2500 litres</p>	<p>M.R</p> <p>M.R.</p> <p>M.R</p>
15	Exit Signage.	Required	Provided	M.R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	<p>N.A</p> <p>—</p>		
17	Standby power supply	—	D.G. set 12.5KVA	M.R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	<p>N.A</p> <p>—</p>		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	<p>N.A</p> <p>—</p>		
20	Special Fire Protection Systems for Protection of special Risks, if any:	<p>N.A</p> <p>—</p>		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

contd: -

Delhi Darshan Guest House,
8230/6, Akashan Road,
Pahar Ganj, New Delhi-110055.

(5)

~~Signature of the Inspecting Officer~~

Name

Designation

Yadav
15-03-12
Signature of the Inspecting Officer

Name *Dharm veer Singh Yadav*

Designation *Assistant Divisional*