

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

NO. F6/DFS/MS/2012/1127

DATED: 28/03/12

FIRE SAFETY CERTIFICATE

Certified that the Industrial building at Plot no.254, FIE Patparganj, Delhi 92, owned/occupied by Sh. Amrish Kumar Goel, comprising of basement, ground plus two upper floors was granted NOC vide letter no. No.F.6/(J)/DFS/2008/149 dated 11.03.2008. The industrial building was inspected by the officer concerned of this department on 12.03.12 in the presence of Sh. Amrish Kumar Goel and found that the industrial building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group G "Industrial Building" with effect from 28/03/12 for a period of three years, subject to conditions printed overleaf.

Issued on 28/03/12 at New Delhi by



Chief Fire Officer  
Delhi Fire Service  
de

Sh. Amrish Kumar Goel  
Plot no.254, FIE Patparganj,  
Delhi-92.

Copy to:-

Joint Director (Bldg) Comml.  
DDA Building Department  
Vikas Sadan, New Delhi.

## INSPECTION REPORT

1. Name & address of the building: Plot No.254, FIE, Patparganj, Delhi -92.
2. Building is comprised of : Basement, Ground + 2, upper floors.
3. Type of Occupancy : Industrial
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/(J)/DFS/2008/149 Dated 11/03/2008
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 12.03.12
8. Name of the Inspecting officers: DO Virendra Singh,
9. Name and designation of Officer:  
from the building side : Shri.Amrish Kumar Goyal
10. Year of Construction - : 1998
11. Applicant's letter No : Nil

NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC(Old) Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	6 Mtrs	15 Mtrs.	MR
	• Gate width	-----	-----	-----
	• Width of internal road	-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	1 No.	1 No.	MR
	• Upper Floor	1 No	1 No.	MR
	• Basement	2 nos,	2.nos.	MR
	B. Width of Staircases	1.25 M	1.30 M	MR
	• Upper Floor	1.25 M	1.30 M	MR
	• Basement	1.25 M	1.30 M	MR
	c. Protection of exits			
	• Fire check door	-----	-----	-----
	• Pressurization	-----	-----	-----
	e. No. of continuous staircases to terrace	1 No.	1No.	MR
	g. Width of Corridor	-----	-----	-----
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			

	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	-----	-----	-----
		-----	-----	-----
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• types</li> </ul>	09 Nos. ABC & Co2	10 Nos. ABC & Co2	MR MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1no.	1 no.	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	Provided Provided	MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of main panel</li> <li>• Location of repeater panel</li> <li>• Alternate source of power</li> </ul>	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
	<ul style="list-style-type: none"> <li>• Hooter's location</li> </ul>	-----	-----	----
8	MOEFA	Required	Provided	MR
9	Public address System.	-----	-----	-----
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• upper floor</li> <li>• sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		-----	-----	-----
		-----	-----	-----
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	100 MM 1 NO. 1 NO.	Provided Provided Provided	MR MR MR



12	Yard Hydrants.			
	• Total number of hydrants	Not Required	Not Provided	MR
	• Hose Box	-----	-----	-----
13	Pumping Arrangements.			
	• Ground Level	-----	-----	-----
	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----
	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----
	➤ Auto Starting /Manual stopping	-----	-----	-----
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	2 Nos.450 LPM	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	-----	-----	-----
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 Ltrs.	15,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	-----	-----	-----
18	Refuge Area.	-----	-----	-----
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room	-----	-----	-----
	• Detector system panel	-----	-----	-----

	<ul style="list-style-type: none"> <li>• Flow switch panel</li> </ul>	-----	-----	-----
	<ul style="list-style-type: none"> <li>• PA system panel</li> </ul>	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Battery backup</li> </ul>	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Dy CPO

*[Handwritten Signature]*  
26/12

*[Handwritten Signature]*  
26/12  
Signature of the Inspecting Officer  
Name **VIRENDRA SINGH**  
Designation **DO (E)**