

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001


No: F 6/DFS/MS/2011/ 1070

Dated:- 23/03/12

FIRE SAFETY CERTIFICATE

Certified that the Maldisram Products Pvt. Ltd. Premise No. S.A. 6, 7 of
D. Mall, Sec-10, Rohini, Delhi comprised of Ground + mezzanine
floor only owned/occupied by M/s. Maldisram
Products Pvt. Ltd. complied with the fire prevention and fire
safety requirement in accordance with rule 33 of the Delhi Fire Service Rule 2010 and verified
by the officer concerned of Fire Service on 23.9.11 at 7.3.12 in the presence of
Mr. A. Vasthi and that the building/premises is fit for occupancy
Restaurant (Assembly) building with effect from 23/03/12 for a period of
3 yrs. in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 23/03/12 at New Delhi.



Chief Fire Officer
For Director
Delhi Fire Service
Jc
ml

Copy to:-

1. M/s. Maldisram Products Pvt Ltd.
2034, Kalsia, Gurgaon, Gurgaon,
Chandni Chowk, Delhi.

2. Dy. Health Officer,
M.G.D. Health Dept. Rohini Zone,
Sector-V, Rohini, Delhi.

Note:-Guidelines overleaf may also be taken care of.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Haldiram Products Pvt Ltd, SA. 6, 7, 'B' mall. Sec-10, Rohini, Delhi.
2. Type of Occupancy : Restaurant (Assembly Bldg sub D-V D-5)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. nil Dated:
5. Fire Safety directives letter No : nil
6. Date of inspection : 23.9.11
7. Name of the Inspecting Officers : DO Jipin Iental
8. Name and designation of officers from the building side : (i) Mr. Junesa (ii) Mr. Chandni Aggarwal Sr. Manager
9. Year of Construction :
10. Applicant's letter No. : DHO/R2/2011/330 dt-24.8.11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 mtr.	Provided	M/R
	• Gate width	-	No Gate provided	-
	• Width of internal road	6 mtr.	6 mtr provided	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two staircase 2 mtr width	Single staircase 1.36 mtr	NMR
	• Basements	- do -	- do -	
	b. Width of staircases			
	• Upper Floors		1.36 mtr	NMR
	• Basements		- do -	
	c. Protection of exits			
	• Fire check door	Required	Provided over	
	• Pressurization	NOC already issued to 'B' mall	At exit case. Required towards common area.	NMR
	e. No. of continuous staircases to terrace		136 cm	NMR
	g. Width of Corridor		7130 cm	
	h. Door Size	1.50 mtr 2 mtr	(i) 2.08 mtr (ii) 2.00 mtr (iii) 1.04 mtr	

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	required	provided except door of rest leading to common area. P 1 hr N.P. N.P.	N/MR
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	P N.P.	N/MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	4 + 1 ABC - 2 kg (2 No) ABC - 5 kg (2 No) CO2 - 4.5 kg (1 No) yes.	
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	one in common area yes.	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		smoke detector. Basement - inside common area on 4 th Provided in common area.	already issued noc to D.M.A.
8	MOEFA	required	provided on mezz floor & common area on G.F.	N/MR. Required on Exit in rest
9	Public Address System.	N.P.	provided.	-
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	Required.	provided & com mon with D.M.A. provided with D.M.A.	M/R.

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 		<p>Provided on GF + me3 floor sprinklers require to be taken above on me3 floor.</p>	N M R
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N.R	4"	-
		-do-	one in common area	-
			one -do-	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N.R	Two	-
		-do-	yes	-
13	Pumping Arrangements.		Common with 'D' main	
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		<p>Two Electric pumps usually one for hydrant + one for smaller 'D' main the base of stem etc. side was not known.</p> <p>Three.</p> <p>Two of 180 LPM each.</p> <p>As mentioned above 4500 LPM</p>	<p>system could n't be checked as no body present.</p>
			N.P	
14	Captive Water Storage for fire fighting.		Common on depth 'D' main.	
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 		-do-	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	<i>Required</i>	<i>Provided</i>	<i>MR</i>
16	Provision of Lifts.	<i>Provided in common areas only</i>		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		<i>Provided for entire D' mall</i>	
18	Refuge Area.	<i>Not required for Rest.</i>		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room	<i>Provided for entire D' mall Already issued NOC</i>		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:		<i>Kitchen DCP type fire Ext provided</i>	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers 2, 3, 4, 10, 13,

15

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

Ventur

VIPIN KENTAZ