

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No. F6/DFS/MS/EH/2012/1192

Dated: 02/04/12

FIRE SAFETY CERTIFICATE

Certified that the **Narangs International Hotels Pvt. Ltd. Unit:-The Ambassador's Sky Chef** located at **IGI Airport Complex, New Delhi-110037**. comprised of **Basement & Ground Floor** was granted NOC by this department vide letter No. **F6/DFS/MS/EH/2009/250** dated **29/01/09**. The premises was re-inspected by the officer concerned of this department on **14/03/12** in the presence of **Mr. M.P.Jaiswal** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group-D Assembly Building** with effect from -----
02/04/12-----for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire subject to conditions printed below

Issued 02/04/12 at New Delhi by.


Chief Fire Officer
For Director
Delhi Fire Service

- Copy to:- (1) Deputy Health Officer,
Municipal Corporation of Delhi,
Office of Dy. Health Officer, Najafgarh Zone, New Delhi-110043.
- (2) The Ambassador's Sky Chef
(Unit of Narangs International Hotels Pvt. Ltd.)
IGI Airport Complex, New Delhi-110037.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Narangs International Hotels Pvt. Ltd. Unit:- The Ambassador's Sky Chef, IGI Airport Complex, New Delhi-110037.
2. Type of occupancy:- Group-D Assembly Building.
3. Type of case:- Renewal
4. Details of previous NOC:-No. F6/DFS/MS/EH/2009/250 dated 29/01/09.
5. Fire safety directives No.- N/A
6. Date of inspection:- 14/03/12
7. Name of the inspecting officer:-A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. M.P. Jaiswal.
9. Year of construction:- 1983.
10. Applicant's letter No:-DHO/NG/2012/04 dated 03/01/12 , Basement & Ground Floor

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	15 Mtr. Provided	MR
	2) Gate width	Required	6 Mtr.	MR
	3) Width of internal road	Required	6 Mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases	Required	Provided	MR
	1. Upper floors	Required	2 Nos.	MR
	2. Basements	Required	2 Staircase	MR
	B. Width of staircase			
	1. Upper floors	Required	2.6 Mtr. <i>2.6m</i>	MR
	2. Basements	Required	1.6 Mtr. <i>2.6m</i>	MR
	C. Protection of exits	N/A	N/A <i>✓</i>	N/A
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	one	MR
	E. Width of corridor	Required	1.5 Mtr.	MR
	F. Door size	Required	1 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan provided	MR
	2) Upper floors	12 a/c per hour	Exhaust fan provided	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	50 Nos.	MR
	2) Types		ABC, W.Co2 Co2 & foam.	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	Four at each	MR

			floor	
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Smoke & Heat	MR
	2) Location of main panel	Required	Ground Floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Battery Backup	MR
	5) Hooter's Location	Required	At various location	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	100 cms.	MR
	2) Number of hydrants per floor	Required	9 Nos.	MR
	3) Hose box	Required	9 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	10 Nos.	MR
	2) Hose box	Required	10 Nos.	MR

13.	Pumping Arrangement			
	1) Ground level	Required	Provided	MR
	a) Discharge of main pump	Required	1800 LPM	MR
	b) Head of main pump	Required	56 Mtr.	MR
	c) Number of main pump	Required	2 Nos.	MR
	d) Jockey pump out put	Required	180 LPM	MR
	e) Jockey pump head	Required	56 Mtr.	MR
	f) Stand by pump output	Required	1800 LPM	MR
	g) Stand by pump head	Required	56 Mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	Required	1,50,000 Ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	Not required	Not provided	Not provided old case
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A

	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	D.G. Set Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	Required	In the Engineer room	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	In the Engineer room	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			Yes <i>cor local approval</i> <i>on LT Panel</i>

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DSA is put up pl

Signature of the inspecting officer

Signature of the inspecting officer

Name

Name

Designation

Designation

S. S. Kausluk

S. S. Kausluk

Asst Div-Officer