

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/Club/2012/1086

Dated: 27 / 03 / 2012

**FIRE SAFETY CERTIFICATE**

Certified that the **Pitampura Club located at H-4/5 Pitampura New Delhi.110034**, comprised of basement, ground floor & two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/818 dated 23-03-2009. The premises was re-inspected by the officers concerned of this department on **16.03.2012** in the presence of Mr. J.R. Mehandiratta (Manager) of the Club and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for Class D-1 (Assembly) occupancy with effect from 27/03/12..... for a period of three years subject to conditions printed below.

Issued on...27/03/12.....at New Delhi by



Chief Fire Officer  
Delhi Fire Service

Copy to:  
Mr. J.R. Mehandiratta (Manager)  
**Pitampura Club**  
H-4/5 Pitampura New Delhi.110034



Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

May Kindly peruse letter no. nil dated 27.02.2012 received from the Manager regarding issue of NOC r/o Pitampura Club located at H-4/5 Pitampura New Delhi.110034. This Club has already been issue NOC wide letter no. F6/DFS/MS/GH/2009/818 dated 23-03-2009. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : Pitampura Club located at H-4/5 Pitampura New Delhi.110034.
2. Type of Occupancy : Class D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2009/818 dated 23-03-2009
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 16.03.2012
7. Name of the Inspecting Officers : Division Officer Sunil Chowdhary
8. Name and designation of officers  
From the building side : Mr. J.R. Mehandiratta (Manager)
9. Year of Construction :
10. Applicant's letter No. : nil dated 27.02.2012

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	09mtrs	Provided	M/R
	• Gate width	5 mtr	Provided	M/R
	• Width of internal road	3 mtr	Provided	M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	Two	Provided	M/R
	• Upper Floors	Two	Provided	M/R
	• Basement	Two	Provided	M/R
	b. Width of staircases			

	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	1.5 mtr & 1.25 mtr	Provided	M/R
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	1.5 mtr & 1.25 mtr	Provided	M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Provided	M.R.
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	Two	Provided	M/R
	e. Width of Corridor	2 mtr	Provided	M.R
	f. Door size	2 mtr & 1.5 mtrs	Provided	M.R.
3.	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Provided	M.R.
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	No shafts	N/R	Not applicable
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	No shafts	N/R	Not applicable
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	Required	Provided	M.R.
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Provided	M.R
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	Required	Provided	M.R.
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	10	16	M.R
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC & CO2 type	Provided	M.R
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	yes	M.R
6.	<b>First-Aid Hose Rees.</b>			

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	one	one at each floor	M.R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m required	Provided	M.R
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	M.R
7.	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Heat & smoke	Provided	M.R
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Ground floor	Provided	M.R
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	each floor	Provided	M.R
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	M.R
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	All over	Provided	M.R
8.	<b>MOEFA</b>	Required	Provided	M.R
9.	<b>Public Address System.</b>	N.R.	N.R.	Not applicable
10.	<b>Automatic Sprinkler system</b>	Required	Provided	M.R
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	M.R
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	M.R
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	M.R
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150 mm	provided	M.R
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	1	provided	M.R
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	1	provided	M.R

<b>12.</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.R.	N.R.	Not applicable ✓
	• Hose Box	N.R.	N.R.	Not applicable ✓
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N.R.	N.R.	Not applicable ✓
	➤ Head of Main pump	N.R.	N.R.	Not applicable ✓
	➤ Number of main pumps	N.R.	N.R.	Not applicable ✓
	➤ Jockey Pump out put	N.R.	N.R.	Not applicable ✓
	➤ Jockey pump head	N.R.	N.R.	Not applicable ✓
	➤ Standby pump out put	N.R.	N.R.	Not applicable ✓
	➤ Standby pump Head	N.R.	N.R.	Not applicable ✓
	➤ Auto Starting/Manual stopping	N.R.	N.R.	Not applicable ✓
	➤ Pump Hose Access	N.R.	N.R.	Not applicable ✓
	<b>Terrace level</b>			
	➤ Discharge of pump	2 pumps 240 LPM	Provided	M.R.
	➤ Head of the pump	45 mtr	Provided	M.R. ✓
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R. ✓
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	N.R.	30,00 ltrs	M.R.

	➤ Draw -off connection	Required	Provided	M.R
	➤ Fire service inlet	Required	Provided	M.R
	➤ Access to tank	Required	Provided	M.R
	➤ Overhead Tank Capacity	20,000 ltrs	Provided	M.R
<b>15</b>	<b>Exit Signage.</b>			
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N.A	N.A.	Not applicable
	• Pressurization of Lift lobby	N.R.	N.R.	Not applicable
	• Communication In lift Car	N.A.	N.A	Not applicable
	• Fireman's Grounding Switch	N.A.	N.A.	Not applicable
	• Lift Signage	N.A	N.A.	Not applicable
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M.R
<b>18.</b>	<b>Refuge Area</b>			
	➤ Total Area	N.R.	N.R.	Not applicable
	➤ Location	N.R.	N.R.	Not applicable
<b>19.</b>	<b>Fire Control Room</b>			
	➤ Detector System Panel	Required	Provided	M.R
	➤ Flow Switch Panel	Required	Provided	M.R
	➤ PA system Panel	Required	Provided	M.R
	➤ Batter backup	Required	Provided	M.R
	➤ Building Floor plans	Required	Provided	M.R

20.	Special Fire Protection Systems for  Protection of special Risks, if any:	N.R.	N.R.	Not applicable
-----	---	------	------	----------------

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

*[Handwritten Signature]*  
10/1/12

Signature of the Inspection Officer

Signature of the Inspection Officer

Name *Sunil chawdhary*

Name

Designation *D.O.*

Designation