

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2012/1069

Dated: 23/03/2012

FIRE SAFETY CERTIFICATE

Certified that the **United Westend Restaurant** located at Ground floor and first floor & first floor at 29, Central Market, Punjabi Bagh West, New Delhi-26 was granted NOC by this department vide letter No. F6/DFS/MS/EH/2009/515 dated 19/02/2009. The premises was re-inspected by the officers concerned of this department on 21/03/2012 in the presence of Sh. Chandan Singh and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit Restaurant occupancy with effect from 21/03/2012 for a period of three years subject to conditions printed below.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily openable by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression/protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the license.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010.



Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Additional Commissioner of Police (Lic) 1st Floor police Station Defense colony new Delhi.
2. The proprietor **United Westend Restaurant** 29, Central Market, Punjabi Bagh West, Delhi

May kindly peruse letter no Nil dated 03-02-2012 received from proprietor United west Ends Restaurant & Bar regarding issue of NOC in r/o their Restaurant situated at 29 Central Market, Punjabi Bagh West, New Delhi 26. The premise was inspected by the Divisional Officer (MN) and Assistant Divisional Officer (MN) from fire safety point of view & the status is put up on prescribed Performa.

1. Name & address of the building : United West Ends Restaurant & Bar, 29, Central Market, Punjabi Bagh West, New Delhi 26.
2. Type of Occupancy : Class -D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : L. No. F6/DFS/MS/EH/2009/515 dated 19/02/2009
5. Fire Safety directives letter No. : As per Sr. No 4
6. Date of inspection : 21.03.2012
7. Name of the Inspecting Officers : DO (MN) and ADO (MN)
8. Name and designation of officers
From the building side : Mr. Chandan Singh (Manager)
9. Year of Construction : -
10. Applicant's letter No. : Nil dated 03/02/2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

| S. No. | Minimum Standards on fire Prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | Required | P | M.R |
| | • Gate width | 4.5 | P | - |
| | • Width of internal road | N/R | N/R | N/R |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | 2 | P | M.R |
| | • Upper Floors | 2 | 2 | M.R |
| | • Basement | 2 | 2 | M.R |

| | | | | |
|--------------|--|--|--------------------------|----------------|
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floors | Two exits are required 1.10mtr&90cm | Provided | Renewal M.R |
| | <ul style="list-style-type: none"> Basement | 1.10mtr&90cm | P | Renewal M.R |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door | R | P | N/R |
| | <ul style="list-style-type: none"> Pressurization | N/R | N/R | N/R |
| | d. No. of continuous staircases to terrace | | | |
| | e. Width of Corridor | Halls only | Halls only | M.R |
| f. Door size | | | M.R of the Restaurant | |
| 3. | Compartmentation. | | | |
| | <ul style="list-style-type: none"> Fire check door | R | P | N/A |
| | <ul style="list-style-type: none"> Sealing of electrical shafts | NA | N/A | |
| | <ul style="list-style-type: none"> Fire Rating of shaft door | R | R | M.R |
| | <ul style="list-style-type: none"> Water Curtain | R | R | M.R |
| | <ul style="list-style-type: none"> Fire Dampers | R | R | M.R |
| 4. | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> Basements | R | Exhaust | M.R |
| | <ul style="list-style-type: none"> Upper floors | N/R | N/R | M.R |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers | 06 | Provided in the | M.R of the |

| | | | | |
|------------|---|---------------------------|---|---------------------------------|
| | <ul style="list-style-type: none"> Types IS marking | 03ABC & 03CO ² | restaurant | restaurant |
| | | | 03 ABC & 03CO ² provided in the restaurant | M.R of restaurant |
| | | required | Provided in the restaurant | M.R of restaurant |
| 6. | First-Aid Hose Rees. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor | 01 | Available in the restaurant | M.R |
| | <ul style="list-style-type: none"> Length of hose reel hose | 30 m R | P | M.R |
| | <ul style="list-style-type: none"> Nozzle diameter | 5 mm R | P | M.R |
| 7. | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors | Required | Smoke & Heat detectors provided in the restaurant | Provided in the restaurant /M.R |
| | <ul style="list-style-type: none"> Location of Main Panel | G.F. | P | M.R |
| | <ul style="list-style-type: none"> Location of Repeater Panel | At each floor | P | M.R |
| | <ul style="list-style-type: none"> Alternate source of power | R | P | M.R |
| | <ul style="list-style-type: none"> Hooter's Location | R | P | M.R |
| 8. | MOEFA | Required | Provided | M.R |
| 9. | Public Address System. | Required | Provided | M.R |
| 10. | Automatic Sprinkler system | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor | Required | Provided at first floor | MR |
| | | N/R | P | M.R |

| | | | | |
|------------|---|------------------|------------------------------|----------------------------------|
| | <ul style="list-style-type: none"> Sprinkler above false ceiling | Required | Provided in the restaurant | Provided in the restaurant /M.R |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer | 100m.m. Required | Provided | Available in the Restaurant/M.R. |
| | <ul style="list-style-type: none"> Number of hydrants per floor | 01 | P | M.R |
| | <ul style="list-style-type: none"> Hose Box | 01 | P | M.R |
| 12. | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants | Not Required | Available for the restaurant | M.R. |
| | <ul style="list-style-type: none"> Hose Box | N/R | N/R | M.R |
| 13. | Pumping Arrangements. | | | |
| | Ground Level | | | |
| | ➤ Discharge of main pump | N/R | N/R | - |
| | ➤ Head of Main pump | - | - | - |
| | ➤ Number of main pumps | - | - | - |
| | ➤ Jockey Pump out put | - | - | - |
| | ➤ Jockey pump head | - | - | - |
| | ➤ Standby pump out put | - | - | - |
| | ➤ Standby pump Head | - | - | - |
| | ➤ Auto Starting/Manual stopping | - | - | - |
| | ➤ Pump Hose Access | | | |

| | | | | |
|------------|---|---------------------|----------------------------------|------|
| | Terrace level | | | |
| | ➤ Discharge of pump | 450 LPM 81802PM | Provided in the Restaurant | M.R |
| | ➤ Head of the pump | 50mtr | P | M.R |
| | ➤ Power supply | R | P | M.R |
| | ➤ Auto Starting of pump | R | P | M.R |
| 14. | Captive Water Storage for fire fighting. | | | |
| | Underground tank capacity | Not Required | N/A | M.R |
| | ➤ Draw -off connection | N/R | N/R | M.R |
| | ➤ Fire service inlet | N/R | N/R | M.R |
| | ➤ Access to tank | N/R | N/R | M.R |
| | ➤ Overhead Tank Capacity | Required 5,000 ltrs | Available with the Restaurant | M.R |
| 15 | Exit Signage. | Required | Provided in the restaurant | M.R |
| 16. | Provision of Lifts | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | Required | Provided | M.R |
| 18. | Refuge Area | | | |
| | ➤ Total Area | N.R. | N.A. | N.A. |

| | | | | |
|-----|---|----------|------------------------------|------|
| | ➤ Location | N.R. | N.A. | N.A. |
| 19. | Fire Control Room | | | |
| | ➤ Detector System Panel | Required | Provided with the Restaurant | M.R |
| | ➤ Flow Switch Panel | R | P | M.R |
| | ➤ PA system Panel | R | P | M.R |
| | ➤ Batter backup | R | P | M.R |
| | ➤ Building Floor plans | N/R | N/R | M.R |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any: | N.A. | N.A. | N.A. |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

SS Tuli

Name

SUNIL CHAWANARYA

Designation

ADD (M/N)

Designation

D.O.