

FORM 'H'
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/Hospital/2012/1035

Dated: 23/03/12

FIRE SAFETY CERTIFICATE

Certified that the Vivekanand Pratishthan Parishad Vivekanand Hospital Yogashram, Patparganj Road, Khureji, Delhi-51, comprised of basement ground plus three upper floors was granted NOC by this department vide letter No.F.6/DFS/MS/HOSPITAL/2004/2005 dated 03.09.2004. The premises was re-inspected by the officer concerned of this department on 01.02.12 in the presence of Mr. Acharya Vikrmaditya Founder of the Vivekanand Pratishthan Parishad, and found that the hospital have deemed complied with the fire prevention and fire safety requirements in accordance with the directives issued earlier by this department and that the building is fit for occupancy class C "Hospital Building" with effect from 23/03/12. Renewed for a period of three years, subject to conditions printed overleaf.

Issued on..... 23/03/12 at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service


21.3.12

Copy to-

Mr. Acharya Vikrmaditya
Founder -Vivekanand Pratishthan Parishad
Vivekanand Hospital Yogashram,
Patparganj Road, Khureji, Delhi-51.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. Basement shall be used as per conditions of BBL.

INSPECTION REPORT

1. Name & address of the building : Vivekanand Pralikhitan Parishad
Vivika Nand Hospital Yogeeshram
Parpar Gang Road Khurangi -51
2. Type of Occupancy : Institutional
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F.61(MS) DFS/HOSPITAL/2009/ 2005 Dated: 3.9.2009
5. Fire Safety directives letter No : F.61(MS) DFS/Hospital/2001/328 dt. 23.2.2001
6. Date of inspection : 1.2.2012
7. Name of the Inspecting Officers : ADO Sunesh Singh
8. Name and designation of officers from the building side : Mr. Vikramaditya
9. Year of Construction : 2004
10. Applicant's letter No. : N/1 dated 24.1.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 		6 M — —	30 H 3.5 M —
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		1	1 MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 		1	1 MR
	b. Width of staircases		2	2 MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 		2 M	2.4 M MR
	c. Protection of exits		2 M	2.4 M MR
	<ul style="list-style-type: none"> • Fire check door • Pressurization 		2 M	2 M MR
	e. No. of continuous staircases to terrace		1	1
	g. Width of Corridor		2.5 M	MIR
	h. Door Size		1 M	MIR

3	Compartmentation.		Provided	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.		Provided exhaust in Basement	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers	Required		
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 No CO ₂ + WaterCO ₂ ISI marked	10 CO ₂ + WaterCO ₂ ISI	MR MR MR
6	First-Aid Hose Reels.	Required		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	5 m 30 m 5 mm	1 at each floor 30 m 5 mm	MIR MR MR
7	Automatic fire detection and alarming system.	Provided		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Heat & Smoke Main entrance Generator On each floor	Heat & Smoke Main entrance Generator Each floor	MR MR MIR MR
8	MOEFA	Provided	Each floor	MR
9	Public Address System.			
10	Automatic Sprinkler System.	Provided		
	<ul style="list-style-type: none"> • Basement 	Basement	Basement	MIR

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants	100 mm	100 mm	MIR
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	1	1	MR
		1	1	MR
12	Yard Hydrants.	Provided		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	One	one	MR
		One	one	MIR
13	Pumping Arrangements.	1, 450 LPM	1, 450 LDM	MR
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM	450 LPH	MR
		60 M	60 M	MIR
		1	1	1
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
		900 LPM	9 LPM	MR
		60 M	60 M	MR
		—	—	—
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.	100000 GL	100000 GL	MR
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	provided	provided	MR

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<u>—</u>	<u>✓</u>	<u>✓</u>
		<u>25000 ltr</u>	<u>25000 ltr</u>	<u>HSR</u>
15	Exit Signage.	<u>Provided</u>	<u>Provided</u>	<u>MIR</u>
16	Provision of Lifts.	<u>N/A</u>		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	<u>—</u>	<u>—</u>	<u>—</u>
17	Standby power supply	<u>—</u>	<u>✓</u>	<u>—</u>
18	Refuge Area.	<u>N/A</u>		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	<u>—</u>	<u>—</u>	<u>—</u>
19	Fire Control Room	<u>N/A</u>		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PAi System Panel • Batter backup • Building Floor Plans 	<u>—</u>	<u>—</u>	<u>—</u>
20	Special Fire Protection Systems for Protection of special Risks, if any:	<u>N/A</u>		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the D- Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

A handwritten signature in blue ink, appearing to read "S. Singh".

Signature of the Inspecting Officer

Name

Suresh Singh

Designation

A.D.O.

Signature of the Inspecting Officer

Name

Designation