

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI – 110001**

No: F 6/DFS/MS/2012/ *School/1139*

Dated:- *28/03/12*

**FIRE SAFETY CERTIFICATE**

Certified that the *Hansraj Model School (Recognised) Ramesh Enclave*  
*Opp Sect-21, Rohini Delhi* located at *Ramesh Enclave, Opp Sect-21 Rohini*  
*Delhi* comprised of *Ground + one upper floor* *Ground floor* occupied  
by *Hansraj Model School* was issued NOC vide this office letter  
No. *F.6/MS/DFS/2006/2885* Dated: *27/9/06*. The premises was re-inspected by the  
officer concerned of this department on *28/1/12* and observed that all the fire  
prevention and fire safety arrangements as provided in the premises found in good working  
condition. The premises have therefore, deemed complied with the requirement under Rule 33  
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class  
*Educational* with effect from *28/03/12* for a period of  
*03 years* in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under  
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on *28/03/12* at New Delhi.



Chief Fire Officer  
Delhi Fire Service

*etc*

Copy to:-  
1. *The Director of Edu. (AET)*  
*Sectt. of NET of Delhi*  
*Old Sectt. Delhi*

2. *The Manager*  
*Hansraj Model School*  
*Ramesh Enclave*  
*Opp Sect-21, Rohini Delhi &c.*

1. All the means of escape shall be kept free of all type of obstruction all the time.
  2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
  3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
  4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
  5. Basement shall be used as per NBC.
  6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building Hansraj Model School, Ramesh Enclave, Sect. 21
2. Type of Occupancy Educational -Delhi-86
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/ms/DFS/2005/2885 Dated: 27-9-06
5. Fire Safety directives letter No : 262-362 dt. 17-1-2005
6. Date of inspection 28-2-2012
7. Name of the Inspecting Officers: ADO - SHIVAM LAL
8. Name and designation of officers Sh. Bhupinder Kumar (Manager)  
from the building side
9. Year of Construction : 2006 & 10. (G+1) \* First floor = 2010.
10. Applicant's letter No. Hms/12/011 dated 9-12-2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular NBC Dir. Edum. Requirement 17/11/2005	Provided at site	Remarks MR/NN
1	<b>Access to building</b>			
	• Road width	Accessible	6 mts.	M/R
	• Gate width	—	4 mts.	M/R
	• Width of internal road	—	4 mts	M/R
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	2	2	M/R
	• Upper Floors	2	2	—
	• Basements	NIL	NIL	—
	b. Width of staircases	1.5 m	1.60 m & 1.50 m	M/R
	• Upper Floors	1.5 m	1.6 mts & 1.5 mt	—
	• Basements	NIL	NIL	—
	c. Protection of exits			
	• Fire check door	NR	NR	—
	• Pressurization	NR	NR	—
	e. No. of continuous staircases to terrace	2	2	M/R
	g. Width of Corridor	—	2.40 m	M/R
	h. Door Size	1 m.	1 m	M/R





	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
11	<b>Internal Hydrants</b>			NR
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b>			NR
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>			NR
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
14	<b>Captive Water Storage for fire fighting.</b>			NR
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>			



	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			
15	<b>Exit Signage.</b>	G+1	NR	MIR
16	<b>Provision of Lifts.</b>		NA	
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	<b>Standby power supply</b>		NR	
18	<b>Refuge Area.</b>		N/A	
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>			
19	<b>Fire Control Room</b>		NR	
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:		Nil	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the De Facto Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

✓

Signature of the Inspecting Officer

Name

Designation

D.O. (New)

Shylal  
29/2/2012

Signature of the Inspecting Officer

Name SHYAM LAL

Designation ADO